



NPS	MAT'L CLASS	OPER.		DESIGN		TEST		INSULATION		PAINT CODE	PWHT	NDE													
		PRESS. (kg/cm2g)	TEMP. (°c)	PRESS. (kg/cm2g)	TEMP. (°c)	PRESS. (kg/cm2g)	MEDIUM	TYPE	TH'K (mm)																
3'	E2A2E	27.4	330	31.5	360	59.66	HYDRO	S	150MM	F	Y	100													
6'	E2A2E	27.4	330	31.5	360	59.66	HYDRO	S	150MM	F	Y	100													
													0	28-APR-16	ISSUED FOR CONSTRUCTION	STC	BSK	HJP	P&ID NO.	AA00-PID-0021-023	UNIT NO.	00	STRESS	YES	
													1	23-DEC-16	REVISED AS MARKED	STC	BSK	HJP	GAD NO.	00-DW-PI-1104	LINE NO.	6'-SER-00023010-E2A2E-S			
													REV.	DATE	DESCRIPTION	BY	CHECK'D	APPR'D	DWG NO.	U00A-SER-00023010-41				REV.	0