Door Schedule_SSG OKS

Revision	Building	Level	Door Number	Type Mark	To Room	To Room: Number	From Room	Leaf Type	Panel 1 Height	Panel 1 Width	Panel 2 Width	Fire Rating	Acoustic Rating	Undercut Height	Frame Type	Architrave	Door Closer	Seals	Elec Strike/Mag Lock	Hold Open	Card Reader/Key Pad	Push to Exit	Locks	Keying Cylinder	Front Door Protection	Front DP Height	Rear Door Protection	Rear DP Height	Auto Door	Comments
P3	RACF	RACF Level 2	R.222.1	D01	S BED (A MIR.)	R.222	CIRCULATION	C4	2040	1020				20	ST1	2 SIDE							KEY	SS	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.222.2	D02	S BED (A MIR.)	R.222	S BED (A MIR.)	A2	2040	920				20	ST1	1 SIDE							PRI1		Protection. : Nil	0	Protection. : Nil	0		LIFT OFF HINGE
P3	RACF	RACF Level 2	R.223.1	D01	S BED (A)	R.223	CIRCULATION	C4	2040	1020				20	ST1	2 SIDE							KEY	SS	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.223.2	D02	S BED (A)	A2	S BED (A)	A2	2040	920				20	ST1	1 SIDE							PRI1		Protection. : Nil	0	Protection. : Nil	0		LIFT OFF HINGE
P3	RACF	RACF Level 2	R.224.1	D01	P BED (F)	R.224	CIRCULATION	C4	2040	1020				20	ST1	2 SIDE							KEY	SS	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.224.2	D02	P BED (F)	R.224	P BED (F)	A2	2040	920				20	ST1	1 SIDE							PRI1		Protection. : Nil	0	Protection. : Nil	0		LIFT OFF HINGE
P3	RACF	RACF Level 2	R.225.1	D01	S BED (A)	R.225	CIRCULATION	C4	2040	1020				20	ST1	2 SIDE							KEY	SS	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.225.2	D02	S BED (A)	R.225	S BED (A)	A2	2040	920				20	ST1	1 SIDE							PRI1		Protection. : Nil	0	Protection. : Nil	0		LIFT OFF HINGE
P3	RACF	RACF Level 2	R.226.1	D01	S BED (A MIR.)	R.226	CIRCULATION	C4	2040	1020				20	ST1	2 SIDE							KEY	SS	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.226.2	D02	S BED (A MIR.)	R.226	S BED (A MIR.)	A2	2040	920				20	ST1	1 SIDE							PRI1		Protection. : Nil	0	Protection. : Nil	0		LIFT OFF HINGE
P3	RACF	RACF Level 2	R.227.1	D01	S BED (A)	R.227	CIRCULATION	C4	2040	1020				20	ST1	2 SIDE							KEY	SS	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.227.2	D02	S BED (A)	R.227	S BED (A)	A2	2040	920				20	ST1	1 SIDE							PRI1		Protection. : Nil	0	Protection. : Nil	0		LIFT OFF HINGE
P3	RACF	RACF Level 2	R.228.1	D01	S BED (A MIR.)	R.228	CIRCULATION	C4	2040	1020				20	ST1	2 SIDE							KEY	SS	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.228.2	D02	S BED (A MIR.)	R.228	S BED (A MIR.)	A2	2040	920				20	ST1	1 SIDE							PRI1		Protection. : Nil	0	Protection. : Nil	0		LIFT OFF HINGE
P3	RACF	RACF Level 2	R.229.1	D01	ACC BED (LHS)	R.229	CIRCULATION	C4	2040	1020				20	ST1	2 SIDE							KEY	SS	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.229.2	D17	ACC BED (LHS)	R.229	ACC BED (LHS)	A2	2040	970				20	ST1	1 SIDE							PRI1		Protection. : Nil	0	Protection. : Nil	0		LIFT-OFF HINGE
P3	RACF	RACF Level 2	R.230.1	D01	P BED (C MIR.)	R.230	CIRCULATION	C4	2040	1020				20	ST1	2 SIDE							KEY	SS	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.230.2	D02	P BED (C MIR.)	A2	2040	920						20	ST1	1 SIDE							PRI1		Protection. : Nil	0	Protection. : Nil	0		LIFT OFF HINGE
P3	RACF	RACF Level 2	R.231.1	D01	P BED (F MIR.)	R.231	CIRCULATION	C4	2040	1020				20	ST1	2 SIDE							KEY	SS	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.231.2	D02	P BED (F MIR.)	R.231	P BED (F MIR.)	A2	2040	920				20	ST1	1 SIDE							PRI1		Protection. : Nil	0	Protection. : Nil	0		LIFT OFF HINGE
P3	RACF	RACF Level 2	R.232.1	D01	P BED (B)	R.232	CIRCULATION	C4	2040	1020				20	ST1	2 SIDE							KEY	SS	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.232.2	D02	P BED (B)	R.232	P BED (B)	A2	2040	920				20	ST1	1 SIDE							PRI1		Protection. : Nil	0	Protection. : Nil	0		LIFT OFF HINGE
P3	RACF	RACF Level 2	R.232.3	D03	P BED (B)	R.232	P BED (A)	A5	2040	920			RW45	20	ST3	1 SIDE		AS					KEY	SS	Protection. : Nil	0	Protection. : Nil	0		INTERCONNECTING ROOM - AS-46-INTERCON SYSTEM
P3	RACF	RACF Level 2	R.233.1	D01	P BED (A)	R.233	CIRCULATION	C4	2040	1020				20	ST1	2 SIDE							KEY	SS	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.233.2	D02	P BED (A)	A2	2040	920						20	ST1	1 SIDE							PRI1		Protection. : Nil	0	Protection. : Nil	0		LIFT OFF HINGE
P3	RACF	RACF Level 2	R.233.3	D03	P BED (A)	R.233	P BED (B)	A5	2040	920			RW45	20	ST3	1 SIDE		AS					KEY	SS	Protection. : Nil	0	Protection. : Nil	0		INTERCONNECTING ROOM - AS-46-INTERCON SYSTEM
P3	RACF	RACF Level 2	R.252.1	DF10	CIRCULATION	R.252	CIRCULATION	F5	2040	920	920	1HR		0	ST3	2 SIDE	DC	FS		HOM					Protection. : Nil	0	Protection. : Nil	0		PULL HANDLE TO PULL SIDE ONLY. PUSH PLATE TO PUSH SIDE.
P3	RACF	RACF Level 2	R.253.1	DF02	STAIR 01	R.253	CIRCULATION	F5	2040	920	920	1HR		0	ST3	1 SIDE	DC	FS	ES		CR				Protection. : Nil	0	Protection. : Nil	0		
C1	RACF	RACF Level 2	R.254.1	DF10	CIRCULATION	R.254	BOH CIRCULATION	F5	2040	920	920	1HR		0	ST3	1 SIDE	DC	FS	ML		CR	PEX			Protection : DPR1	900	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.254.2	DF16	CIRCULATION	R.254	ELEC	F5	2040	770	770	1HR		0	ST3	1 SIDE		FS					KEY	MM	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.254.3	D07	CIRCULATION	R.254	HYD	A2	2040	970				20	ST1	1 SIDE							KEY	MM	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.254.4	D19	CIRCULATION	R.254	LINEN	A2	2040	970	970			20	ST1	1 SIDE									Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.256.1	D07	STORE	R.256	LIBRARY - WEST	A2	2040	970				20	ST1	1 SIDE	DC		ES		CR				Protection. : Nil	0	Protection. : Nil	0		
C1	RACF	RACF Level 2	R.257.1	D17	ACC WC	R.257	CIRCULATION	A2	2040	970				20	ST1	1 SIDE	DC						PRI2		Protection : DPR2	140	Protection : DPR2	140		ALLOW CEILING AIR TRANSFER GRILLE
C1	RACF	RACF Level 2	R.258.1	OP02	ACTIVITY	R.258	CIRCULATION - WEST	D1	2040	980	980			0	AL1			AS							Protection. : Nil	0	Protection. : Nil	0		2100H GLAZED OPERABLE WALL - 4 EQUAL PANELS - REFER ELEVATION
P3	RACF	RACF Level 2	R.260.1	DF10	CIRCULATION	R.254	CIRCULATION - WEST	F5	2040	920	920	1HR		0	ST3	2 SIDE	DC	FS		HOM					Protection. : Nil	0	Protection. : Nil	0		PULL HANDLE TO PULL SIDE ONLY. PUSH PLATE TO PUSH SIDE.
P3	RACF	RACF Level 2	R.260.2	DF10	CIRCULATION - WEST	R.260	CIRCULATION - WEST	F5	2040	920	920	1HR		0	ST3	2 SIDE	DC	FS		HOM					Protection. : Nil	0	Protection. : Nil	0		PULL HANDLE TO PULL SIDE ONLY. PUSH PLATE TO PUSH SIDE.
C1	RACF	RACF Level 2	R.261.1	D14	KITCHEN - WEST	R.261	PANTRY	C2	2040	1020				20	ST1	1 SIDE	DC		ES		CR				Protection : DPR2	140	Protection : DPR1	140		VISION PANEL
C1	RACF	RACF Level 2	R.262.1	D14	PANTRY	R.262	BOH CIRCULATION	C2	2040	1020				20	ST1	-	DC				CR	PEX			Protection : DPR1	900	Protection : DPR1	300	AUTO HINGE	VISION PANEL
C1	RACF	RACF Level 2	R.264.1	D53	AIRLOCK/LOBBY	R.264	CIRCULATION - WEST	S-D2	2040	970				20	AL2	-					KP	PEX			Protection. : Nil	0	Protection. : Nil	0	AUTO SLIDE	REFER INTERNAL GLAZING SCHEDULE. CONTRAST STRIP TO AS.1288
C1	RACF	RACF Level 2	R.264.2	D53	CIRCULATION - EAST	R.272	AIRLOCK/LOBBY	S-D2	2040	970				20	AL2	-					KP	PEX			Protection. : Nil	0	Protection. : Nil	0	AUTO SLIDE	REFER INTERNAL GLAZING SCHEDULE. CONTRAST STRIP TO AS.1288
C1	RACF	RACF Level 2	R.265.1	D40	STAFF HUB	R.265	DINING - WEST	D1	2040	970				20	AL1	-	DC		ES		CR				Protection. : Nil	0	Protection. : Nil	0		ALLOW FOR DECORATIVE FILM
C1	RACF	RACF Level 2	R.265.2	D40	STAFF HUB	R.265	DINING - EAST	D1	2040	970				20	AL1	-	DC		ES		CR				Protection. : Nil	0	Protection. : Nil	0		ALLOW FOR DECORATIVE FILM
P3	RACF	RACF Level 2	R.267.1	D08	CLEANER	R.267	BOH CIRCULATION	C2	2040	920				20	ST1	-	DC		ES		CR				Protection : DPR1	900	Protection : DPR1	900		VISION PANEL
P3	RACF	RACF Level 2	R.268.1	D08	SLUICE	R.268	BOH CIRCULATION	C2	2040	920				20	ST1	-	DC								Protection : DPR1	900	Protection : DPR1	900		VISION PANEL
P3	RACF	RACF Level 2	R.269.1	D08	TREATMENT	R.269	BOH CIRCULATION	C2	2040	920				20	ST1	-	DC		ES		CR				Protection : DPR1	900	Protection : DPR1	300		VISION PANEL
C1	RACF	RACF Level 2	R.270.1	D14	PANTRY	R.270	BOH CIRCULATION	C2	2040	1020				20	ST1	-	DC				CR	PEX			Protection : DPR1	900	Protection : DPR1	300	AUTO HINGE	VISION PANEL
C1	RACF	RACF Level 2	R.271.1	D14	KITCHEN - EAST	R.271	PANTRY	C2	2040	1020				20	ST1	1 SIDE	DC		ES		CR				Protection : DPR2	140	Protection : DPR1	140		VISION PANEL
P3	RACF	RACF Level 2	R.272.1	DF10	CIRCULATION	R.277	CIRCULATION - EAST	F5	2040	920	920	1HR		0	ST3	2 SIDE	DC	FS		HOM					Protection. : Nil	0	Protection. : Nil	0		PULL HANDLE TO PULL SIDE ONLY. PUSH PLATE TO PUSH SIDE.
P3	RACF	RACF Level 2	R.272.2	DF10	CIRCULATION - EAST	R.272	CIRCULATION	F5	2040	920	920	1HR		0	ST3	2 SIDE	DC	FS		HOM					Protection. : Nil	0	Protection. : Nil	0		PULL HANDLE TO PULL SIDE ONLY. PUSH PLATE TO PUSH SIDE.
P3	RACF	RACF Level 2	R.272.4	DF16	CIRCULATION - EAST	R.272	ELEC	F5	2040	770	770	1HR		0	ST3	1 SIDE		FS					KEY	MM	Protection. : Nil	0	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.274.1	DF04	CIRCULATION - EAST	R.272	COMMS	F7	2040	920		2HR		0	ST3	1 SIDE	DC	FS					KEY	MM	Protection. : Nil	0	Protection. : Nil	0		
C1	RACF	RACF Level 2	R.275.1	D17	ACC WC	R.275	CIRCULATION	A2	2040	970				20	ST1	1 SIDE	DC						PRI2		Protection : DPR2	140	Protection : DPR2	140		ALLOW CEILING AIR TRANSFER GRILLE
P3	RACF	RACF Level 2	R.276.1	DF02	STAIR 02	R.276	CIRCULATION	F5	2040	920	920	1HR		0	ST3	1 SIDE	DC	FS	ES		CR				Protection. : Nil	0	Protection. : Nil	0		
C1	RACF	RACF Level 2	R.277.1	DF10	CIRCULATION	R.277	BOH CIRCULATION	F5	2040	920	920	1HR		0	ST3	1 SIDE	DC	FS	ML		CR	PEX			Protection : DPR1	900	Protection. : Nil	0		
P3	RACF	RACF Level 2	R.277.2	D19	CIRCULATION	R.277	LINEN	A2	2040	970	970			20	ST1	1 SIDE									Protection. : Nil	0	Protection. : Nil	0		
C1	RACF	RACF Level 2	R.279.1	G03	COMMUNAL TERRACE	R.280	PLANTED TERRACE	GATE	1500	1000				0	-	-	DC						KEY	SS						VERTICAL BATTEN GATE TO MATCH FENCING
C1	RACF	RACF Level 2	R.281.1	G03	PLANTED TERRACE	R.281	COMMUNAL TERRACE	GATE	1500	1000				0	-	-	DC						KEY	SS						VERTICAL BATTEN GATE TO MATCH FENCING
C1	RACF	RACF Plant Deck	R.301.1	DF01	STAIR 02	R.301	ROOF PLANT	F7	2040	920		2HR		0	ST3	-	DC	FS					KEY	MM	Protection. : Nil	0	Protection. : Nil	0		ENSURE EXTERNAL GRADE

Door Schedule_SSG OKS_External Glazed Sliders

Revision	Building	Level	Door Number	System Number	Location	Construction Type	Closer	Seals	Elec Strike/Mag Lock	Card Reader/Key Pad	Lock	Keying Cylinder	Auto Door	Comments
C1	RACF	Ground Floor	R.G.06	GS01	R.G01 AIRLOCK	GLAZED / ALUMINIUM. REFER WINDOW SCHEDULE FOR DIMENSIONS				KP			AUTO SLIDE	RECESSED PELMET WITHIN AIRLOCK
C1	RACF	Ground Floor	R.G.12	GS28	R.G14 CIRCULATION	GLAZED / ALUMINIUM. REFER WINDOW SCHEDULE FOR DIMENSIONS				CR			AUTO SLIDE - NO SENSOR	BRUSH SEALS REQUIRED
C1	RACF	Ground Floor	R.G.17	GS26	R.G22 LOUNGE/BAR	GLAZED / ALUMINIUM. REFER WINDOW SCHEDULE FOR DIMENSIONS				CR			AUTO SLIDE - NO SENSOR	BRUSH SEALS REQUIRED
C1	RACF	Ground Floor	R.G.27	GS04	R.G28 AIRLOCK	GLAZED / ALUMINIUM. REFER WINDOW SCHEDULE FOR DIMENSIONS				KP			AUTO SLIDE - NO SENSOR	
P3	RACF	Ground Floor	R.G.32	GS05	R.G38 STAFF ROOM	GLAZED / ALUMINIUM. REFER WINDOW SCHEDULE FOR DIMENSIONS					KEY	SS		ALLOW FOR LARGE D PULL HANDLE
P3	RACF	RACF_Level 1	R.1.12	GS06	R.159 DINING-WEST	GLAZED / ALUMINIUM. REFER WINDOW SCHEDULE FOR DIMENSIONS					KEY	SS	AUTO SLIDE - NO SENSOR	BRUSH SEALS REQUIRED
P3	RACF	RACF_Level 1	R.1.14	GS06	R.173 DINING-EAST	GLAZED / ALUMINIUM. REFER WINDOW SCHEDULE FOR DIMENSIONS					KEY	SS	AUTO SLIDE - NO SENSOR	BRUSH SEALS REQUIRED
P3	RACF	RACF Level 2	R.2.12	GS06	R.259 DINING-WEST	GLAZED / ALUMINIUM. REFER WINDOW SCHEDULE FOR DIMENSIONS					KEY	SS	AUTO SLIDE - NO SENSOR	BRUSH SEALS REQUIRED
P3	RACF	RACF Level 2	R.2.14	GS06	R.273 DINING-EAST	GLAZED / ALUMINIUM. REFER WINDOW SCHEDULE FOR DIMENSIONS					KEY	SS	AUTO SLIDE - NO SENSOR	BRUSH SEALS REQUIRED

Door Schedule Legend

All doors to be obtained from an approved manufacturer and to carry a 2 (two) year Warranty against warping or distortion.
Leading edges of pairs of doors are not to be rebated unless required for fire / smoke doors.

LEAF TYPES

A2 **Flush panel door nom. 40mm thick, internal grade.**
Solid frame of ex. 38mm KDHW.
Solid MR particleboard core.
Faced with 4.8mm redicoat hardboard both sides, ready for paint finish.
KDHW edge strip to stile edges.

A4 **Flush panel door nom. 40mm thick, Internal grade veneer faced**
Solid frame of ex. 38mm KDHW.
Solid MR particleboard core.
Faced with 4mm Victorian Ash timber veneer plywood on both sides.
KDHW edge strip to stile edges.

A5 **Flush panel door min. 40mm thick**
Solid frame of ex. 38mm KDHW.
Solid MR particleboard core, minimum mass of door of 22kg/m2.
Faced with 4.8mm redicoat hardboard both sides, ready for paint finish.
KDHW strip to all edges.
Door grilles not permitted for acoustic reasons.

A8 **Flush panel door nom. 40mm thick (min. 35mm thick), internal grade, Smoke Door.**
Solid frame of ex. 38mm KDHW.
Solid MR particleboard core.
Faced with 4.8mm redicoat hardboard both sides, ready for paint finish.
KDHW edge strip to stile edges.

A9 **Flush panel door nom. 40mm thick, internal grade.**
WITH FACE FIXED INTERIOR FINISH. REFER ELEVATIONS AND SCHEDULE.
Solid frame of ex. 38mm KDHW.
Solid MR particleboard core.
Faced with 4.8mm redicoat hardboard both sides, ready for paint finish. And fixing of interior lining.
KDHW edge strip to stile edges.

C2 **Flush panel door nom. 40mm thick, with viewing panel**
(For double doors, vision panel only in active leaf).
Solid frame of ex. 38mm KDHW.
Solid MR particleboard core.
Faced with 4.8mm redicoat hardboard both sides, ready for paint finish.
KDHW edge strip to stile edges.
Glazed viewing panel 200mm wide x 950mm high, set back 200mm from latch edge with bottom 900mm above floor level.
Viewing panel inset within thickness of door, rebated and glazed with 6.38mm laminated glass and 19 x 13mm square KDHW beads, to finish flush with face of door.

C4 **Custom panel bedroom door. Solid Core door 40mm thick, internal grade.**
Custom panelling to match wall panelling details, refer door elevation

D1 **Full glazed aluminium door with midrail**
refer Materials Schedule - Metalwork

D2 **Full glazed aluminium door without midrail**
refer Materials Schedule - Metalwork

F5 **Fire rated door, 60 minutes**
Pyropanel 60 minute Fire rated door and frame to achieve FRL - / 60 / 30.
Facing : MDF or hardboard. External Grade where noted.
Installation : in accordance with manufacturer's instructions.

F7 **Fire rated door, 120 minutes**
Pyropanel 120 minute Fire rated door and frame to achieve FRL - / 120 / 30.
Facing : MDF or hardboard. External Grade where noted.
Installation : in accordance with manufacturer's instructions.

F10 **Fire rated door, 60 minutes, vision panel**
Pyropanel 60 minute Fire rated door and frame to achieve FRL - / 60 / 30, with Vision Panel 600 H x 100 W, as required by FER.
Facing : MDF or hardboard. External Grade where noted.
Installation : in accordance with manufacturer's instructions.

F11 **Fire rated door, 120 minutes, vision panel**
Pyropanel 120 minute Fire rated door and frame to achieve FRL - / 120 / 30. With Vision Panel 600 H x 100 W, as required by FER.
Facing : MDF or hardboard. External Grade where noted.
Installation : in accordance with manufacturer's instructions.

L **Lotus 'Acoustic sliding Door'**
refer Meterials Schedule - Metalwork

PVC **'Butcher style' PVC Door.**
TBC

S-## **Denotes Sliding Door**
Leaf construction as noted above

Refer Materials Schedule - Section 08800 Glass & Glazing for Glass Types in glazed doors.

FRAME TYPES

AL1 **Aluminium**
Aluminium frame with stop by fabricator to suit door, refer Materials Schedule - Metalwork - for frame details. Incorporates perimeter weather seals where shown AFS.

AL2 **Aluminium**
Aluminium Frame flush/ no stops, to suit surface sliding door. Refer Materials Schedule - Metalwork - for frame details.

ST1 **Steel**
Item : 1.2mm pressed zinc anneal steel frame.
Installation : Frames custom sized where required to be compatible with wall thickness and situation, including double skin walls and to be sealed to fit neatly with finished surfaces.
Finish : as specified in Section 09900 Painting.

ST3 **Steel**
Proprietary steel frame supplied with Acoustic or Fire rated door. Custom sized where required to suit wall thickness.

T1 **Timber**
refer Materials Schedule/Specification.

T3 **Timber**
Timber framed cavity sliding unit to suit door.

ARCHITRAVES

2 SIDE **ARCHITRAVES TO BOTH SIDES OF DOOR**
REFER MATERIAL SCHEDULE

1 SIDE **ARCHITRAVES TO ONE SIDE OF DOOR**
REFER MATERIAL SCHEDULE.
- NO ARCHITRAVE TO BOH AREAS
- NO ARCHITRAVE TO TILED AREAS. ALLOW INSTEAD FOR POWDERCOATED ALUMINIUM ANGLE TO FINISH TILED EDGE.

- **NO ARCHITRAVE**

PRIVACY

PRI1 **PRIVACY LATCH INTEGRATED IN DOOR HANDLE**
REFER SCHEULE

PRI2 **PRIVACY LATCH WITH VACANT/ENGAGED SYMBOL**
REFER SCHEDULE

BAL 12.5 Rating

ALL EXTERNAL DOORS TO BE TIGHT FITTING AND PROVIDED WITH WEATHER SEALS TO THE FULL PERIMETER OF THE DOOR TO PREVENT EMBER ENTRY, IN ACCORDANCE WITH AS3959-2009.

General Notes

NOTE: NOT ALL CODES MAY BE USED

DOOR SCHEDULE TO BE READ IN CONJUNCTION WITH ARCHITECTURAL DRAWING AND SPECIFICATION PACKAGES.

THIS SPECIFICATION MUST BE CHECKED AGAINST THE FINAL FLOOR PLANS RELEVANT SPECIFICATIONS.

ALL DDA/NCC SAFETY DECALS TO GLAZING TO COMPLY WITH CLAUSE 6.6 OF AS1428.1

ALL DOOR FURNITURE TO BE MOUNTED AT 1000mm FROM FINISHED FLOOR LEVEL UNLESS OTHERWISE SPECIFIED

PROVIDE ESCAPE FUNCTION TO ESCAPE DOORS IN ACCODANCE WITH THE BCA

CHECK ALL FURNITURE WITH HARDWARE SUPPLIER REPRESENTATIVE INCLUDING CODES FOR LEFT AND RIGHT DOORS AND COORDINATION OF SCHEDULED HARDWARE WITH FINAL FLOOR PLAN

FURNITURE IS TO BE GENERALLY FITTED WITH CENTRE OF LEVER HANDLE 1000mm ABOVE FLOOR, UNLESS OTHERWISE SHOWN ON DRAWINGS OR SPECIFIED IN DOOR SCHEDULE

Keying

NOTE: ALL KEYS TO BE IN A GRAND MASTER KEY SYSTEM

MASTER KEYING REQUIRED FOR ALL LOCKABLE DOORS.

XXX KEYS TO BE PROVIDED TO EACH MASTER KEYING LEVEL. PRIOR TO PLACING ORDER FOR LOCK CYLINDERS, THE CONTRACTOR IS TO CHECK WITH THE ARCHITECT/ SUPERINTENDENT REGARDING THE KEYING SCHEDULE FOR THE GRAND MASTER KEY SYSTEM. A NUMBER OF DOORS ARE TO BE KEYED ALIKE AND/OR MAISON KEYED TO OTHER LOCKS AS SHOWN ON A FUTURE KEYING SCHEDULE.

CONTRACTOR TO ENSURE ALL LOCKS ARE COMPATIBLE WITH THE EXISTING MASTER LOCK SYSTEM.

CONTRACTOR TO PROVIDE ADEQUATE OPENING ALLOWANCE FOR BI-LOCK CYLINDER.

BUILDER TO ALLOW FOR THE SULLY, INSTALLATION AND REMOVAL OF ADEQUATE QUANTITIES OF CONSTRUCTION CYLINDERS.

FINAL DETAIL OF MASTERKEYING WILL BE CLARIFIED BY CLIENT PRIOR TO PLACEMENT OF ORDER

KEYS

MM	MAINTENANCE MGR
SS	SENIOR STAFF
S	CARE STAFF
AD	ADMIN STAFF
KS	KITCHEN
LN	LAUNDRY
R	RESIDENTS

Security

CARDREADER, REFER ELECTRICAL ENGINEER DRAWINGS/ SPECIFICATION

CODEPAD, REFER ELECTRICAL ENGINEER DRAWINGS/ SPECIFICATION

REQUEST TO EXIT BUTTON, REFER ELECTRICAL ENGINEER DRAWINGS / SPECIFICATION

BREAKGLASS, REFER ELECTRICAL ENGINEER DRAWINGS/ SPECIFICATION

REED SWITCH, REFER ELECTRICAL ENGINEER DRAWINGS/ SPECIFICATION

ACCESS GROUPS

S	ALL STAFF
SS	MEDICATION STAFF ONLY
V	ALL STAFF + VISITORS
R	ALL STAFF + ILA RESIDENTS
C	ALL STAFF + CONTRACTORS
MO	MANAGEMENT STAFF ONLY

Closers

ALL CLOSERS MUST CONFORM TO EUROPEAN NORM STANDARD 1154. ALL PRODUCTS WHERE POSSIBLE MUST ACHIEVE AN EN1 RATING AT THE LOWEST SETTING, UNLESS OTHERWISE SPECIFIED.

ALL CLOSERS TO PUBLIC AND TRAFFIC AREAS MUST BE CAM ACTION, UNLESS OTHERWISE SPECIFIED

Door Grilles and Undercuts

REFER TO MECHANICAL ENGINEERS DRAWINGS FOR DOOR UNDERCUTS LOCATIONS AND DOOR GRILLE DIMENSIONS.

UNDERCUTS TO BE 25MM U.N.O.

DOOR GRILLES TO BE POWDERCOAT FINISHED TO SCHEDULED COLOUR. REFER TO FINISHES SCHEDULE.

ALL FIRE DOOR TO HAVE A MAXIMUM UNDERCUT OF 10MM FOR COMPLIANCE WITH 1905.1

Door Protection

REFER TO ASC01 MATERIALS, PRODUCTS & FINISHES SCHEDULE FOR SPECIFICATION.

APPLIED DOOR PROTECTION DPR1 DENOTES ACROVYN 4000 RIGID SHEET IN COLOUR 378 BRUSHED NICKEL (C2C SILVER)

APPLIED DOOR PROTECTION DPR2 DENOTES ACROVYN 4000 RIGID SHEET IN COLOUR TO MATCH DOOR LEAF (TBC)

APPLIED DOOR PROTECTION CODE FOLLOWED BY HEIGHT ABOVE LOWER SECTION OF DOOR.

UNLESS NOTED OTHERWISE, DOOR PROTECTION SHALL BE APPLIED TO BOTH FACES OF EACH DOOR LEAF WHERE DP HAS BEEN IDENTIFIED.

Finishes

REFER TO ASC01 MATERIALS, PRODUCTS & FINISHES SCHEDULE FOR SPECIFCATION.

ALL SOLID DOORS TO BE PAINT FINISHED (TBC)

ALL ALUMINIUM DOORS WILL BE POWDERCOAT FINISHED AS SPECIFIED. ALL PRESSED METAL DOOR FRAMES TO BE PAINTED.
ANY EXPOSED SECTIONS OF DOORS TO BE PAINT FINISHED.

ALL DOOR GRILLES WILL BE POWDER COAT FINISHED TO MATCH DOOR FINISH

FOR CONSTRUCTION

Revision/Issue		Date
P1	Preliminary Door Issue for Review	2025.07.24
P2	Tender Pack - Doors and Windows	2025.09.15
P3	ISSUE FOR CONTRACT	2025.10.10
C1	ISSUE FOR CONSTRUCTION - DOOR SCHEDULE	2026.03.16

ClarkeHopkinsClarke

Melbourne | Wurundjeri
L9, Melbourne Connect
700 Swanston Street
Carlton VIC 3053
Telephone (03) 9419 4340
Email studio@chc.com.au
www.chc.com.au

Sydney | Gadigal Country
Suite 3, Ground Floor
91 Campbell Street
Surry Hills NSW 2010
Telephone (02) 9221 9200
Email studio@chc.com.au
www.chc.com.au

Scale	1 : 200 @ A1
Date	01/03/2024
Drawn	TM
Architect	EL

Project
Summerset Oakleigh
52 Golf Road, Oakleigh South, VIC

Drawing
Schedule - Doors - Sheet 3

Drawing No.
230185/A1912 C1

A1 Use figured dimensions in preference to scale. Verify dimensions at job before shop fabrication. Read drawing in conjunction with specification.

© ClarkeHopkinsClarke