
How much of a battery counts at the North Island winter peak?

An independent check of SOSA 2026's 60% battery factor, from public EMI data

Feng Jiang · October 2026 · github.com/Kenchch/nz-bess-peak-credit

The question. SOSA 2026 counts every grid battery of two hours or less at 60% of its nameplate in the North Island Winter Capacity Margin, however many are built. A two-hour battery can only flatten the part of the peak that is less than two hours wide. Once the sharpest peaks are flattened, what is left is wider, so each additional MW lowers the peak by less. At what fleet size does 60% become more than a battery could physically deliver?

The answer. On the 2021–2025 average, the ceiling for a two-hour fleet falls to 60% at **about 500 MW on gross demand and 430 MW on net demand**. The North Island will have about 335 MW of grid batteries once Huntly's is commissioned. That puts the crossing above today's fleet but inside the pipeline SOSA 2026 already treats as committed. Single winters differ widely: in a winter like 2021, the ceiling is already below 60% at 234 MW.




How it was measured. For each of six winters (2021–2026), North Island half-hourly demand was rebuilt from public Electricity Authority data: grid injection plus HVDC transfer north, with wind and solar removed for the net basis. A linear programme then gives a battery fleet of P MW and d hours perfect foresight. The fleet charges and discharges on every half-hour from 1 April to minimise H100, the mean of the 200 tightest half-hours between 07:00 and 22:00. That is the demand measure the capacity margin is set against. Credit is the fall in H100 per MW, so the result is a **ceiling**: real batteries hold reserves, do not know the load in advance and are not always full, so they can only deliver less.

Why the credit falls. Even a 35 MW battery reaches only 82%, not 100%. The top 200 half-hours fall on 35–46 days, often four or five on the same day, so the coldest days need more than two hours of cover. Every extra MW must cover a wider slice of the peak. By 1,000 MW the ceiling is 43%.

Three readings of the same result.

- *Ceiling against 60%* (the headline). Above p*, 60% is too high whatever the batteries' behaviour.
- *Same behaviour, bigger fleet.* If 60% is right for a 35 MW battery like Rotohiko, holding that behaviour fixed and scaling it by the fall in the ceiling gives about **49% at 335 MW** and **31–34% at 1,000 MW**. This is the most robust reading: the ratio barely moves when the energy convention or the basis changes.
- *SOSA's own scoring.* SOSA scores wind and solar by mean output over the original top 200. Scored that way, the same dispatch rates 3–6 points higher, and p* moves out to about 600 MW. The gap is the shoulder hours that rise into the top 200 once the peak is flattened. H100 counts them; per-period scoring does not.



What it could mean for SOSA 2027 and the SSAD review.

- Make the battery factor depend on fleet size and duration, as the effective load-carrying capability methods used by PJM and in California do. A lookup table from this method (fleet × duration ⟶ factor) can be rebuilt each year in minutes.
- Report the factor per winter, not only as an average. The coldest winter binds first.
- Check how SOSA's state-of-charge model debits energy across consecutive peak half-hours. On H100, a one-hour battery's ceiling is 46–49% even at 35 MW, below the 60% applied to all batteries of two hours or less.

What this is not.

- It is not a forecast of battery behaviour.
- Generation_MD shows energy only. In winter 2026 the two batteries it can see, Ruakākā and Rotohiko, delivered 19% of their nameplate as energy across the top 200 half-hours, against a 76% ceiling for a fleet of their size. Much of their peak value is reserve, which this data cannot see, and Glenbrook and Huntly have no rows at all.
- Demand is grid-view, so embedded generation and rooftop solar are already netted off.
- H100 over 200 half-hours is the SSAD's measure. Scoring only the 50 tightest half-hours pushes p* out to 700–800 MW, so the choice of tail matters.
- History is not the future: demand growth and time-of-use pricing will reshape the peaks.

Reproducibility. Every number above can be traced to a run. The 200 input files are pinned by SHA-256, and six quality gates stop a run rather than publish a doubtful result: calibration against SOSA's published wind and solar factors, and replay checks on all 1,218 LPs among them. A trace script rebuilds every output from the raw files and confirms they match exactly. Code, results and limitations are at github.com/Kenchch/nz-bess-peak-credit.