

KEA Consult - Atvise, SQL & TIA Guide

Part 1: Atvise SCADA Setup

1. Installation: Install Atvise on a Windows or Linux host. For industrial reliability, Linux is often preferred.
2. Web Technology: Atvise HMIs are pure HTML5/SVG. This allows any browser-enabled device to act as an operator panel.
3. Building HMIs: Use the Atvise Builder to drag-and-drop SVG objects. Ensure consistency with KEA Consult's high-contrast standard.
4. Communication: Set up OPC-UA servers in Atvise to bridge with TIA Portal PLCs.

Part 2: SQL Integration

1. Historian Configuration: In Atvise, configure the Historian to log process tags to an SQL database.
2. Database Schema: Create tables for 'Live Data', 'Alarm History', and 'Batch Reports'.
3. TIA to SQL: Use Siemens LSQL library for direct PLC-to-SQL communication for critical logging tasks that must bypass the SCADA level.

Part 3: TIA Portal Standard

1. Software Version: Standardized on TIA Portal V19.
2. Project Structure: Maintain a clean 'Plant Hierarchy'. Use standard equipment blocks (FB/FC) from the KEA Library.
3. Hardware: Optimized for Siemens S7-1500 and ET200SP IO systems.
4. Backup: Always zip projects (e.g., MBS_Rosersberg.zip) before major changes or handover.