

检验/检测报告

TEST REPORT

受理编号: M250616-30

Acceptance: M250616-30

样品名称: KDF55

Name of KDF55

委托单位: 淄博宗立水处理技术有限公司

ZIBO ONLYZONE WATER TREATMENT

Applicant: TECHNOLOGY CO.,LTD

检测类别: 一般委托

Test categories: General commissioned

浙江弗里斯检测技术有限公司

Zhejiang Fries Testing Technology Co., Ltd.

检验/检测报告

浙微测
FSDA Testing



报告编号 (Report Num): FM250616-30

Page 1 of 2

样品名称 (Name of Sample)	KDF55	KDF55	样品编号 (Sample No.)	M250616-30
检验项目 (Item Tested)	铅去除率	Lead removal rate	样品数量 (Sample Quantity)	1 袋
样品颜色/性状 (Sample color/character)	粉末	powder	接样日期 (Sample Received Date)	2025.6.16
样品规格/型号 (Spec of Sample)	/	/	完成日期 (Completion Date)	2025.6.23
检测类别 (Test Type)	一般委托	general commissioned	采样单位 (Sampling unit)	/
生产单位 (Production unit)	淄博宗立水处理技术有限公司			
委托单位 (Applicant)	ZIBO ONLYZONE WATER TREATMENT TECHNOLOGY CO.,LTD			
委托单位地址 (Address)	山东省淄博市桓台县三赢路以南耀昌路以西创智未来产业小镇一期 25 # Building 25-1, Zhongnan High-tech, 333 Sanying Road, Huantai County, Zibo City, Shandong Province, China			

检测结论 (Detection conclusion):

100g材料+100g铅溶液浸泡 24 小时后, 检测溶液中铅浓度, 并算出去除率。

After soaking 100g of material and 100g of lead solution for 24 hours, measure the lead concentration in the solution and calculate the removal rate.

以下空白 Blank below

编制  审核  批准 
(Compile by): jiarai zhu (Checked by): Yang Zhang (Approve by): Junjing Yu

(盖章)
检验检测专用章
Special seal for inspection and detection

2025 YDB M27D
FSDA4-QA-075III10/02

检验/检测报告

报告编号 (Report Numb): FM250616-30

Page 2 of 2

样品名称 (Name of Sample)	KDF55	接样日期 (Sample Received Date)	2025.6.16
检验项目 (Item Tested)	铅去除率 Lead removal rate	完成日期 (Completion Date)	2025.6.23


表 1: 检验结果 (Table 1: Test results)

序号 (NO.)	测定项目 (Item)	单位 (Unit)	检验结果 (After filtration)		
			对照 (Before filtration)	样品 (Sample)	去除率 (Removal rate)
1	铅 lead	µg/L	64.7	4.8	92.6%

以下空白 Blank below

编制 
(Compile by): Jia Wei Chen

审核 
(Checked by): Song Zhen

批准 
(Approve by): Jun Jing Yu



报告说明 Report Explain

1、对检验/检测报告若有异议，应于收到报告之日起十五日内向本公司提出。

If there is any objection to the inspection / test report, it shall be submitted to the company within 15 days after receiving the report.

2、本公司保证检测的公正性，对检测数据负责，并对委托方提供的样品和技术资料保密。

The company shall guarantee the fairness of the test, be responsible for the test data, and keep confidential for the samples and technical data provided by the client.

3、委托方对所提供的技术资料 and 样品的真实性负责。

The client shall be responsible for the authenticity of the provided technical files and samples.

4、不得部分复制本检测报告。

Do not copy the test report partially.

5、本检验/检测报告无“检验检测专用章”或本公司公章无效；本检测报告无授权签字人签字无效；涂改无效。

This inspection / test report is invalid without the "Special Inspection Seal" or The Company's Official Seal; This test report is invalid without the signature of the authorized signatory; Invalidation with alteration.

6、一般情况，委托检测仅对来样负责。

The entrusted test is only responsible for the samples under normal circumstances.

7、报告中未加 CMA 标志时，检测数据和结果仅供科研，教学或内部质量控制之用。

When the CMA mark is not added in the report, the test data and results are only for scientific research, teaching, or internal quality control purposes.

地址：浙江省慈溪市白沙路街道三北大街 2588 号

Address: No. 2588, Sanbei Street, Baisha Road Street, Cixi City, Zhejiang Province

邮政编码 (Postal code) : 315300

电话 (Telephone) : 0574-63038712/63120007

传真 (Fax) : 0574-63038713

邮箱 (E-mail) : company@china-fsda.com

网址 (Web site) : www.china-fsda.com

