

Revision Schedule			
Rev	Date	Description	Drn By
C1	27.11.25	Construction Issue	-

Window Schedule - Country Brick															
Location	Ref	Structural Opening		uPVC Cill Size		Sashes - 2021	Glazing Colour	Toughened Glass?	Escape Hinges?	Safety Rail Reqd?	Security?	M4(2) Reqd?	2013 Regs Trickle Ventilation Area	2021 Regs Trickle Ventilation Area	Remarks
		Width	Height												
Living Room	W1	1810 mm	1425 mm	85		Left Pane - Left Hung Centre Pane - Right Hung Right Pane - Right Hung	Clear	Toughened Glass			ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Cloakroom	W2	685 mm	1050 mm	85		Centre Pane - Right Hung	Obscure				ADQ	Handles to satisfy requirements of Approved Document M4(2)	4000 mm²	0 mm²	
Kitchen/Dining	W3	2372.5 mm	2100 mm	180		Left Pane - Top Hung Centre Pane - Pair of French Doors Right Pane - Top Hung Btm Left Pane - Fixed Btm Right Pane - Fixed	Clear	Doors, and any glass adjacent to doors within 1500mm of FFL to be Toughened Glass			ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	Mid transom rail set 800mm from top of window. uPVC Double French Door Set with Sidelights, and accessible threshold
Kitchen/Dining	W4	1247.5 mm	1050 mm	180		Left Pane - Top Hung Right Pane - Top Hung	Clear				ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Bedroom 2	W5	1247.5 mm	1200 mm	85		Left Pane - Left Hung Right Pane - Right Hung	Clear		Yes	2021 Regs Only		Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Bedroom 3	W6	1247.5 mm	1200 mm	85		Left Pane - Left Hung Right Pane - Right Hung	Clear		Yes	2021 Regs Only		Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Bedroom 1	W7	1810 mm	1200 mm	180		Left Pane - Left Hung Centre Pane - Right Hung Right Pane - Right Hung	Clear		Yes	2021 Regs Only		Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Bedroom 1 Ensuite	W8	1247.5 mm	1200 mm	180		Left Pane - Fixed Pane with Dummy Sash Right Pane - Right Hung	Obscure					Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	0 mm²	
Bathroom	W9	685 mm	1125 mm	180		Centre Pane - Left Hung	Obscure					Handles to satisfy requirements of Approved Document M4(2)	4000 mm²	0 mm²	
Stairs	W10	685 mm	1125 mm	180		Centre Pane - Fixed	Obscure	Toughened Glass				FIXED WINDOW	4000 mm²	0 mm²	Plot 1 <u>ONLY</u>
Total Background Ventilation													68000 mm²	24000 mm²	

95.34m² floor area (4 people) requires 45,000mm² minimum total background ventilation area (System 1 Ventilation)

Part O requirements:-
Safety Rail to be installed at 1100mm, which may be omitted if Build Tolerance to window opening is within a range of maximum 1100mm and minimum 1000mm



Artistic impression of Window Safety Rail (2021 Regs only)

CONSTRUCTION

Bellway

www.bellway.co.uk

Bellway Homes (Eastern Counties)

Building 2030, Cambourne Business Park,
Cambridgeshire CB23 6DW
Tel: 01480 425 200

Project

Somersham

St Ives Road

Working Drawings

Drawing Title

The Coppersmith-Life

CSL-3B-2S-CB

1026 ft² | 3b Det / Semi | Country Brick

Window Schedule

Drawing Created By	First Issue Date	Scale(s)
Group	April '25	
Project No	Drg Status	Revision
BI01	Construction	C1
Drawing No.	BI01/1026CSL/90/CB/02	

Plots 08, 14, 50 (AS) & 01, 03, 09, 18, 19, 49 OPP

Do not scale - if in doubt, ask