

86.79m² floor area requires 45,000mm² minimum total background ventilation area (System 1 Ventilation)

Revision Schedule			
Rev	Date	Description	Drn By
C1	28.11.25	Construction Issue	-

Window Schedule - Country Brick															
Location	Ref	Structural Opening		uPVC Cill Size	Sashes - 2013	Sashes - 2021	Glazing Colour	Toughened Glass?	Escape Hinges?	Safety Rail Req'd?	Security?	M4(2) Req'd?	2013 Regs Trickle Ventilation Area	2021 Regs Trickle Ventilation Area	Remarks
		Width	Height												
Living Room	W1	1810 mm	1425 mm	85	Left Pane - Left Hung Centre Pane - Fixed Pane Right Pane - Right Hung	Left Pane - Left Hung Centre Pane - Right Hung Right Pane - Right Hung	Clear	Toughened Glass			ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Kitchen / Dining	W2	900 mm	1050 mm	180	Left Pane - Top Hung Right Pane - Fixed Pane	Left Pane - Top Hung Right Pane - Top Hung	Clear				ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Kitchen / Dining	W3	1247.5 mm	1050 mm	180	Left Pane - Top Hung Right Pane - Fixed Pane	Left Pane - Top Hung Right Pane - Top Hung	Clear				ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Bedroom 2	W4	1360 mm	1200 mm	85	Left Pane - Left Hung Right Pane - Fixed Pane	Left Pane - Left Hung Right Pane - Right Hung	Clear		Yes	2021 Regs Only		Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Bedroom 3	W5	1247.5 mm	1200 mm	85	Left Pane - Fixed Pane Right Pane - Right Hung	Left Pane - Left Hung Right Pane - Right Hung	Clear		Yes	2021 Regs Only		Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Bathroom	W6	910 mm	1125 mm	180	Left Pane - Fixed Pane Right Pane - Top Hung	Left Pane - Top Hung Right Pane - Top Hung	Obscure					Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	0 mm²	
Bedroom 1	W7	1247.5 mm	1200 mm	180	Left Pane - Fixed Pane Right Pane - Right Hung	Left Pane - Left Hung Right Pane - Right Hung	Clear		Yes	2021 Regs Only		Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Living Room	W8	1247.5 mm	1050 mm	180	Left Pane - Top Hung Right Pane - Fixed Pane	Left Pane - Top Hung Right Pane - Top Hung	Clear				ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
WC	W9	685 mm	1050 mm	180		Pane - Top Hung	Obscure				ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	0 mm²	Plot 36 <u>ONLY</u>
Landing	W10	685 mm	1050 mm	180		Pane - Fixed	Clear						8000 mm²	4000 mm²	Plot 36 <u>ONLY</u>
Total Background Ventilation													80000 mm²	32000 mm²	

Artistic impression of Window Safety Rail (2021 Regs only)



Part O requirements:-
Safety Rail to be installed at 1100mm, which may be omitted if Build Tolerance to window opening is within a range of maximum 1100mm and minimum 1000mm

Plots 32, 34, 36, 46 (AS) & 33, 35, 47 (OPP)

CONSTRUCTION

Bellway

www.bellway.co.uk

Bellway Homes (Eastern Counties)

Building 2030, Cambourne Business Park,
Cambridgeshire CB23 6DW
Tel: 01480 425 200

Project

Somersham

St Ives Road

Working Drawings

Drawing Title

The Draftsman-Life

DML-3B-2S-CB

934 ft² | 3b Semi/Mid | Country Brick

Window Schedule

Drawing Created By	First Issue Date	Scale(s)
Group	April '25	
Project No	Drg Status	Revision
BI01	Construction	C1
Drawing No.	BI01/934DML/90/CB/02	

Do not scale - if in doubt, ask