

Electrical Switches / Sockets Schedule				
Qty	Description	Manufacturer	Range	Model Number(s)
Bedroom 1				
1	1 Gang 1 Way 10AX Switch SP	BWY		
3	2 Gang 13A Switched Socket	BWY		
1	Co-Axial TV Outlet	BWY		
Bedroom 2				
1	1 Gang 1 Way 10AX Switch SP	BWY		
3	2 Gang 13A Switched Socket	BWY		
Bedroom 3				
1	1 Gang 1 Way 10AX Switch SP	BWY		
2	2 Gang 13A Switched Socket	BWY		
Hall				
2	1 Gang 2 Way 10AX Switch SP	BWY		
1	1 Gang 10AX Intermediate Switch	BWY		
1	2 Gang 2 Way 10AX Switch SP	BWY		
1	2 Gang 13A Switched Socket	BWY		
2	6A 3 Pole Fan Isolator	BWY		
1	240v Optical Smoke Alarm c/w Battery Back Up	Deta	-	1164
1	2013 - 1 Gang 2 Way 10AX Switch SP 2021 - 2 Gang 2 Way 10AX Switch SP	BWY		
Kitchen / Dining				
3	1 Gang 13A Unswitched Socket	BWY		
4	2 Gang 13A Switched Socket	BWY		
1	3A double-pole switched fused spur connection	BWY		
1	10 Year Battery Powered CO Alarm	Deta	-	1139
3	13A double-pole switched fused spur connection	BWY		
1	240v Heat Alarm c/w Battery Back Up	Deta	-	1166
1	2013 - 2 Gang 2 Way 10AX Switch SP 2021 - 3 Gang 2 Way 10AX Switch SP	BWY		
Landing				
1	1 Gang 2 Way 10AX Switch SP	BWY		
1	2 Gang 13A Switched Socket	BWY		
1	6A 3 Pole Fan Isolator	BWY		
1	20A Double Pole Switch & Neon (to be used as lightswitch for Roof Space light)	BWY		
1	240v Optical Smoke Alarm c/w Battery Back Up	Deta	-	1164
1	2013 - 1 Gang 2 Way 10AX Switch SP 2021 - 2 Gang 2 Way 10AX Switch SP	BWY		
Living Room				
1	1 Gang 1 Way 10AX Switch SP	BWY		
4	2 Gang 13A Switched Socket	BWY		
1	2 Module Moulded Plate	BWY		
1	240v Optical Smoke Alarm c/w Battery Back Up	Deta	-	1164
1	Co-Axial TV Module	BWY		
1	RJ45 Cat6 Module	BWY		
Roof Space				
1	240v Combined Optical Smoke and Heat Alarm c/w Battery Back Up	Deta	-	1171
1	DC Solar Isolation Switch	BWY		
Store				
1	2 Gang 13A Switched Socket	BWY		
1	2 Module Moulded Plate	BWY		
1	AC Solar Isolation Switch	BWY		
1	BT Master Outlet	BWY		
1	Co-Axial TV Module	BWY		
1	Distribution Board	Wylex	T.B.C.	
1	Openreach Optical Network Terminal (ONT)			
1	RJ45 Cat6 Module	BWY		

Lighting Schedule					
Room	Qty	Description	Manufacturer	Range	Model Number(s)
	1	Exterior Up/Down Wall Light with PIR	BWY	Exterior Lighting	
Bathroom	1	Straight Batten Lampholder	BWY		
Bedroom 1	1	6" Pendant Set C/W Lampholder	BWY		
Bedroom 2	1	6" Pendant Set C/W Lampholder	BWY		
Bedroom 3	1	6" Pendant Set C/W Lampholder	BWY		
Cloakroom	1	Straight Batten Lampholder	BWY		
Hall	2	6" Pendant Set C/W Lampholder	BWY		
Kitchen / Dining	1	6" Pendant Set C/W Lampholder	BWY		
Kitchen / Dining	1	Straight Batten Lampholder	BWY		
Landing	1	6" Pendant Set C/W Lampholder	BWY		
Living Room	1	6" Pendant Set C/W Lampholder	BWY		
Roof Space	1	Straight Batten Lampholder	BWY		

Extract Schedule (2013 - System 1)			
Room	Product	Description	Terminal
Bathroom	BWY - Medium Power (Wall-Mounted)	Intermittent axial fan with a flow rate of up to 117m³/hr (32l/s). IPX4 rated.	Standard Wall Terminal
Cloakroom	BWY - Lower Power (Ceiling-Mounted)	Intermittent axial fan with a flow rate of up to 69m³/hr (19 l/s). IPX4 rated.	Standard Wall Terminal
Kitchen / Dining	BWY - High Power (Ceiling-Mounted)	Intermittent axial fan with a flow rate of up to 270m³/hr (75 l/s). IPX4 rated.	Standard Wall Terminal

Extract Schedule (2021 - System 3 dMEV)				
Room	Product	Description	Terminal	L/S Extract Rate
Bathroom	BWY - Continuous Running (dMEV) (Wall Mounted)	24v, quiet continuous running axial fan with a flow rate of circa 47m³/hr (13l/s), and with a Boost mode of circa 72m³/hr (20l/s). IPX5 rated.	Standard Wall Terminal	13
Cloakroom	BWY - Continuous Running (dMEV) (Ceiling-Mounted)	24v, quiet continuous running axial fan with a flow rate of circa 22m³/hr (6 l/s), and with a Boost mode of circa 29m³/hr (8l/s). IPX5 rated.	Standard Wall Terminal	6
Kitchen / Dining	BWY - Continuous Running (dMEV) (Ceiling-Mounted)	24v, quiet continuous running axial fan with a flow rate of circa 47m³/hr (13l/s), and with a Boost mode of circa 72m³/hr (20l/s). IPX5 rated.	Standard Wall Terminal	13

Revision Schedule			
Rev	Date	Description	Drn By
C1	28.11.25	Construction Issue	

2021 Regulations - System 3 dMEV (Decentralised Mechanical Extract Ventilation)

The minimum whole dwelling ventilation rate for the supply of air to the habitable rooms in a dwelling should meet both of the following conditions.

a. A minimum rate of 0.3 litres per second per m² of internal floor area (this includes all floors, e.g. for a two-storey building, add the ground-floor and first-floor areas).

b. A minimum rate determined by the number of bedrooms, as specified in Approved Document F Table 1.3 (given below).

Number of bedrooms	Minimum ventilation rate by number of bedrooms (l/s)
1	19
2	25
3	31
4	37
5	43

Wetroom Switches for dMEV Applications

Outside of Bathrooms, Ensuites, WCs and Utility Rooms, any double switches (for lights and intermittent fans) should be substituted with single switches (for lights only) when dMEV fans are fitted.

Note - Isolator switches should still be installed above doors in all cases.

CONSTRUCTION


www.bellway.co.uk

Bellway Homes (Eastern Counties)

Building 2030, Cambourne Business Park,
Cambridgeshire CB23 6DW
Tel: 01480 425 200

Project

Somersham

St Ives Road

Working Drawings

Drawing Title		
The Draftsman-Life		DML-3B-2S-0
934 ft² 3b Semi/Mid All Variants		
Electrical Take Off		
Drawing Created By	First Issue Date	Scale(s)
Group		
Project No	Drg Status	Revision
	Construction	C1
Drawing No.		BI01/934DML/95/0/03