

97.87m² floor area requires 77,500mm² minimum total background ventilation area (System 1 Ventilation)

Revision Schedule			
Rev	Date	Description	Drn By
C1	28.11.25	Construction Issue	-

Window Schedule - Country Brick															
Location	Ref	Structural Opening		uPVC Cill Size	Sashes - 2013	Sashes - 2021	Glazing Colour	Toughened Glass?	Escape Hinges?	Safety Rail Req'd?	Security?	M4(2) Req'd?	2013 Regs Trickle Ventilation Area	2021 Regs Trickle Ventilation Area	Remarks
		Width	Height												
Kitchen / Dining	W1	1247.5 mm	1350 mm	85	Left Pane - Left Hung Right Pane - Fixed Pane	Left Pane - Left Hung Right Pane - Right Hung	Clear	Toughened Glass			ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	0 mm²	
Hall	W2	450 mm	1125 mm	85	Centre Pane - Top Hung	Centre Pane - Top Hung	Clear	Toughened Glass			ADQ		2500 mm²	2500 mm²	Window cill lowered
Hall	W3	450 mm	1125mm	85	Centre Pane - Top Hung	Centre Pane - Top Hung	Clear	Toughened Glass			ADQ		2500 mm²	2500 mm²	Window cill lowered
Living Room	W4	1810 mm	1350 mm	85	Left Pane - Left Hung Centre Pane - Fixed Pane Right Pane - Right Hung	Left Pane - Left Hung Centre Pane - Right Hung Right Pane - Right Hung	Clear	Toughened Glass			ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Living Room	W5	2372.5 mm	2100 mm	180	Left Pane - Top Hung Centre Pane - Pair of French Doors Right Pane - Top Hung Btm Left Pane - Fixed Btm Right Pane - Fixed	Left Pane - Top Hung Centre Pane - Pair of French Doors Right Pane - Top Hung Btm Left Pane - Fixed Btm Right Pane - Fixed	Clear	Doors, and any glass adjacent to doors within 1500mm of FFL to be Toughened Glass			ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	Mid transom rail set 800mm from top of window. uPVC Double French Door Set with Sidelights, and accessible threshold
Utility	W6	488 mm	1050 mm	180	Centre Pane - Top Hung	Centre Pane - Top Hung	Clear				ADQ	Handles to satisfy requirements of Approved Document M4(2)	4000 mm²	4000 mm²	
Kitchen / Dining	W7	2372.5 mm	2100 mm	180	Left Pane - Top Hung Centre Pane - Pair of French Doors Right Pane - Top Hung Btm Left Pane - Fixed Btm Right Pane - Fixed	Left Pane - Top Hung Centre Pane - Pair of French Doors Right Pane - Top Hung Btm Left Pane - Fixed Btm Right Pane - Fixed	Clear	Doors, and any glass adjacent to doors within 1500mm of FFL to be Toughened Glass			ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	Mid transom rail set 800mm from top of window. uPVC Double French Door Set with Sidelights, and accessible threshold
Kitchen / Dining	W8	685 mm	1050 mm	85	Centre Pane - Top Hung	Centre Pane - Top Hung	Clear				ADQ	Handles to satisfy requirements of Approved Document M4(2)	4000 mm²	0 mm²	
Kitchen / Dining	W9	1810 mm	1050 mm	85	Left Pane - Top Hung Centre Pane - Fixed Pane Right Pane - Top Hung	Left Pane - Top Hung Centre Pane - Top Hung Right Pane - Top Hung	Clear				ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	0 mm²	
Bedroom 1	W10	910 mm	1125 mm	85	Left Pane - Left Hung Right Pane - Right Hung	Left Pane - Left Hung Right Pane - Right Hung	Clear					Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Bedroom 1 Ensuite	W11	910 mm	1125 mm	85	Left Pane - Left Hung Right Pane - Right Hung	Left Pane - Left Hung Right Pane - Right Hung	Obscure					Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	0 mm²	
Bedroom 3	W12	1810 mm	1200 mm	85	Left Pane - Left Hung Centre Pane - Fixed Pane Right Pane - Right Hung	Left Pane - Left Hung Centre Pane - Right Hung Right Pane - Right Hung	Clear		Yes	2021 Regs Only		Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Bathroom	W13	685 mm	1050 mm	180	Centre Pane - Top Hung	Centre Pane - Top Hung	Obscure					Handles to satisfy requirements of Approved Document M4(2)	4000 mm²	0 mm²	
Landing	W14	685 mm	1050 mm	180	Centre Pane - Top Hung	Centre Pane - Top Hung	Clear					Handles to satisfy requirements of Approved Document M4(2)	4000 mm²	4000 mm²	
Bedroom 2	W15	1247.5 mm	1200 mm	180	Left Pane - Fixed Pane Right Pane - Right Hung	Left Pane - Left Hung Right Pane - Right Hung	Clear		Yes	2021 Regs Only		Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Bedroom 2	W16	685 mm	1050 mm	85	Centre Pane - Top Hung	Centre Pane - Top Hung	Clear					Handles to satisfy requirements of Approved Document M4(2)	4000 mm²	4000 mm²	
Bedroom 1	W17	1810 mm	1200 mm	85	Left Pane - Left Hung Centre Pane - Fixed Pane Right Pane - Right Hung	Left Pane - Left Hung Centre Pane - Right Hung Right Pane - Right Hung	Clear		Yes	2021 Regs Only		Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	

Total Background Ventilation

105000 mm²

45000 mm²

Part O requirements:-
Safety Rail to be installed at 1100mm, which may be omitted if Build Tolerance to window opening is within a range of maximum 1100mm and minimum 1000mm



Plots 20, 23 (OPP)

CONSTRUCTION

Bellway

www.bellway.co.uk

Bellway Homes (Eastern Counties)

Building 2030, Cambourne Business Park,
Cambridgeshire CB23 6DW
Tel: 01480 425 200

Project

Somersham
St Ives Road
Working Drawings

Drawing Title		
The Fuller Life		FRL-3B-2S-CB
1053 ft² 3b Det (Corner Turner) Country Brick Window Schedule		
Drawing Created By	First Issue Date	Scale(s)
Group	April '25	
Project No	Drg Status	Revision
BI01	Construction	C1
Drawing No.		BI01/1053FRL/90/CB/02

Do not scale - if in doubt, ask