

73.42m² floor area requires 35,000mm² minimum total background ventilation area (System 1 Ventilation)

Revision Schedule			
Rev	Date	Description	Drn By
C1	01.12.25	Construction Issue	FDL

Window Schedule - Country Brick

Location	Ref	Structural Opening		uPVC Cill Size	Sashes - 2013	Sashes - 2021	Glazing Colour	Toughened Glass?	Escape Hinges?	Safety Rail Req'd?	Security?	M4(2) Req'd?	2013 Regs Trickle Ventilation Area	2021 Regs Trickle Ventilation Area	Remarks
		Width	Height												
Hall	W1	460 mm	1050 mm	85	Centre Pane - Top Hung	Centre Pane - Top Hung	Clear				ADQ	Handles to satisfy requirements of Approved Document M4(2)	2500 mm²	2500 mm²	
Kitchen	W2	910 mm	1050 mm	85	Left Pane - Top Hung Right Pane - Fixed Pane	Left Pane - Top Hung Right Pane - Fixed Pane with Dummy Sash	Clear				ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	0 mm²	
Living / Dining	W3	2372.5 mm	2100 mm	180	Left Pane - Top Hung Centre Pane - Pair of French Doors Right Pane - Top Hung Btm Left Pane - Fixed Btm Right Pane - Fixed	Left Pane - Top Hung Centre Pane - Pair of French Doors Right Pane - Top Hung Btm Left Pane - Fixed Btm Right Pane - Fixed	Clear	Doors, and any glass adjacent to doors within 1500mm of FFL to be Toughened Glass			ADQ	Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	Mid transom rail set 550mm from centreline of transom to top of window (uPVC Double French Door Set with Sidelights, and accessible threshold
Bedroom 2	W4	1360 mm	1200 mm	85	Left Pane - Left Hung Centre Pane - Right Hung Right Pane - Right Hung	Left Pane - Left Hung Centre Pane - Right Hung Right Pane - Right Hung	Clear		Yes	2021 Regs Only		Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	Complete with floating mullion to aid escape
Bedroom 1	W5	1810 mm	1200 mm	180	Left Pane - Left Hung Centre Pane - Fixed Pane Right Pane - Right Hung	Left Pane - Left Hung Centre Pane - Right Hung Right Pane - Right Hung	Clear		Yes	2021 Regs Only		Handles to satisfy requirements of Approved Document M4(2)	8000 mm²	4000 mm²	
Landing	W6	685 mm	1050 mm	180	Centre Pane - *Fixed	Centre Pane - *Fixed	obscured					Handles to satisfy requirements of Approved Document M4(2)	4000 mm²	4000 mm²	Semi-Detached properties only
Total Background Ventilation													38500 mm²	18500 mm²	

Part O requirements:-
Safety Rail to be installed at 1100mm, which may be omitted if Build Tolerance to window opening is within a range of maximum 1100mm and minimum 1000mm

Artistic impression of Window Safety Rail (2021 Regs only)



Plots 10, 16, 41, 42 (AS) & 11, 17, 43 (OPP)

CONSTRUCTION

Bellway

www.bellway.co.uk

Bellway Homes (Eastern Counties)

Building 2030, Cambourne Business Park,
Cambridgeshire CB23 6DW
Tel: 01480 425 200

Building Regulations
2013 & 2021
Compliant

Project

Somersham
St Ives Road
Working Drawings

Drawing Title

The Hooper-Life

790 ft² | 2b Semi/Terr | Country Brick
Window Schedule

HPL-2B-2S-CB

Drawing Created By Group	First Issue Date April '25	Scale(s)
Project No BI01	Drg Status Construction	Revision C1
Drawing No. BI01/790HP/90/CB/02		

Do not scale - if in doubt, ask