

Electrical Switches / Sockets Schedule				
Qty	Description	Manufacturer	Range	Model Number(s)
Bedroom 1				
1	1 Gang 1 Way 10AX Switch SP	BWY		
3	2 Gang 13A Switched Socket	BWY		
1	Co-Axial TV Outlet	BWY		
Bedroom 2				
1	1 Gang 1 Way 10AX Switch SP	BWY		
3	2 Gang 13A Switched Socket	BWY		
Hall				
1	1 Gang 1 Way 10AX Switch SP	BWY		
1	1 Gang 2 Way 10AX Switch SP	BWY		
1	2 Gang 2 Way 10AX Switch SP	BWY		
1	2 Gang 13A Switched Socket	BWY		
1	6A 3 Pole Fan Isolator	BWY		
1	240v Optical Smoke Alarm c/w Battery Back Up	Deta	-	1164
1	2013 - 1 Gang 2 Way 10AX Switch SP 2021 - 2 Gang 2 Way 10AX Switch SP	BWY		
Kitchen				
3	1 Gang 13A Unswitched Socket	BWY		
2	2 Gang 13A Switched Socket	BWY		
1	3A double-pole switched fused spur connection	BWY		
1	6A 3 Pole Fan Isolator	BWY		
1	8 Gang Module Grid Plate complete with marked switches and blanking plates (as required)	BWY		
1	10 Year Battery Powered CO Alarm	Deta	-	1139
2	25A Flex Outlet Plate 3 Terminals	BWY		
1	45A Double Pole Switch	BWY		
1	240v Heat Alarm c/w Battery Back Up	Deta	-	1166
1	2013 - 1 Gang 2 Way 10AX Switch SP 2021 - 2 Gang 2 Way 10AX Switch SP	BWY		
1	Cooker Outlet Plate	BWY		
Landing				
1	2 Gang 13A Switched Socket	BWY		
1	6A 3 Pole Fan Isolator	BWY		
1	20A Double Pole Switch & Neon (to be used as lightswitch for Roof Space light)	BWY		
1	240v Optical Smoke Alarm c/w Battery Back Up	Deta	-	1164
1	2013 - 2 Gang 2 Way 10AX Switch SP 2021 - 3 Gang 2 Way 10AX Switch SP	BWY		
Living / Dining				
1	2 Gang 2 Way 10AX Switch SP	BWY		
6	2 Gang 13A Switched Socket	BWY		
1	2 Module Moulded Plate	BWY		
1	3 Gang 2 Way 10AX Switch SP	BWY		
1	240v Optical Smoke Alarm c/w Battery Back Up	Deta	-	1164
1	Co-Axial TV Module	BWY		
1	RJ45 Cat6 Module	BWY		
Roof Space				
1	240v Combined Optical Smoke and Heat Alarm c/w Battery Back Up	Deta	-	1171
1	DC Solar Isolation Switch	BWY		
Store				
1	1 Module Moulded Plate	BWY		
1	2 Gang 13A Switched Socket	BWY		
1	AC Solar Isolation Switch	BWY		
1	BT Master Outlet	BWY		
1	Co-Axial TV Module	BWY		
1	Distribution Board	Wylex	T.B.C.	
1	Openreach Optical Network Terminal (ONT)			

Lighting Schedule					
Room	Qty	Description	Manufacturer	Range	Model Number(s)
	2	Exterior Up/Down Wall Light with PIR	BWY	Exterior Lighting	
Bathroom	4	IP65 Fire Rated Dimmable Downlight - White (supplied with dimmable LED lamp (3000K)).	Green Lighting	Downlights	GL-ECO8WH
Bedroom 1	1	6" Pendant Set C/W Lampholder	BWY		
Bedroom 2	1	6" Pendant Set C/W Lampholder	BWY		
Cloakroom	1	Straight Batten Lampholder	BWY		
Hall	2	6" Pendant Set C/W Lampholder	BWY		
Kitchen	3	IP65 Fire Rated Dimmable Downlight - White (supplied with dimmable LED lamp (3000K)).	Green Lighting	Downlights	GL-ECO8WH
Landing	1	6" Pendant Set C/W Lampholder	BWY		
Living / Dining	2	6" Pendant Set C/W Lampholder	BWY		
Roof Space	1	Straight Batten Lampholder	BWY		

Revision Schedule			
Rev	Date	Description	Drn By
C1	01.12.25	Construction Issue	FDL

2021 Regulations - System 3 dMEV (Decentralised Mechanical Extract Ventilation)

The minimum whole dwelling ventilation rate for the supply of air to the habitable rooms in a dwelling should meet both of the following conditions.

a. A minimum rate of 0.3 litres per second per m² of internal floor area (this includes all floors, e.g. for a two-storey building, add the ground-floor and first-floor areas).

b. A minimum rate determined by the number of bedrooms, as specified in Approved Document F Table 1.3 (given below).

Number of bedrooms	Minimum ventilation rate by number of bedrooms (l/s)
1	19
2	25
3	31
4	37
5	43

Wetroom Switches for dMEV Applications

Outside of Bathrooms, Ensuites, WCs and Utility Rooms, any double switches (for lights and intermittent fans) should be substituted with single switches (for lights only) when dMEV fans are fitted.

Note - Isolator switches should still be installed above doors in all cases.

Extract Schedule (2021 - System 3 dMEV)				
Room	Product	Description	Terminal	L/S Extract Rate
Bathroom	BWY - Continuous Running (dMEV) (Ceiling-Mounted)	24v, quiet continuous running axial fan with a flow rate of circa 22m³/hr (6 l/s), and with a Boost mode of circa 29m³/hr (8l/s). IPX5 rated.	Standard Wall Terminal	6
Cloakroom	BWY - Continuous Running (dMEV) (Ceiling-Mounted)	24v, quiet continuous running axial fan with a flow rate of circa 22m³/hr (6 l/s), and with a Boost mode of circa 29m³/hr (8l/s). IPX5 rated.	Standard Wall Terminal	6
Kitchen	BWY - Continuous Running (dMEV) (Ceiling-Mounted)	24v, quiet continuous running axial fan with a flow rate of circa 47m³/hr (13l/s), and with a Boost mode of circa 72m³/hr (20l/s). IPX5 rated.	Standard Wall Terminal	13

Alternative extract to roof tile to bathroom when plotted as terraced

CONSTRUCTION

Bellway

www.bellway.co.uk

Bellway Homes (Eastern Counties)

Building 2030, Cambourne Business Park, Cambridgeshire CB23 6DW

Tel: 01480 425 200

Building Regulations

2013 & 2021

Compliant

Project

Somersham

St Ives Road

Working Drawings

Drawing Title

The Hooper-Life

790 ft² | 2b Semi/Terr | All Variants

Electrical Take Off

HPL-2B-2S-0

Drawing Created By Group	First Issue Date 10 Aug 2020	Scale(s)
Project No	Drg Status Construction	Revision C1
Drawing No. BIO1/790HP/95/0/03		

Plots 10, 16, 41, 42 (AS) & 11, 17, 43 (OPP)

Do not scale - if in doubt, ask