

Factory Acceptation Test
for
110FT Exploration Yacht
of
King Ship
at

Free Technics BV

Date: 12 oct 2006

Free Technics BV
Corellistraat 35d
2394 GX Hazerswoude
The Netherlands
Tel: +31 71 341 5189
Email: info@freetechnics.eu

King Ship Marine Ltd
Suite 3112, 31/F, Tower 6
The Gateway, Harbour City
Hong Kong
Tel: +86 760 570 1333
Email: george@kingshipyacht.com



Scope of supply (See GA drawing, page 1 of 7-8-2006)		Tested
Alarm PC Systems	Alarm Main Server	✓
	Alarm Backup Server	✓
	Fail Safe Test between servers	✓
	Communication between systems	✓
Alarm Panels	Engine Control Room(ECR)	✓
	Engine Room	✓
	Wheelhouse	✓
	Captain's Cabin	✓
	Crew Mess	✓
	Engineer's Cabin	✓
Network	Network Switches	✓
	Serial Servers	✓
	I/O Stations	✓
Random Selected Failures	Network Cables	✓
	Serial Cables	✓
	I/O Points	✓

Remarks	
Part	Comment
Serial Servers	VLinux Serial server locked after network cable was disconnected. Needed hardware reset (happened once)
Network	Alarm message when PC Lazarette was switched off was not shown (Logbook displays the message)
Network	Add back-bone alarm (next to network cables)

Witnessed by		
Name: JOHAN BLOM FREE TECHNICS Signature: <i>Johan Blom</i>	Name: <div style="border: 1px solid black; padding: 2px; display: inline-block;"> Lloyd's Register EMEA H.L. Reekers Rotterdam Office </div> Signature: <i>[Signature]</i>	Name: Signature:

LR MUR ROT 0604604
12-10-06.

