



## **SUBMITTAL**

### **Project**

Kerr Stock Equipment

### **Date**

Tuesday, July 18, 1905

### **Designer**

applied@kerrcontrols.ca

### **Notes**

KERR STOCK EQUIPMENT

Kerr Applied

## Table Of Contents

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

|                           |          |
|---------------------------|----------|
| <b>48FCEM09A3A5-8B0AN</b> | <b>3</b> |
| Unit Report               | 4        |
| Certified Drawing         | 5        |
| Performance Summary       | 6        |
| Guide Specifications      | 9        |
| Unit Feature Sheet        | 26       |
| Spec Sheet                | 27       |

**48FCEM09A3A5-8B0AN**

**Tag Cover Sheet  
Unit Report  
Certified Drawing  
Performance Report  
Guide Specification  
Unit Feature Sheet  
Spec Sheet**

## Unit Report For 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

### Unit Parameters

Unit Model:.....**48FCEM09A3A5-8B0AN**  
Unit Size:.....**09 (8.5 Tons)**  
Volts-Phase-Hertz:.....**230-3-60**  
Heating Type:.....**Gas**  
Refrigerant:.....**R-410A**  
Heat Option:.....**Medium Heat**  
Duct Cfg:.....**Vertical Supply / Vertical Return**  
DX Options:.....**Single Circuit, Two Stage Cooling**

### Dimensions (ft. in.) & Weight (lb.) \*\*\*

Unit Length:.....**7' 4.125"**  
Unit Width:.....**4' 11.5"**  
Unit Height:.....**4' 1.375"**  
**Total Operating Weight:.....968 lb**

\*\*\* Weights and Dimensions are approximate. Weight does not include unit packaging. Approximate dimensions are provided primarily for shipping purposes. For exact dimensions and weights, refer to appropriate product data catalog.

### Lines and Filters

Gas Line Size:.....**3/4**  
Condensate Drain Line Size:.....**3/4**  
Return Air Filter Type:.....**Throwaway**  
Return Air Filter Quantity:.....**4**  
Return Air Filter Size:.....**20 x 20 x 2**

Selection includes construction throwaway filter into the base fan curve.

### Unit Configuration

High Static (EcoBlue)  
Al/Cu - Al/Cu  
Electromechanical - can be used with POL224 EconomizerONE (includes FDD)  
Temperature Economizer w/ Barometric Relief  
Canada Export Unit

### Warranty Information

1-Year parts(std.)  
5-Year compressor parts(std.)  
10-Year heat exchanger - Aluminized(std.)

No optional warranties were selected.

**NOTE: Please see Warranty Catalog 500-089 for explanation of policies and ordering methods.**

### Ordering Information

| Part Number        | Description                                        | Quantity |
|--------------------|----------------------------------------------------|----------|
| 48FCEM09A3A5-8B0AN | Rooftop Unit                                       | 1        |
|                    | Base Unit                                          |          |
|                    | High Static (EcoBlue)                              |          |
|                    | Low Leak Temp EconomizerONE with barometric relief |          |

# Certified Drawing for 48FCM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied


10/06/2026  
04:14PM

## NOTES:


1. DIMENSIONS ARE IN INCHES. DIMENSIONS IN [ ] ARE IN MILLIMETERS.
2. CENTER OF GRAVITY
3. DIRECTION OF AIR FLOW
4. ALL VIEW DRAWN USING 3RD ANGLE

| UNIT     | OUTDOOR COIL TYPE | J             | K            | H            |
|----------|-------------------|---------------|--------------|--------------|
| 48FC-M08 | RTPF              | 41 1/4 [1048] | 33 3/4 [857] | 15 7/8 [403] |
| 48FC-M09 | RTPF              | 49 3/8 [1253] | 36 3/8 [925] | 15 7/8 [403] |
| 48FC-M12 | RTPF              | 49 3/8 [1253] | 36 3/8 [925] | 15 7/8 [403] |


RTPF - ROUND TUBE, PLATE FIN (COPPER/ALUM)




BACK



LEFT



TOP



FRONT



THIS DOCUMENT IS THE PROPERTY OF CARRIER CORPORATION AND IS DELIVERED UPON THE EXPRESS CONDITION THAT THE CONTENTS WILL NOT BE DISCLOSED OR USED WITHOUT CARRIER CORPORATION'S WRITTEN CONSENT.

SUBMISSION OF THESE DRAWINGS OR DOCUMENTS DOES NOT CONSTITUTE PART PERFORMANCE OR ACCEPTANCE OF CONTRACT.

| CONNECTION SIZES |                                         |
|------------------|-----------------------------------------|
| A                | 1 3/8" [35] DIA FIELD POWER SUPPLY HOLE |
| B                | 2 1/2" [64] DIA POWER SUPPLY KNOCKOUT   |
| C                | 1 3/4" [51] DIA GAUGE ACCESS PLUG       |
| D                | 7/8" [22] DIA FIELD CONTROL WIRING HOLE |
| E                | 3/4"-14 NPT CONDENSATE DRAIN            |
| F                | 1/2"-14 NPT GAS CONNECTION              |
| G                | 2" [51] DIA POWER SUPPLY KNOCK-OUT      |

## THRU-THE-BASE CHART (FIELD INST)


THESE HOLES REQUIRED FOR USE WITH ACCY KITS:  
CRBTMPWRO02A01: GAS THRU CURB  
CRBTMPWRO04A01: GAS THRU BASEPAN

|   | THREADED CONDUIT SIZE                                                    | WIRE USE | REQ'D HOLE SIZES (MAX.) |
|---|--------------------------------------------------------------------------|----------|-------------------------|
| W | 1/2"                                                                     | ACC.     | 7/8" [22.2]             |
| X | 1/2"                                                                     | 24V      | 7/8" [22.2]             |
| Y | 1 1/4" (002,004)                                                         | POWER    | 1 3/4" [44.4]           |
| Z | (004) 3/4" FPT                                                           | GAS      | 1 3/4" [44.4]           |
| * | (002) PROVIDES 3/4" FPT THRU CURB FLANGE & FITTING. HOLE SIZE: 2" [50.8] |          |                         |

## THRU-THE-BASE CHART (FIOP)

FOR "THRU-THE-BASEPAN" FACTORY OPTION, FITTINGS FOR ONLY X, Y, & Z ARE PROVIDED. \*\*

FOR BELOW LISTED MODELS, A FIELD SUPPLIED 1/2" ADAPTER IS REQUIRED BETWEEN BASE PAN FITTING AND GAS VALVE:  
48FCD, S\*08, 09



RIGHT

|                    |        |          |            |                                                         |            |     |
|--------------------|--------|----------|------------|---------------------------------------------------------|------------|-----|
| ITC CLASSIFICATION | SHEET  | DATE     | SUPERCEDES | 48FC 08-12 SINGLE ZONE ELECTRICAL COOLING WITH GAS HEAT | 48TM006295 | REV |
| U.S. ECCN: NSR     | 1 OF 3 | 03/12/21 | -          |                                                         |            | -   |

## Performance Summary For 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

### Part Number:48FCEM09A3A5-8B0AN

Refrigerant:..... R-410A  
ARI EER:..... 11.20  
IEER:..... 15.0

#### Base Unit Dimensions

Unit Length:..... 88.1 in  
Unit Width:..... 59.5 in  
Unit Height:..... 49.4 in

#### Operating Weight

Base Unit Weight:..... 868 lb  
Medium Heat:..... 15 lb  
High Static (EcoBlue):..... 30 lb  
Temperature Economizer w/ Barometric Relief:..... 55 lb  
  
Total Operating Weight:..... 968 lb

#### Unit

Unit Voltage-Phase-Hertz:..... 230-3-60  
Air Discharge:..... Vertical  
Fan Drive Type:..... Vane Axial  
Actual Airflow:..... 3400 CFM  
Site Altitude:..... 100 ft

#### Cooling Performance

Condenser Entering Air DB:..... 95.0 F  
Evaporator Entering Air DB:..... 80.0 F  
Evaporator Entering Air WB:..... 67.0 F  
Entering Air Enthalpy:..... 31.50 BTU/lb  
Evaporator Leaving Air DB:..... 58.5 F  
Evaporator Leaving Air WB:..... 57.6 F  
Evaporator Leaving Air Enthalpy:..... 24.82 BTU/lb  
Gross Cooling Capacity:..... 101.72 MBH  
Gross Sensible Capacity:..... 78.71 MBH  
Compressor Power Input:..... 6.95 kW  
Coil Bypass Factor:..... 0.087

#### Heating Performance

Heating Airflow:..... 3400 CFM  
Entering Air Temp:..... 70.0 F  
Leaving Air Temp:..... 110.5 F  
Gas Heating Input Capacity:..... 120.0 / 180.0 MBH  
Gas Heating Output Capacity:..... 98.0 / 148.0 MBH  
Temperature Rise:..... 40.5 F

#### Supply Fan

External Static Pressure:..... 0.50 in wg  
Options / Accessories Static Pressure  
Economizer:..... 0.14 in wg  
Application External Static (ESP + Unit Opts/Acc.):..... 0.64 in wg  
Fan RPM:..... 1578  
Fan Power:..... 1.37 BHP  
NOTE:..... Selected IFM RPM Range: 1110 - 2200

Selection includes construction throwaway filter into the base fan curve. This filter is not MERV Rated.

#### Electrical Data

Voltage Range:..... 187 - 253

## Performance Summary For 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

|                                   |         |
|-----------------------------------|---------|
| Compressor #1 RLA:                | 13.7    |
| Compressor #1 LRA:                | 123     |
| Compressor #2 RLA:                | 13.7    |
| Compressor #2 LRA:                | 123     |
| Indoor Fan Motor Type:            | HIGH    |
| Indoor Fan Motor FLA (Total):     | 7.5     |
| Combustion Fan Motor FLA (ea):    | 0.48    |
| Power Supply MCA:                 | 42      |
| Power Supply MOCP (Fuse or HACR): | 50      |
| Disconnect Size FLA:              | 44      |
| Disconnect Size LRA:              | 265     |
| Electrical Convenience Outlet:    | None    |
| Outdoor Fan [Qty / FLA (ea)]:     | 2 / 1.5 |


**Control Panel SCCR: 5kA RMS at Rated Symmetrical Voltage**

### Acoustics

Sound Power Levels, db re 10E-12 Watts

|            | Discharge | Inlet | Outdoor |
|------------|-----------|-------|---------|
| 63 Hz      | 85.8      | 82.4  | 85.6    |
| 125 Hz     | 81.9      | 76.3  | 84.7    |
| 250 Hz     | 76.5      | 70.4  | 80.5    |
| 500 Hz     | 73.3      | 65.9  | 76.0    |
| 1000 Hz    | 74.6      | 66.2  | 72.4    |
| 2000 Hz    | 70.4      | 59.9  | 68.0    |
| 4000 Hz    | 65.7      | 52.6  | 62.8    |
| 8000 Hz    | 56.6      | 47.1  | 59.3    |
| A-Weighted | 78.4      | 70.2  | 79.0    |

### Advanced Acoustics



### Advanced Acoustics Parameters

|                                                      |      |    |
|------------------------------------------------------|------|----|
| 1. Unit height above ground:                         | 30.0 | ft |
| 2. Horizontal distance from unit to receiver:        | 50.0 | ft |
| 3. Receiver height above ground:                     | 5.7  | ft |
| 4. Height of obstruction:                            | 0.0  | ft |
| 5. Horizontal distance from obstruction to receiver: | 0.0  | ft |
| 6. Horizontal distance from unit to obstruction:     | 0.0  | ft |

### Detailed Acoustics Information

| Octave Band Center Freq. Hz | 63   | 125  | 250  | 500  | 1k   | 2k   | 4k   | 8k   | Overall |
|-----------------------------|------|------|------|------|------|------|------|------|---------|
| A                           | 85.6 | 84.7 | 80.5 | 76.0 | 72.4 | 68.0 | 62.8 | 59.3 | 89.2 Lw |

## Performance Summary For 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied


10/06/2026  
04:14PM

|   |      |      |      |      |      |      |      |      |          |
|---|------|------|------|------|------|------|------|------|----------|
| B | 59.4 | 68.6 | 71.9 | 72.8 | 72.4 | 69.2 | 63.8 | 58.2 | 78.5 LwA |
| C | 53.2 | 52.3 | 48.1 | 43.6 | 40.0 | 35.6 | 30.4 | 26.9 | 56.8 Lp  |
| D | 27.0 | 36.2 | 39.5 | 40.4 | 40.0 | 36.8 | 31.4 | 25.8 | 46.1 LpA |

### Legend

A Sound Power Levels at Unit's Acoustic Center, Lw  
B A-Weighted Sound Power Levels at Unit's Acoustic Center, LwA  
C Sound Pressure Levels at Specific Distance from Unit, Lp  
D A-Weighted Sound Pressure Levels at Specific Distance from Unit, LpA

Calculation methods used in this program are patterned after the ASHRAE Guide; other ASHRAE Publications and the AHRI Acoustical Standards. While a very significant effort has been made to insure the technical accuracy of this program, it is assumed that the user is knowledgeable in the art of system sound estimation and is aware of the tolerances involved in real world acoustical estimation. This program makes certain assumptions as to the dominant sound sources and sound paths which may not always be appropriate to the real system being estimated. Because of this, no assurances can be offered that this software will always generate an accurate sound prediction from user supplied input data. If in doubt about the estimation of expected sound levels in a space, an Acoustical Engineer or a person with sound prediction expertise should be consulted.



## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

Note about this specification:

This specification is in the "Masterformat" as published by the Construction Specification Institute. Please feel free to copy this specification directly into your building spec.



### Gas Heat/Electric Cooling Packaged Rooftop

#### HVAC Guide Specifications

Size Range: **7.5 to 15 Nominal Tons**

Carrier Model Number: **48FC\*08-16**

#### (23 06 80) Schedules for Decentralized HVAC Equipment

(23 06 80.13) Decentralized Unitary HVAC Equipment Schedule

(23 06 80.13.A.) Rooftop Unit (RTU) Schedule:

1. Schedule is per the project specification requirements.

#### (23 07 16) HVAC Equipment Insulation

(23 07 16.13) Decentralized, Rooftop Units:

(23 07 16.13.A.) Evaporator Fan Compartment:

2. Interior cabinet surfaces shall be insulated with a minimum 1/2 in. thick, minimum 1-1/2 lb density, flexible fiberglass insulation bonded with a phenolic binder, neoprene coated on the air side.
2. Insulation and adhesive shall meet NFPA 90A requirements for flame spread and smoke generation.

(23 07 16.13.B.) Gas Heat Compartment:

3. Aluminum foil-faced fiberglass insulation shall be used.
3. Insulation and adhesive shall meet NFPA 90A requirements for flame spread and smoke generation.

#### (23 09 13) Instrumentation and Control Devices for HVAC

(23 09 13.23) Sensors and Transmitters

(23 09 13.23.A.) Thermostats:

4. Thermostat must:
  - a. energize both "W" and "G" when calling for heat.
  - b. have capability to energize 1 or 2 stages of cooling, and 2 different stages of heating.
  - c. include capability for occupancy scheduling.

#### (23 09 23) Direct Digital Control system for HVAC

(23 09 23.13) Decentralized, Rooftop Units:

(23 09 23.13.A.) SystemVu™ intelligent integrated Direct Digital Control (DDC) shall provide:

1. Integrated unit operation for comfort cooling, heating ventilation as well as all monitoring, recording and reporting capabilities. Controller shall also provide diagnostics and alarms of abnormal unit operation through the controller. Controller shall have an intuitive user display and be able to be used in a standalone operation or via building automation system (BAS).
2. Quick Unit Status LEDs of: RUN — meaning all systems are go, ALERT — that indicates there is currently a non-critical issue with the unit, like filters need to be replaced and FAULT — that indicates the unit has a critical issue and will

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

possibly shut down.

3. Six large navigation keys for easy access. Navigation keys shall consist of: TEST, BACK, ENTER, and MENU along with UP and DOWN arrows.
4. Full back lit user display with 4 line by 30 character text capabilities. Display menu shall be designed to provide guided major menus and sub menus main menus provided below:
  - a. Shutdown Unit
  - b. Run Status
  - c. Settings
  - d. Alerts/Faults
  - e. Service
  - f. Inputs
  - g. Outputs
  - h. USB
5. The capability for standalone operation with conventional thermostat/sensor or use with building automation systems (BAS) of Carrier i-Vu®, BACnet MS/PT and Carrier Comfort Network® (CCN) systems. No special modules or boards are required for these capabilities. Has the capability to work with Equipment Touch™ and System Touch™ devices and ZS Sensors.
6. The ability to read refrigerant pressures at display or via BAS network of Discharge Pressure and Suction Pressure. The need for traditional refrigerant gauges is not required.
7. USB Data Port for flash drive interaction. This will allow the transfer of data for uploads, downloads, perform software upgrades, back-up and restore data and file transfer data such as component number of starts and run hours.
8. Reverse Rotation Protection of compressors if field 3-phase wiring is misapplied.
9. Provide Service Capabilities of:
  - b. Auto run test
  - c. Manual run test
  - d. Component run hours and starts
  - e. Commissioning reports
  - e. Data logging
  - f. Alarm history
10. Economizer control and diagnostics. Set up economizer operation, receive feedback from actuator. Also meets the most recent California Title 24, ASHRAE 90.1 and IECC Fault Detection and Diagnostic (FDD) requirements.
11. Unit cooling operation down to 40°F (4°C) (0°F [-18°C] for size 14 models).
12. Controller shall have easy access connections around the controller perimeter area and consist of Mate-N-Lok, terminal block and RJ style modular jack connections.
13. 365 day real time clock, 20 holiday schedules along with occupied and unoccupied scheduling.
14. Auto-Recognition for easy installation and commissioning of devices like economizers, space sensors etc.
15. A 5°F (3°C) temperature difference between cooling and heating setpoints to meet the latest ASHRAE 90.1 Energy Standard.
16. Contain return air sensor, supply air sensor and outdoor air sensor to help monitor and provide data for the unit comfort operation, diagnostic and alarms.

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

17. Use of Carrier's field accessory hand-held Navigator™ display, Equipment Touch and System Touch devices.
18. Units with the factory-installed Humidi-MiZer® system option are capable of providing multiple modes of improved dehumidification as a variation of the normal cooling cycle.
19. Supply Air Tempering control operates the gas or electric heat to maintain a minimum supply air temperature during conditions where very cold outdoor air causes the supply air temperature to fall below the configured Supply Air Tempering Setpoint. This occurs during periods where DCV is active and increasing the amount of outdoor air or in cases where the system is operating at very low airflow and the calculated economizer position has increased to maintain a constant ventilation rate.
20. Demand limiting in SystemVu™ is achieved through setpoint expansion. The systems heating and cooling setpoints are expanded in steps or levels. The degree to which the setpoints may be expanded is defined by the 6 demand level offsets and the 2 commanded demand limit levels.
21. 3-year limited part warranty.

### (23 09 33) Electric and Electronic Control System for HVAC

(23 09 33.13) Decentralized, Rooftop Units:

(23 09 33.13.A.) General:

1. Shall be complete with self-contained low-voltage control circuit protected by a resettable circuit breaker on the 24-v transformer side. Transformer shall have 75VA capability.
2. Shall utilize color-coded wiring.
3. Shall include a Unit Control Board to conveniently and safely provide connection points for vital control functions such as: smoke detectors, phase monitor, gas controller, economizer, thermostat, DDC control options, and low and high pressure switches. Controller shall also provide an intuitive means to adjust the indoor fan speed through a simple switch and pot adjustment design.
4. The heat exchanger shall be controlled by an integrated gas controller (IGC) microprocessor. See heat exchanger section of this specification.
5. Unit shall include a minimum of one 8-pin screw terminal connection board for connection of control wiring.

(23 09 33.13.B.) Safeties:

2. Compressor over-temperature, over-current. High internal pressure differential.
3. Low Pressure Switch:
  - a. Low pressure switch shall use different color wire than the high pressure switch. The purpose is to assist the installer and service technician to correctly wire and or troubleshoot the rooftop unit.
4. High Pressure Switch:
  - b. High pressure switch shall use different color wire than the low pressure switch. The purpose is to assist the installer and service technician to correctly wire and or troubleshoot the rooftop unit.
5. Mixed Air Auto Reset Temperature Switch:
  - c. When return air temperatures get the critical point that can cause compressor reliability issues, this switch will shut down compression only until the temperature raise accordingly. Switch opens at 60°F (16°C) and closes at 65°F (18°C).
6. Automatic Reset, Motor Thermal Overload Protector.
6. Heating section shall be provided with the following minimum protections:
  - d. High temperature limit switches.
  - b. Induced draft motor speed sensor.
  - c. Flame rollout switch.

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

d. Flame proving controls.

### (230993) Sequence of Operations for HVAC Controls

(230993.13) Decentralized, Rooftop Units:

(230993.13.A.) INSERT SEQUENCE OF OPERATION

### (234013) Panel Air Filters

(234013.13) Decentralized, Rooftop Units:

(234013.13.A.) Standard Filter Section:

1. Shall consist of factory installed, low velocity, disposable 2 in. thick fiberglass filters of commercially available sizes.
2. Unit shall use only one filter size. Multiple sizes are not acceptable.
3. Filters shall be accessible through an access panel with "no-tool" removal as described in the unit cabinet section of this specification (238119.13.G).

### (238119) Self-Contained Air Conditioners

(238119.13) Small-Capacity Self-Contained Air Conditioners:

(238119.13.A.) General:

2. Outdoor, rooftop mounted, electrically controlled, heating and cooling unit utilizing a fully hermetic scroll compressors for cooling duty and gas combustion for heating duty.
3. Factory assembled, single-piece heating and cooling rooftop unit. Contained within the unit enclosure shall be all factory wiring, piping, controls, and special features required prior to field start-up.
4. Unit shall use Puron® (R-410A) refrigerant.
4. Unit shall be installed in accordance with the manufacturer's instructions.
7. Unit must be selected and installed in compliance with local, state, and federal codes.

(238119.13.B.) Quality Assurance:

3. Unit meets ASHRAE 90.1 minimum efficiency requirements.
4. Unit shall be rated in accordance with AHRI Standards 340/360.
5. Unit shall be designed to conform to ASHRAE 15.
5. Unit shall be UL-tested and certified in accordance with ANSI Z21.47 Standards and UL-listed and certified under Canadian standards as a total package for safety requirements.
8. Insulation and adhesive shall meet NFPA 90A requirements for flame spread and smoke generation.
7. Unit casing shall be capable of withstanding 500 hour salt spray exposure per ASTM B117 (scribed specimen).
8. Unit shall be designed in accordance with ISO 9001, and shall be manufactured in a facility registered by ISO 9001:2015.
9. Roof curb shall be designed to conform to NRCA Standards.
10. Unit shall be subjected to a completely automated run test on the assembly line. The data for each unit will be stored at the factory, and must be available upon request.
11. Unit shall be designed in accordance with UL Standard 60335-2-40, including tested to withstand rain.
12. Unit shall be constructed to prevent intrusion of snow and tested to prevent snow intrusion into the control box up to 40 mph.
13. Unit shake tested to assurance level 1, ASTM D4169 to ensure shipping reliability.

(238119.13.C.) Delivery, Storage, and Handling:

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

4. Unit shall be stored and handled per manufacturer's recommendations.
5. Lifted by crane requires either shipping top panel or spreader bars.
6. Unit shall only be stored or positioned in the upright position.

(2381 19.13.D.) Project Conditions:

5. As specified in the contract.

(2381 19.13.E.) Operating Characteristics:

6. Unit shall be capable of starting and running at 125°F (52°C) ambient outdoor temperature except 14 size models that are capable of starting and running at 120°F (49°C), meeting maximum load criteria of AHRI Standard 210/240 or 340/360 at ±10% voltage.
6. Compressor with standard controls shall be capable of operation down to 40°F (4°C) [0°F (–18°C) for size 14 models], ambient outdoor temperatures. Accessory winter start kit is necessary if mechanically cooling at ambient temperatures down to 25°F (–4°C) or 0°F (–18°C).
7. Unit shall discharge supply air vertically or horizontally as shown on contract drawings.
6. Unit shall be factory configured for vertical supply and return configurations.
9. Unit shall be field convertible from vertical to horizontal airflow on all models. No special kit required except on 16 size models that require a Supply Duct Kit field installed for horizontal air flow.
8. Unit shall be capable of mixed operation: vertical supply with horizontal return or horizontal supply with vertical return.

(2381 19.13.F.) Electrical Requirements:

7. Main power supply voltage, phase, and frequency must match those required by the manufacturer.

(2381 19.13.G.) Unit Cabinet:

8. Unit cabinet shall be constructed of galvanized steel, and shall be bonderized and coated with a prepainted baked enamel finish on all externally exposed surfaces.
7. Unit cabinet exterior paint shall be: film thickness, (dry) 0.003 inches minimum, gloss (per ASTM D523, 60°F/16°C): 60, Hardness: H-2H Pencil hardness.
8. Evaporator fan compartment interior cabinet insulation shall conform to AHRI Standards 340/360 minimum exterior sweat criteria. Interior surfaces shall be insulated with a minimum 1/2 in. thick, 1 lb density, flexible fiberglass insulation, neoprene coated on the air side. Aluminum foil-faced fiberglass insulation shall be used in the gas heat compartment.
7. Base of unit shall have a minimum of 4 locations for thru-the-base gas and electrical connections (factory-installed or field-installed), standard.
10. Base Rail:
  - a. Unit shall have base rails on a minimum of 2 sides.
  - b. Holes shall be provided in the base rails for rigging shackles to facilitate maneuvering and overhead rigging.
  - c. Holes shall be provided in the base rail for moving the rooftop by fork truck.
  - d. Base rail shall be a minimum of 16 gauge thickness.
9. Condensate Pan and Connections:
  - b. Shall be a sloped condensate drain pan made of a corrosion resistant material.
  - c. Shall comply with ASHRAE Standard 62.
  - d. Shall use a 3/4 in. 14 NPT drain connection, possible either through the bottom or side of the drain pan. Connection shall be made per manufacturer's recommendations.
9. Top Panel:

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

- c. Shall be a single piece top panel on 08-14 models and 2 piece on 16 size models.

### 10. GasConnections:

- d. All gas piping connecting to unit gas valve shall enter the unit cabinet at a single location on side of unit (horizontal plane).
- d. Thru-the-Base Capability:
  - 1) Standard unit shall have a thru-the-base gas-line location using a raised, embossed portion of the unit basepan.
  - 2) Optional, factory approved, water-tight connection method must be used for thru-the-base gas connections.
  - 3) No basepan penetration, other than those authorized by the manufacturer, is permitted.

### 11. Electrical Connections:

- a. All unit power wiring shall enter unit cabinet at a single, factory prepared, knockout location.
- b. Thru-the-Base Capability:
  - 1) Standard unit shall have a thru-the-base electrical location(s) using a raised, embossed portion of the unit basepan.
  - 2) Optional, factory approved, water-tight connection method must be used for thru-the-base electrical connections.
  - 4) No basepan penetration, other than those authorized by the manufacturer, is permitted.

### 12. ComponentAccessPanels (standard):

- a. Cabinet panels shall be easily removable for servicing.
- b. Unit shall have one factory installed, tool-less, removable, filter access panel.
- c. Panels covering control box, indoor fan, indoor fan motor, gas components (where applicable), and compressors shall have molded composite handles.
- e. Handles shall be UV modified, composite. They shall be permanently attached, and recessed into the panel.
- e. Screws on the vertical portion of all removable access panel shall engage into heat resistant, molded composite collars.
- f. Collars shall be removable and easily replaceable using manufacturer recommended parts.

### (238119.13.H.) Gas Heat:

#### 1. General:

- a. Heat exchanger shall be an induced draft design. Positive pressure heat exchanger designs shall not be allowed.
- c. Shall incorporate a direct-spark ignition system and redundant main gas valve.
- d. Gas supply pressure at the inlet to the rooftop unit gas valve must match that required by the manufacturer.

#### 2. The heat exchanger shall be controlled by an integrated gas controller (IGC) microprocessor.

- b. IGC board shall notify users of fault using an LED (light-emitting diode).
- b. The LED shall be visible without removing the control box access panel.
- e. IGC board shall contain algorithms that modify evaporator fan operation to prevent future cycling on high temperature limit switch.
- f. Unit shall be equipped with anti-cycle protection with one short cycle on unit flame rollout switch or 4 continuous short cycles on the high temperature limit switch. Fault indication shall be made using an LED.

#### 3. Standard Heat Exchanger Construction:

- c. Heat exchanger shall be of the tubular-section type constructed of a minimum of 20-gauge steel coated with a nominal 1.2 mil aluminum-silicone alloy for corrosion resistance.
- c. Burners shall be of the in-shot type constructed of aluminum-coated steel.

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

- c. Burners shall incorporate orifices for rated heat output up to 2000 ft (610 m) elevation. Additional accessory kits may be required for applications above 2000 ft (610 m) elevation, depending on local gas supply conditions.
- g. Each heat exchanger tube shall contain multiple dimples for increased heating effectiveness.
- 4. Optional Stainless Steel Heat Exchanger Construction:
  - d. Use energy saving, direct-spark ignition system.
  - d. Use a redundant main gas valve.
  - d. Burners shall be of the in-shot type constructed of aluminum-coated steel.
  - d. All gas piping shall enter the unit cabinet at a single location on side of unit (horizontal plane).
  - f. The optional stainless steel heat exchanger shall be of the tubular-section type, constructed of a minimum of 20-gauge type 409 stainless steel.
  - g. Type 409 stainless steel shall be used in heat exchanger tubes and vestibule plate.
  - g. Complete stainless steel heat exchanger allows for greater application flexibility.
- 5. Induced Draft Combustion Motor and Blower:
  - e. Shall be a direct-drive, single inlet, forward-curved centrifugal type.
  - e. Shall be made from steel with a corrosion resistant finish.
  - e. Shall have permanently lubricated sealed bearings.
  - e. Shall have inherent thermal overload protection.
  - e. Shall have an automatic reset feature.

### (2381 19.13.I.) Coils:

- 1. Standard Aluminum Fin-Copper Tube Coils:
  - a. Standard evaporator and condenser coils shall have aluminum lanced plate fins mechanically bonded to seamless internally grooved copper tubes with all joints brazed.
  - f. Evaporator coils shall be leak tested to 150 psig, pressure tested to 450 psig, and qualified to UL 1995 burst test at 1775 psig.
  - f. Condenser coils shall be leak tested to 150 psig, pressure tested to 650 psig, and qualified to UL 1995 burst test at 1980 psig.
- 2. Optional Pre-coated Aluminum-Fin Condenser Coils:
  - b. Shall have a durable epoxy-phenolic coating to provide protection in mildly corrosive coastal environments.
  - b. Coating shall be applied to the aluminum fin stock prior to the fin stamping process to create an inert barrier between the aluminum fin and copper tube.
  - g. Epoxy-phenolic barrier shall minimize galvanic action between dissimilar metals.
  - f. Corrosion durability of fin stock shall be confirmed through testing to be no less than 1000 hours salt spray per ASTM B117-90.
  - f. Corrosion durability of fin stock shall be confirmed through testing to have no visible corrosion after 48 hour immersion in a room temperature solution of 5% salt, 1% acetic acid.
  - h. Fin stock coating shall pass 2000 hours of the following: one week exposure in the prohesion chamber followed by one week of accelerated ultraviolet light testing. Prohesion chamber: the solution shall contain 3.5% sodium chloride and 0.35% ammonium sulfate. The exposure cycle is one hour of salt fog application at ambient followed by one hour drying at 95°F (35°C).
- 3. Optional Copper-Fin Evaporator and Condenser Coils:

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

- c. Shall be constructed of copper fins mechanically bonded to copper tubes and copper tube sheets.
- c. Galvanized steel tube sheets shall not be acceptable.
- c. A polymer strip shall prevent coil assembly from contacting the sheet metal coil pan to minimize potential for galvanic corrosion between coil and pan.

#### 4. Optional E-coated Aluminum-Fin Evaporator and Condenser Coils:

- d. Shall have a flexible epoxy polymer coating uniformly applied to all coil surface areas without material bridging between fins.
- d. Coating process shall ensure complete coil encapsulation of tubes, fins and headers.
- d. Color shall be high gloss black with gloss per ASTM D523-89.
- d. Uniform dry film thickness from 0.8 to 1.2 mil on all surface areas including fin edges.
- g. Superior hardness characteristics of 2H per ASTM D3363-92A and cross-hatch adhesion of 4B-5B per ASTM D3359-93.
- i. Impact resistance shall be up to 160 in. lb (ASTM D2794-93).
- h. Humidity and water immersion resistance shall be up to minimum 1000 and 250 hours respectively (ASTM D2247-92 and ASTM D870-92).
- h. Corrosion durability shall be confirmed through testing to be no less than 1000 hours salt spray per ASTM B117-90.

#### (2381 19.13.J.) Refrigerant Components:

##### 1. Refrigerant circuit shall include the following control, safety, and maintenance features:

- a. Thermostatic Expansion Valve (TXV) shall help provide optimum performance across the entire operating range. Shall contain removable power element to allow change out of power element and bulb without removing the valve body.
- e. Refrigerant filter drier — Solid core design.
- e. Service gauge connections on suction and discharge lines.
- e. Pressure gauge access through a specially designed access port in the top panel of the unit.

##### 2. Compressors:

- b. Unit shall use 2 tandem scroll compressors on single independent refrigeration circuit.
- b. Units shall have single circuit and 2 stage cooling and contain 2 dual stage compressors.
- f. Evaporator coils shall be a full active design to help better control comfort latent removal.
- f. Compressor motors shall be cooled by refrigerant gas passing through motor windings.
- h. Compressors shall be internally protected from high discharge temperature conditions.
- j. Compressors shall be protected from an over-temperature and over-amperage conditions by an internal, motor overload device.
- i. Compressor shall be factory-mounted on rubber grommets.
- i. Compressor motors shall have internal line break thermal, current overload and high pressure differential protection.
- i. Crankcase heaters shall not be required for normal operating range, unless required by the manufacturer due to refrigerant charge limits.

#### (2381 19.13.K.) Return Air Filter Section:

- 1. Filters access is specified in the unit cabinet section of this specification.
- 2. Filters shall be held in place by a pivoting filter tray, facilitating easy removal and installation.
- 3. Shall consist of factory installed, low velocity, throw-away 2 in. thick fiberglass filters.

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

4. Filters shall be standard, commercially available sizes.

5. Only one size filter per unit is allowed.

(2381 19.13.L.) Evaporator Fan and Motor with EcoBlue™ Technology:

2. Direct Drive Evaporator Fan Motor:

- a. Shall be a ECM motor design.
- b. Shall have permanently lubricated bearings.
- c. Shall have inherent automatic-reset thermal overload protection.
- d. Shall have slow ramp up to speed capabilities.
- e. Shall require no fan/motor belts for operation, adjustments and or initial fan speed set up.
- k. Fan DC voltage set up on Unit Control Board can eliminate the need of removal of blower access door, required on conventional belt drive systems.
- j. Shall be internally protected from electrical phase reversal and loss.

2. Evaporator Fan:

- b. Shall be easily set with dedicated selection switch and adjustment pot on unit control board or through SystemVu™ controller.
  - b. Shall provide 2 stage cooling capacity control, the indoor fan speed is automatically controlled to meet the code-compliant <66% low fan speed and 100% at full fan speed operation.
  - d. Blower fan shall be a Vane Axial fan design with 75% less moving parts than a conventional belt drive system.
  - e. Shall be constructed of a cast aluminum stator and high impact composite material on stator, rotor and air inlet casing.
  - f. Shall be a patented design with a corrosion resistant material and dynamically balanced.
  - l. Shall have slow ramp up to speed capabilities to help reduce sound and comfort issues typically associated with single speed belt drive systems.
  - k. Shall be a slide out design with removal of a few support brackets.
3. Shall include an easily accessible Unit Control Board to conveniently and safely provide connection points for vital control functions such as: smoke detectors, phase monitor, gas controller, economizer, thermostat, DDC control options, and low, high and mixed air temperature switches. Controller shall also provide an intuitive means to adjust the indoor fan speed through a simple switch and pot adjustment design.

(2381 19.13.M.) Condenser Fans and Motors:

1. Condenser Fan Motors:

- a. Shall be a totally enclosed motor.
- c. Shall use permanently lubricated bearings.
- c. Shall have inherent thermal overload protection with an automatic reset feature.
- f. Shall use a shaft-down design on all sizes.

2. Condenser Fans:

- b. Shall be a direct-driven propeller type fan.
- b. Shall have galvalum blades riveted to steel spider that have corrosion-resistant properties and shall be dynamically balanced.

(2381 19.13.N.) Special Features Options and Accessories:

1. Integrated Economizer ONE and EconoMiSer® 2 Low Leak Rate Models.

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

- a. Integrated, gear driven opposing modulating blade design type capable of simultaneous economizer and compressor operation.
- c. Independent modules for vertical or horizontal return configuration shall be available. Vertical return modules shall be available as a factory installed option.
- d. Damper blades shall be galvanized steel with composite gears. Plastic or composite blades on intake or return shall not be acceptable.
- g. Shall include all hardware and controls to provide free cooling with outdoor air when temperature and/or humidity are below set-points.
- g. Shall be equipped with gear driven dampers for both the outdoor ventilation air and the return air for positive air stream control.
- m. Standard leak rate shall be equipped with dampers not to exceed 2% leakage at 1 in. wg pressure differential.
- l. Economizer controller on EconomizerONE models shall be Siemens POL224 that provides:
  - 1) Combined minimum and DCV maximum damper position potentiometers with compressor staging relay.
  - 2) Functions with solid-state analog enthalpy or dry bulb changeover control sensing.
  - 3) LED indicators for free cooling, sensor, and damper operation.
  - 4) One-line LCD interface screen for setup, configuration and troubleshooting.
  - 5) Optional configuration via WLAN stick and Siemens Climatix™<sup>1</sup> smartphone app for easy setup.
  - 6) On-board Fault Detection and Diagnostics (FDD) that senses and alerts when the economizer is not operating properly, per California Title 24, ASHRAE 90.1 and IECC®.
  - 7) Sensor failure loss of communication identification.
  - 8) Capabilities for use with multiple-speed or single speed indoor fan systems.
  - 9) Digital sensors: Dry bulb and Enthalpy.
- h. Economizer controller on EconoMi\$er 2 models with SystemVu™ controls shall be a 4 to 20mA design controlled directly by the controller. SystemVu controller meets California Title 24, ASHRAE 90.1 and IECC Fault Detection and Diagnostic (FDD) requirements.
  - i. Shall be capable of introducing up to 100% outdoor air.
  - j. Shall be equipped with a barometric relief damper capable of relieving up to 100% return air and contain seals that meet ASHRAE 90.1 requirements.
  - k. Shall be designed to close damper(s) during loss-of-power situations with spring return built into motor.
  - l. Dry bulb outdoor air temperature sensor shall be provided as standard. Enthalpy sensor is also available on factory-installed economizers only. Outdoor air sensor setpoint shall be adjustable and shall range from 40°F to 100°F (4°C to 38°C). Additional sensor options shall be available as accessories.
- m. The economizer controller shall also provide control of an accessory power exhaust unit function. Factory set at 100%, with a range of 0% to 100%.
- n. The economizer shall maintain minimum airflow into the building during occupied period and provide design ventilation rate for full occupancy.
- o. Dampers shall be completely closed when the unit is in the unoccupied mode.
- p. Economizer controller shall accept a 0 to 10 vdc CO<sub>2</sub> sensor input for IAQ/DCV control. In this mode, dampers shall modulate the outdoor air damper to provide ventilation based on the sensor input.
- q. Compressor lockout temperature on POL224 control is adjustable from -45°F to 80°F (-42.8°C to 26.6°C), set at a factory default of 32°F (0°C).

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

- r. Actuator shall be direct coupled to economizer gear. No linkage arms or control rods shall be acceptable.
- s. Contains LED indicators for free cooling, sensor, and damper operation.

### 2 Integrated EconoMiSer 2 and EconomizerONE Ultra Low Leak Rate Models.

- a. Integrated, gear driven opposing modulating blade design type capable of simultaneous economizer and compressor operation.
- b. Independent modules for vertical or horizontal return configuration shall be available. Vertical return modules shall be available as a factory installed option.
- c. Damper blades shall be galvanized steel with composite gears. Plastic or composite blades on intake or return shall not be acceptable.
- d. Shall include all hardware and controls to provide free cooling with outdoor air when temperature and/or humidity are below setpoints.
- e. Shall be equipped with gear driven dampers for both the outdoor ventilation air and the return air for positive air stream control.
- f. Ultra Low Leak design meets California Title 24 section 140.4 and ASHRAE 90.1 requirements for 4 cfm per sq. ft on the outside air dampers and 10 cfm per sq. ft on the return dampers.
- g. Economizer controller on EconomizerONE models shall be the Siemens POL224 that provides:
  - 1) One-line LCD interface screen for setup, configuration and troubleshooting.
  - 2) Optional configuration via WLAN stick and Siemens Climatix™ smartphone app for easy setup.
  - 3) On-board Fault Detection and Diagnostics (FDD) that senses and alerts when the economizer is not operating properly, per California Title 24, ASHRAE 90.1 and IECC.
  - 4) Sensor failure loss of communication identification.
  - 5) Capabilities for use with multiple-speed indoor fan systems.
  - 6) Digital sensors: Dry bulb and Enthalpy.
- i. Economizer controller on EconoMiSer® 2 models with SystemVu™ controls shall be a 4-20mA design controlled directly by the controller. SystemVu controller meets California Title 24, ASHRAE 90.1 and IECC Fault Detection and Diagnostic (FDD) requirements.
- j. Shall be capable of introducing up to 100% outdoor air.
- k. Shall be equipped with a barometric relief damper capable of relieving up to 100% return air and contain seals that meet ASHRAE 90.1 requirements.
- l. Shall be designed to close damper(s) during loss-of-power situations with spring return built into motor.
- m. Dry bulb outdoor air temperature sensor shall be provided as standard. Enthalpy sensor is also available on factory-installed economizers only. Outdoor air sensor setpoint shall be adjustable and shall range from 40°F to 100°F (4°C to 38°C). Additional sensor options shall be available as accessories.
- n. The economizer controller shall also provide control of an accessory power exhaust unit function. Factory set at 100%, with a range of 0% to 100%.
- o. The economizer shall maintain minimum airflow into the building during occupied period and provide design ventilation rate for full occupancy.
- p. Dampers shall be completely closed when the unit is in the unoccupied mode.
- q. Economizer controller shall accept a 0 to 10 vdc CO<sub>2</sub> sensor input for IAQ/DCV control. In this mode, dampers shall modulate the outdoor air damper to provide ventilation based on the sensor input.
- r. Compressor lockout temperature on POL224 control is adjustable from -45°F to 80°F (-42.8°C to 26.6°C), set at a factory default of 32°F (0°C).

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

- s. Actuator shall be direct coupled to economizer gear. No linkage arms or control rods shall be acceptable.
- t. Contains LED indicators for free cooling, sensor, and damper operation.
- 3. Wi-Fi/WLAN stick for EconomizerONE POL224 (field-installed):  
This item allows use of the Siemens Climatix™ mobile application.
- 4. Two-Position Damper (Field-installed only):
  - a. Damper shall be a Two-Position Damper. Damper travel shall be from the full closed position to the field adjustable%-open set-point.
  - b. Damper shall include adjustable damper travel from 25% to 100% (full open).
  - c. Damper shall include single or dual blade, gear driven dampers and actuator motor.
  - d. Actuator shall be direct coupled to damper gear. No linkage arms or control rods shall be acceptable.
  - e. Damper will admit up to 100% outdoor air for applicable rooftop units.
  - f. Damper shall close upon indoor (evaporator) fan shutoff and/or loss of power.
  - g. The damper actuator shall plug into the rooftop unit's wiring harness plug. No hard wiring shall be required.
  - h. Outside air hood shall include aluminum water entrainment filter.
- 5. Manual Damper (Field-installed only):
  - b. Manual damper package shall consist of damper, air inlet screen, and rain hood which can be preset to admit up to 25 or 50% outdoor air for year round ventilation.
- 6. Humidi-MiZer® Adaptive Dehumidification System:
  - c. The Humidi-MiZer Adaptive Dehumidification System shall be factory installed and shall provide greater dehumidification of the occupied space by 2 modes of dehumidification operations in addition to its normal design cooling mode:
    - 1) Subcooling mode further sub cools the hot liquid refrigerant leaving the condenser coil when both temperature and humidity in the space are not satisfied.
    - 2) Hot gas reheat mode shall mix a portion of the hot gas from the discharge of the compressor with the hot liquid refrigerant leaving the condenser coil to create a 2-phase heat transfer in the system, resulting in a neutral leaving air temperature when only humidity in the space is not satisfied.
    - 3) Includes low ambient controller.
- 7. Low Ambient Control Package:
  - a. Controller shall control coil head pressure by condenser fan speed modulation or condenser fan cycling and wind baffles.
  - b. Shall consist of solid-state control and condenser coil temperature sensor to maintain condensing temperature between 90°F (32°C) and 110°F (43°C) at outdoor ambient temperatures down to 0°F (-18°C).
- 8. Propane Gas Conversion Kit:
  - b. Package shall contain all the necessary hardware and instructions to convert a standard natural gas unit for use with liquefied propane, up to 2000 ft (610 m) elevation.
  - c. Additional accessory kits may be required for applications above 2000 ft (610 m) elevation.
- 9. Flue Shield (08-14 sizes only):
  - c. Flue shield shall provide protection from the hot sides of the gas flue hood.
- 10. Condenser Coil Hail Guard Assembly:
  - d. Shall protect against damage from hail.

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

- d. Shall be either hood style or louvered.
- 11. Unit-Mounted, Non-Fused Disconnect Switch (Available on 7.5 to 12.5 ton units with MOCs of 80 amps or less, or 15 ton units with MOCs of 100 amps or less):
  - e. Switch shall be factory installed, internally mounted.
  - e. National Electric Code (NEC) and UL approved non-fused switch shall provide unit power shutoff.
  - c. Shall be accessible from outside the unit.
  - e. Shall provide local shutdown and lockout capability.
  - e. Sized only for the unit as ordered from the factory. Does not accommodate field-installed devices.
- 12. Convenience Outlet:
  - f. Powered Convenience Outlet.
    - 1) Outlet shall be powered from main line power to the rooftop unit.
    - 2) Outlet shall be powered from line side or load side of disconnect by installing contractor, as required by code. If outlet is powered from load side of disconnect, unit electrical ratings shall be UL certified and rated for additional outlet amperage.
    - 3) Outlet shall be factory-installed and internally mounted with easily accessible 115-v female receptacle.
    - 4) Outlet shall be factory-installed and internally mounted with easily accessible 115-v female receptacle.
    - 5) Voltage required to operate convenience outlet shall be provided by a factory installed step-down transformer.
    - 6) Outlet shall be accessible from outside the unit.
    - 7) Outlet shall include a field installed "Wet in Use" cover.
  - b. Factory-Installed Non-Powered Convenience Outlet.
    - 2) Outlet shall be powered from a separate 115/120-v power source.
    - 2) A transformer shall not be included.
    - 4) Outlet shall be factory-installed and internally mounted with easily accessible 115-v female receptacle.
    - 5) Outlet shall include 15 amp GFI receptacles with independent fuse protection.
    - 6) Outlet shall be accessible from outside the unit.
    - 7) Outlet shall include a field installed "Wet in Use" cover.
  - c. Field-Installed Non-Powered Convenience Outlet.
    - 3) Outlet shall be powered from a separate 115/120v power source.
    - 3) A transformer shall not be included.
    - 3) Outlet shall be field-installed and internally mounted with easily accessible 115-v female receptacle.
    - 6) Outlet shall include 20 amp GFI receptacles. This kit provides a flexible installation method which allows code compliance for height requirements of the GFCI outlet from the finished roof surface as well as the capability to relocate the outlet to a more convenient location.
    - 7) Outlet shall be accessible from outside the unit.
    - 8) Outlet shall include a field installed "Wet in Use" cover.
- 13. Flue Discharge Deflector:
  - a. Flue discharge deflector shall direct unit exhaust vertically instead of horizontally.
  - b. Deflector shall be defined as a "natural draft" device by the National Fuel and Gas (NFG) code.

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

14. Thru-the-Base Connectors:
  - b. Kits shall provide connectors to permit gas and electrical connections to be brought to the unit through the unit basepan.
  - c. Minimum of 4 connection locations per unit.
15. Supply Duct Cover (size 16 only):
  - c. Required when field converting the factory standard vertical duct supply to horizontal duct supply configuration. One required per unit.
16. Propeller Power Exhaust:
  - d. Power exhaust shall be used in conjunction with an integrated economizer.
  - d. Independent modules for vertical or horizontal return configurations shall be available.
  - c. Horizontal power exhaust shall be mounted in return ductwork.
  - d. Power exhaust shall be controlled by economizer controller operation. Exhaust fans shall be energized when dampers open past the 0 to 100% adjustable setpoint on the economizer control.
17. Roof Curbs (Vertical):
  - e. Full perimeter roof curb with exhaust capability providing separate air streams for energy recovery from the exhaust air without supply air contamination.
  - e. Formed galvanized steel with wood nailer strip and shall be capable of supporting entire unit weight.
  - d. Permits installation and securing of ductwork to curb prior to mounting unit on the curb.
18. High Altitude Gas Conversion Kit:
  - f. Package shall contain all the necessary hardware and instructions to convert a standard natural gas unit to operate from 2000 to 7000 ft (610 to 2134 m) elevation with natural gas or from 0 to 7000 ft (0 to 2134 m) elevation with liquefied propane.
19. Outdoor Air Enthalpy Sensor:
  - g. The outdoor air enthalpy sensor shall be used to provide single enthalpy control. When used in conjunction with a return air enthalpy sensor, the unit will provide differential enthalpy control. The sensor allows the unit to determine if outside air is suitable for free cooling.
20. Return Air Enthalpy Sensor:
  - h. The return air enthalpy sensor shall be used in conjunction with an outdoor air enthalpy sensor to provide differential enthalpy control.
21. Indoor Air Quality (CO<sub>2</sub>) Sensor:
  - i. Shall be able to provide demand ventilation indoor air quality (IAQ) control.
  - f. The IAQ sensor shall be available in duct mount, wall mount, or wall mount with LED display. The setpoint shall have adjustment capability.
22. Smoke Detectors (factory-installed only):
  - j. Shall be a 4-Wire Controller and Detector.
  - g. Shall be environmental compensated with differential sensing for reliable, stable, and drift-free sensitivity.
  - e. Shall use magnet-activated test/reset sensor switches.
  - e. Shall have tool-less connection terminal access.
  - e. Shall have a recessed momentary switch for testing and resetting the detector.
  - f. Controller shall include:

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

- 1) One set of normally open alarm initiation contacts for connection to an initiating device circuit on a fire alarm control panel.
  - 2) Two Form-C auxiliary alarm relays for interface with rooftop unit or other equipment.
  - 3) One Form-C supervision (trouble) relay to control the operation of the Trouble LED on a remote test/reset station.
  - 4) Capable of direct connection to 2 individual detector modules.
  - 5) Can be wired to up to 14 other duct smoke detectors for multiple fan shutdown applications.
23. Winter Start Kit:
- a. Shall contain a bypass device around the low pressure switch.
  - b. Shall be required when mechanical cooling is required down to 25°F (−4°C).
  - c. Shall not be required to operate on an economizer when below an outdoor ambient of 40°F (4°C).
24. Time Guard:
- b. Shall prevent compressor short-cycling by providing a 5-minute delay (±2 minutes) before restarting a compressor after shutdown for any reason.
  - c. One device shall be required per compressor.
25. Disconnect Switch Bracket (size 16 only):
- c. Provides a pre-engineered and sized mounting bracket for applications requiring a unit mounted fused and non-fused disconnect of greater than 100 amps. Bracket assures that no damage will occur to coils when mounting with screws and other fasteners.
26. Hinged Access Panels:
- d. Shall provide easy access through integrated quarter turn latches.
  - d. Shall be on major panels of: filter, control box, fan motor, and compressor.
27. Condensate Overflow Switch:
- e. This sensor and related controller monitors the condensate level in the drain pan and shuts down compression operation when overflow conditions occur. It includes:
    - 1) Indicator light — solid red (more than 10 seconds on water contact — compressors disabled), blinking red (sensor disconnected).
    - 2) 10 second delay to break — eliminates nuisance trips from splashing or waves in pan (sensor needs 10 seconds of constant water contact before tripping).
    - 3) Disables the compressors operation when condensate plug is detected, but still allows fans to run for economizer.
28. 4 in. MERV-13 Return Air Filters:
- a. Factory option to upgrade standard unit filters to 4 in. MERV-13 filters. Filter media is securely fastened inside the filter frame on all 4 sides.
29. 4 in. Filter Rack Kit:
- b. The 4 in. filter rack accessory kit is designed to hold 4 in. MERV-8 or MERV-13 filters. Filters not included in kit.
30. 2 in. MERV-13 Return Air Filters:
- c. Accessory kit to field upgrade standard unit filters to 2 in. MERV-13 filters.
31. 2 in. MERV-8 Return Air Filters:
- d. Accessory kit to field upgrade standard unit filters to 2 in. MERV-8 filters.

## Guide Specification for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

### 32. Phase Monitor Control:

- e. Shall monitor the sequence of 3-phase electrical system to provide a phase reversal protection.
- b. Shall monitor the 3-phase voltage inputs to provide a phase loss protection for the 3-phase device.
- c. Will work on either a Delta or Wye power connection.

### 33. Horn/Strobe Annunciator:

- f. Provides an audible/visual signaling device for use with factory-installed option or field installed accessory smoke detectors.
  - 1) Requires installation of a field-supplied 24-v transformer suitable for 4.2 VA (AC) or 3.0 VA (DC) per horn/strobe accessory.
  - 2) Requires field-supplied electrical box, North American 1-gang box, 2 in. (51 mm) x 4 in. (102 mm).
  - 3) Shall have a clear colored lens.

### 34. UV-C Ultraviolet Lamp Kit:

- a. High-output, low temperature ultraviolet lamp accessory. It includes:
  - 1) 36 in. lamp, interlock switch, mounting brackets, necessary wires, wire ties, screws and labels to field install kit in unit return air plenum.
  - 3) Separate dedicated 115-v power source required.
  - 4) UV-C kit can not be used on units with Humidi-MiZer® system.

### 35. High Short Circuit Current Rating (SCCR) Protection:

- a. Factory-installed option provides high short circuit current protection to each compressor, plus all indoor and outdoor fan motors of 10 kA against high potential fault current situations. (Standard unit comes with 5 kA rating.)
- b. This option is not available with factory installed Non-Fused Disconnect, Humidi-MiZer system, Low Ambient controls, Phase loss monitor/protection and 575-v models.

## Unit Feature Sheet for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM

**There is no Certified Drawing available for this tag**

## Spec Sheet for 48FCEM09A3A5-8B0AN

Project: Kerr Stock Equipment  
Prepared By: Kerr Applied

10/06/2026  
04:14PM