

Block Parameters: PID Controller
PID 1dof (mask) (link)
This block implements continuous- and discrete-time PID control algorithms and includes advanced features such as anti-windup, external reset, and signal tracking. You can tune the PID gains automatically using the 'Tune...' button (requires Simulink Control Design).
Controller: PID
Form: Parallel
Time domain:
Continuous-time
Discrete-time
Discrete-time settings
Sample time (-1 for inherited): -1
Compensator formula
$P + I\frac{1}{s} + D\frac{N}{1 + N\frac{1}{s}}$
Main
Initialization
Saturation
Data Types
State Attributes
Controller parameters
Source: internal
Proportional (P): 13.4031830807766
Integral (I): 1435.28842906173
Use I*Ts (optimal for codegen)
Derivative (D): 0.0109901224496183
Filter coefficient (N): 454.522544204323
Use filtered derivative
Automated tuning
OK
Cancel
Help
Apply