CITY OF TSHWANE	**Department: Economic Development and Spatial Planning** **Section: Building Plans Management**	DOC NO	EDSP/BPM/OP 7.5.1/1/9
		ISSUE DATE	14/01/2014
		REV DATE	30/05/2024
		REV NO	5

BUILDING PLAN CHECK LIST

PLAN NUMBER	**PL615/R1/R936/25**	BUILDING SURVEYOR	JOHANNES R. MOKOKE
PROPERTY DESCRIPTION	**591 SOSH - EAST**	DATES & AREA	02/10/25- 20/10/2025 **61m2**

GENERAL					
Municipal Application Form			SANS 10400 A, Form 1, Completed by Competent Person.		
Additional Fees / Building line Relaxation- **R1100.00**			SANS 10400 A, Form 2, Completed by Competent Person/s. Engineer	X	
Title Block Description Incomplete/Incorrect –			Show Scales on Building Plans - Correctly & Drawn to Scale		
New/Existing Areas & Coverage (%) Indicated on Building Plans			Second Dwelling Consent		
Building Plans Signed & Dated by Owner, Author	X		Provide Drainage Connection Slip		
Copy of Title Deed/SG Diagram/Zoning/Annexure T			Provide Copy of Recent - Municipal Service Account		
Approval Letter from Body Corporate/Duet/s/Sectional Tittle			Provide Approved Building Plan - Lapa/Pool/Structure/Out-Building	X	
Power of Attorney			Subdivision/Consolidation		
One Copy of Building Plans Coloured- New work			Home Undertaking (Max 60 m²)		
Title Deed Restriction			Habitable Outbuilding (max 20% and 50m²)		
Calculation of Theoretical Annual Energy Consumption	X		Total Outbuildings (max 50%)		
Proof of Registration with; SACAP, ECSA or SACNSP.			Permission (Second Kitchen/Coverage/Height/Building Line)		
SITE PLAN					
Indicate Street Name and Number, Vehicle Entrance (No Obstruction)			Show Building Lines/Servitudes (Scheme/Annexure T/Title Deed)	X	
Show North Point/Erf No/Adjacent Erf Numbers			Show Planning Schedule (Scheme/Annexure T)		
Show Distance to Boundaries / Between Buildings(1m min)			Show and Describe New & Existing Buildings		
Indicate New and Existing Drainage			Show Position and Depth of Municipal Drainage Connection		
Dimension / Position of Septic Tank / French Drain			Show Municipal Sewer Line		
Indicate all Boundary Dimensions as per SG Diagram			Indicate Position of Water Meter	X	
FLOOR PLANS					
Dimension and Specify Use of all Rooms			Show Hot and Cold Water Layout and Calculations		
Show Section Lines			Size of Habitable Room (min 6m² /2m)		
Chimney as per Part "V" of NBR (Describe on Building Plan)			Fire Walls / Fire Doors / Fire Safety Distance (min 1m)		
Facilities for Disabled Persons (Toilet / Parking / Ramp)			Indicate Buildings / Drainage not to Encroach Servitude		
Drywalls to Comply with SANS 10082 / Wood SANS 0163			Ventilation (5%) and Lighting (10%) in Habitable Rooms		
SECTIONS & DETAILS					
Show Sections as Marked on Building Plan			Foundations / Roof not to Encroach Boundary (detail)		
Show Ceiling Heights as per NBR Part 'C', Table 2			Foundations / Internal Foundations / Floor Thickening Sizes		
Pool Safety (SABS 1390) Self-Closing & -Locking Gate			Min. Stair Headroom 2.1m / Stair Width / Size of Landing		
Pitch / Waterproofing under 26° / Roofing Material			Truss Sizes (n/an if by Engineer) Grade / Spacing / Span		
Boundary / Screen Wall Details & Dimensions / Eng Cert			Show DPC / Vertical DPC / 75mm Bedding		
Safety Glass at Stairs (Window below 1.8m)			Balustrades / Hand Rails 1m High, 100mm Spacing / Risers & Treads		
ELEVATIONS					
Provide relevant/correct elevations			Glazing as per Detail requirements of SANS 10400 Part N.		
Specify all finishes on elevations. Show natural ground levels.			Boundary Wall to be maintenance free on neighbor's side.		
Window and Door Schedule			Markings on transparent glazing		
DRAINAGE PLANS					
Show Sanitary Fixtures and Sanitary Schedule.			Describe Vent Pipes/Vent Valves and Sizes on Layout Plan		
Show R.E's, I.E's, A.E's & Access Panel			Indicate Drainage Invert Level (min. 450mm) on Layout Plan		
Provide one Gulley per System at lowest point			Show gradient of Drainage on Layout Plan		
Show Drainage Pipes/Wastepipes and sizes- Color	X		Type of Drainage material to be used/distance from building		
Provide RE/CE at max 25m distances			Protect/provide access to drains under building / 914 detail		
Provide RE/CE at 1500mm from Mum Sewer Connection			Septic Tank/French Drain min 5m from any building		
Provide Covered Refuse Area (Water Inlet/Grease Trap)			Septic Tank and French Drain, Min. 45m from any Water Source or Property Boundary.		
Describe Hot Water Heating System.	X		Drainage to Comply with SANS 10400 Part P/Q		
CIRCULATE TO DEPARTMENTS					
Regional Spatial Planning / LUMA			Water and Sanitation	X	
Fire Department	X		Waste Management		
Traffic Engineering			Environmental Planning & Open Space Management		
Roads & Stormwater	X		Legal Services	X	
Municipal Health			Geology		
OTHER COMMENTS					
* All corrections on Building Plans to be done with black ink, on all copies: initial & date all corrections.					
* No correction fluid used on Building Plans			* All corrections on Building Plans to be done by Author only		

*** COMPLETE ALL DOCUMENTS IN FULL.**

*** Provide Comments from another Party: ERF 590**