Membrane Cycle Tolerance Is the Binding Constraint on Renewable Desalination in the Gulf

UN-aligned impact and policy brief

Muhammet Yalkapov, Sulaymon Sadullo, Rama Abdallah, Khadeja Al Khazraji
Abu Dhabi University · Team HYDRA · Registration CMAT-00107
Khalifa University – UN Global Water Hackathon 2026
Theme 1: Water Security and Sustainable Desalination

The headline

Decarbonising desalination is usually framed as a question of solar cost and storage cost. Our analysis finds that in the Arabian Gulf it is neither. **The binding constraint on how much renewable energy a seawater desalination plant can absorb is how many times its membranes can be started and stopped.** That quantity has, as far as we could establish, never been measured for warm hypersaline seawater.

Alignment with UN Water pillars and SDG 6

- **Water for People.** The UAE draws over 90% of its drinking water from desalination. Anything that raises the cost or lowers the reliability of that supply is a direct risk to SDG 6.1.
- **Water for Prosperity.** Desalination consumes roughly 15% of UAE electricity. How that load is scheduled determines whether it supports or obstructs the national renewable transition.
- **Water for Planet.** Desalination accounts for more than 22% of UAE energy-related CO_2. Our results quantify the carbon price at which abatement through co-located solar actually pays.
- **Investments for Water.** We identify a low-cost research investment that would de-risk a much larger class of capital decisions.

What we did

We built an hourly simulation of a Gulf seawater reverse-osmosis train that couples three things normally modelled in isolation: renewable dispatch, energy consumption as a function of feed salinity and temperature, and membrane biofouling including its irreversible component. It runs on measured NASA POWER irradiance, temperature and aerosol data for the Abu Dhabi coast (annual GHI 2009 kW h/m^2, mean aerosol optical depth 0.545), and is benchmarked against a published energy-use projection for a full-scale Gulf plant.

Four findings that matter for policy

1. Load-following desalination destroys value in Gulf conditions

The renewable-integration literature treats flexible desalination as a way to absorb solar power and cut costs; one demand-response study reports savings of over 20% for an RO plant. Those models treat the plant as a simple power-to-water converter and omit the membrane — although experiments show that intermittent operation accelerates fouling, and a seawater membrane under solar-emulated variable operation lost 37% of its permeability in three days without rinsing. When membrane degradation is

priced into the same dispatch decision, the result reverses: flexible operation raises renewable fraction from 39.5% to 52.3% but raises the levelized cost of water by 45%, from 0.992 USD/m^3 to 1.434 USD/m^3, because membrane life falls from 2.06 yr to 0.53 yr.

Implication. The steady-output-plus-solar configuration Gulf operators have adopted is economically rational, not conservative. Policy should not assume that flexible desalination is available capacity for balancing the grid.

2. The constraint is a measurable membrane property

We express the result through a single parameter, the *cycle tolerance* N_{tol}: how many start/stop cycles a membrane survives before replacement. Flexible operation becomes economic only above $N^*_{\mathrm{tol}} \approx 4201$ cycles — 11.7 yr of daily cycling, which is more than twice the 2 yr to 5 yr after which operating plants replace their membranes. Across the entire plausible range the degradation-aware optimiser declines to flex at all.

Implication. This is a materials problem with an economic consequence, and it is cheap to resolve experimentally.

3. Time-of-use tariffs would make things worse, not better

A natural policy instrument for unlocking flexible load is a time-of-use tariff. On our results this backfires. At realistic cycle tolerance, widening the tariff spread from flat to a factor of 1.00 increases the cost penalty of flexing rather than reducing it, because the price signal draws operators into cycling their membranes cannot support.

Implication. Introducing strong time-of-use pricing for desalination before membrane cycle tolerance is established would incentivise value-destroying behaviour. Sequence matters.

4. Solar on desalination is mandate-driven, and we can price it

At UAE grid electricity prices, no photovoltaic capacity is optimal on levelized cost alone. Existing deployments are therefore driven by policy, not economics — which means the size of the policy signal determines the outcome. Table 1 gives the schedule.

Table 1: Implicit carbon price required to justify co-located PV on a steady-output Gulf SWRO plant.

PV capacity (MW_p)	**Renewable share** (%)	**Cost of water** (USD/m^3)	**Break-even carbon price** (USD/t CO_2)
0.0	0.0	0.732	—
10.5	30.2	0.750	38
21.0	39.8	0.783	84
35.0	43.4	0.835	155

Renewable share saturates at 43.4% even when solar capacity is doubled to full energy parity, because a steady-output plant can only absorb sunlight during daylight. Each additional panel displaces less grid energy than the last, which is why the break-even carbon price rises so steeply. These prices use a grid emission factor of 0.40 kg CO_2/kWh, between the UAE's 2019 baseline of 0.55 and its 2030 target of 0.27 (Climate Action Tracker); across that range the first increment breaks even at 28–57 USD/t, and the price rises as the grid decarbonises.

Implication. A mandate expressed as a renewable *percentage* above roughly 39.8% procures emissions reductions at rapidly escalating cost unless the absorption limit is addressed first.

Recommendations

1. **Fund a membrane cycling-tolerance testing programme.** A bench campaign of a few hundred start/stop cycles on Gulf feedwater would measure N_{tol} directly. This is the single highest-leverage public investment identified by this study: it is inexpensive relative to the capital decisions it would inform, and it determines whether a substantial body of international demand-response research applies to the region at all.

2. **Do not count desalination as dispatchable demand** in grid planning until that measurement exists. Treating it as flexible capacity overstates system balancing resources.

3. **Sequence tariff reform after the measurement, not before.** Time-of-use signals are the right long-run instrument but are counterproductive at present membrane capability.

4. **Express decarbonisation mandates as carbon price or absolute emissions, not renewable percentage.** Percentage targets above roughly 39.8% hit the absorption limit and become expensive per tonne abated.

5. **Direct desalination R&D toward cycling-tolerant membranes and restart protocols.** The avoidable membrane cost we identify ($0.452\,\mathrm{USD/m^3}$) is an order of magnitude larger than the accessible energy saving ($0.021\,\mathrm{USD/m^3}$).

Confidence and limitations

This is a modelling study benchmarked against published plant values, not calibrated to plant operating records. Of 52 model parameters, 34 (65%) are assumptions of this study; conclusions are therefore reported as functions of those assumptions rather than as point predictions. The decisive parameter, per-cycle irreversible permeability loss in warm hypersaline seawater, is unmeasured — which is precisely Recommendation 1. We have deliberately framed the central claim so that a single bench experiment could refute it.

Full method and results: accompanying technical report; code available on request. Contact: Muhammet Yalkapov (team leader), 1095390@students.adu.ac.ae. Faculty advisor and mentor: Dr. Murad Al-Rajab, Abu Dhabi University.