

トランスデューサ試験成績表

TRANSDUCER INSPECTION CERTIFICATE

No. RHT1-45-17

得意先 CUSTOMER		殿			
品名 DESCRIPTION		RESISTANCE THERMOMETER		トランスデューサ TRANSDUCER	
形名 TYPE	FSRH-1E1FX521	試験日 DATE	May. 7, 2024	室温 TEMP	23℃
入力 INPUT	-50~+50℃	第1出力 OUTPUT 1	DC 4~20mA	負荷抵抗値 LOAD 1	0~750Ω
		第2出力 OUTPUT 2		負荷抵抗値 LOAD 2	
		補助電源電圧 AUXILIARY SUPPLY		DC24V	
Pt100Ωat0℃ EXTERNAL RESISTANCE 0~50Ω		変換精度 ACCURACY		±0.3%	
製造番号 SERIAL		TAG No.			
校正試験 CALIBRATION					
入力値 INPUT VALUE	第1出力 OUTPUT 1			第2出力 OUTPUT 2	
	試験負荷抵抗値 TEST LOAD			試験負荷抵抗値 TEST LOAD	
	標準出力値 OUTPUT STANDARD	測定値 MEASURED VALUE		標準出力値 OUTPUT STANDARD	測定値 MEASURED VALUE
℃ (Ω)	DC	mA	DC	mA	
50.0 (119.40)		20.00		19.99	
25.0 (109.73)		16.00		15.99	
0.0 (100.00)		12.00		12.00	
-25.0 (90.19)		8.00		8.00	
-50.0 (80.31)		4.00		4.00	
合格 PASS					
外観・構造試験 APPEARANCE & CONSTRUCTION TEST			良 GOOD	表示事項試験 MARKING ITEMS TEST	
試験部 TEST PARTS	電気回路一括と 外箱間 Between all electric circuits and outer case	入力端子と 出力端子間 Between input terminals and output terminals	補助電源端子と入力 ・出力端子間 Between auxiliary power circuits and input- output terminals	試験結果 RESULT	
試験項目 TEST ITEMS					
絶縁抵抗 INSULATION RESISTANCE	Over 50MΩ at DC500V	Over 50MΩ at DC500V	Over 50MΩ at DC500V	良 GOOD	
耐電圧 WITHSTAND VOLTAGE	120% of AC2000V, 1second (guarantee AC2000V, 1minute)	120% of AC2000V, 1second (guarantee AC2000V, 1minute)	120% of AC2000V, 1second (guarantee AC2000V, 1minute)	良 GOOD	
備考 REMARKS	EXTERNAL RESISTANCE 25Ω AT CALIBRATION		承認者 APPROVED BY	検査者 INSPECTOR	



様式 08-439a