

CC-Link Setting

[CC-Link Setting]

	1	2	3	4
Start I/O No.	0000	-	-	-
Type	Master Station	-	-	-
Master Station Data Link Type	PLC Parameter Auto Start	-	-	-
Mode	Remote Net(Ver.1 Mode)	-	-	-
Total Module Connected	3	-	-	-
Remote input(RX)	M1008	-	-	-
Remote output(RY)	M1200	-	-	-
Remote register(RW _r)	D500	-	-	-
Remote register(RW _w)	D520	-	-	-
Ver.2 Remote input(RX)	-	-	-	-
Ver.2 Remote output(RY)	-	-	-	-
Ver.2 Remote register(RW _r)	-	-	-	-
Ver.2 Remote register(RW _w)	-	-	-	-
Special relay(SB)	SB0	-	-	-
Special register(SW)	SW0	-	-	-
Retry Count	3	-	-	-
Automatic Reconnection Station Count	1	-	-	-
Standby Master Station No.	-	-	-	-
PLC Down Select	Stop	-	-	-
Scan Mode Setting	Asynchronous	-	-	-
Delay Time Setting	0	-	-	-
Remote Device Station Initial Setting	No setting	-	-	-
Interrupt Settings	No setting	-	-	-