

**SYDNEY WATER
BUILDING PLAN APPROVED
SUBJECT TO REQUIREMENTS**

Sydney Water Tap in™ 1650950

Property Number 3691566

Dolphin No. If Applicable: N/A

Quick Check Ref: N/A

e-Developer Case No: 202987 (S73)

Ausflow Project: 7050

Property Location

Street No: 83a

Lot No: 17

Street Name: Brixton Road

Suburb: Berala

Building/Structure Description: Proposed residential dwelling

Building Plan No: RJK Architects Dwg No. CC02 & CC04, issue B (25/4/23)

Engineer Plan No: Cordor Pty Limited Project No. 2021 08, Dwg No. 2 (3/2/2023)

Proposed building/structure is **APPROVED** to construct **Over/Adjacent** to a Sydney Water sewer/asset, subject to the following requirements:

1. **The foundations/piers are to be founded below the zone of influences.**
2. **No part of the building/structure or its foundations to be less than a minimum 1.1 metre, horizontal distance from the outside edge of the asset (where pipe is being encased).**
3. ~~No part of the swimming pool or its foundations to be less than a minimum ... metre, horizontal distance from the outside edge of the asset to the outer edge of the pool.~~
4. **No part of the above-ground building/structure to be less than 1m horizontal distance from outside edge of any Sydney Water structure.**
5. **No part of the below ground foundations to be less than 0.9m horizontal distance from outside edge of any Sydney Water Structure. (1.6m for pier solutions from centre of manhole)**
6. ~~No part of any swimming pool (excluding coping) is to be less than 2m horizontal distance from outside edge of any Sydney Water structure (MANHOLE).~~
7. **Foundations/piers are constructed in accordance with Engineers detail plans (stated above) as submitted to Sydney Water.**
8. **All foundations/piers are to be founded to below the zone of influence or to solid rock.**
9. ~~Indemnity letter to be signed by owner/s of property and returned to Water Servicing Coordinator prior to issue of building plan approval.~~
10. **Concrete encase approximately 11 metres of asset.
Concrete encasement to be carried out by an Accredited Constructor of Minor Works (Sewer) / Constructor and a Minor Works Agreement signed prior to commencement of works.**
11. **Concrete encasement must extend a minimum of 1m past the external walls of the proposed structure.**
12. **Minimum of 450mm vertical clearance between top of concrete encasement to underside of proposed structure.**
13. ~~Property connection point (junction) to be inserted under Minor Works Agreement.~~
14. **All works are to be completed in accordance with Case 202987 (S73)**

SPECIAL REQUIREMENTS

(1) Requirement of this approval is a Concrete Encasement Inspection. Inspection to be carried out by Ausflow Pty Ltd.

(2) Requirement of this approval is a Pier inspection. Inspection to be carried out by Ausflow Pty Ltd.

(3) Sydney Water require, safe and external 24-hour access to manhole structure to manage incidents without delay. Hildebrandt Abloy Lock system to be installed on any gates where required.

Working space of at least 1 m around the rim of the cover with minimum headroom of 2.4 m above. No allowance to build over or to cover manhole lid inclusive of pavers, decks or removable flooring.

Please ensure **48hrs (2 working days) notice** is given to ensure our field team can attend your site at the time you require. (PLEASE NOTE: Failure to supply sufficient notice may result in project delays OR additional cost to facilitate an inspection time).

NOTE:

Above requirements must be inspected/supervised by a WSC to enable the issue of a satisfactory compliance letter.


Contact Inspector: (02) 9555 7979 – Ausflow Pty Ltd. 48 Hours notice required prior to commencement of works.

APPROVED BY:

WSC Company Name: **Ausflow Pty Ltd**

Name of Key Personnel: **Marcia Faundez**

Signature of Key Personnel:



Date: 18/05/2023

GENERAL NOTE:

The swimming pool including overflow water must be drained to the sewer. No further consent is required on this part. Permits are required to fill all renovated or new swimming pools and spas with a capacity greater than 10,000 litres. To arrange for a permit please contact Sydney Water on 13 20 92 during business hours. Fines do apply for filling swimming pools/spas without a permit greater than the above mentioned capacity. For more information please visit sydneywater.com.au