

Water requirement for KIADB Industrial Areas

Sl. no	District / Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD			Remarks
				Total	Fresh Water	Treated Water	
A. Bengaluru Rural District							
1	Nelamangala Taluk						
		Existing Industrial Areas					
		Dabaspete 1st and 2nd Phase	339	2	0.5	1.5	
		Dabaspete 3rd Phase (Sompura1st & 2nd)	1321	7	3.5	3.5	
		Dabspete 4th Phase	973	5	2.5	2.5	
		Dabspete 5th Phase	1040	5	2.5	2.5	
		Oblapura & MMLP	842	4	2	2	
		Proposed Industrial Areas					
		KHIR	2200	10	6	4	
		Sompura 28(4)	520	3	1.5	1.5	
		Hanumanthapura, Bidluru, Kodipalya 28(1)	495	3	1.5	1.5	
2	Doddaballapura Taluk						
		DB pura General Industrial Area	352	3	1.5	1.5	
		Appearl Park 1st and 2nd phase	453	8	6	2	
		Obedenahalli	697	5	3	2	
		Adinarayana Hosahalli 1st Phase	195	2	1	1	
		Adinarayana Hosahalli 2nd Phase	981	12	7	5	

Sl. no	District / Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD			Remarks
				Total	Fresh Water	Treated Water	
3	Devanahalli Taluk						
		Existing Industrial Areas					
		Hitech Defence & Aerospace Park 1st phase	3009	30	20	10	
		Hitech Defence & Aerospace Park 2nd phase	1200	13	8	5	
		Devanahalli General IA 1st phase	986	15	10	5	
		Proposed Industrial Areas					
		Hitech Defence & Aerospace Park 3rd phase	1770	15	10	5	
		Devanahalli General IA 2nd phase	1200	15	10	5	
4	Hoskote Taluk	Hoskote	402.15	15	8	7	
		Hoskote (Proposed)	1000				
	Kolar District						
		Existing Industrial Areas					
5	Malur Taluk	Malur 1st, 2nd, 3rd and 4th Phase	917	10	5	5	
		Bhavanahalli	722.05	10	5	5	
		Jakkasandra	627.45	6	3	3	
		Jakkasandra II Phase (Mindahalli)	335.41	3	1	2	
		Malur (Proposed)	1614.16	12	5	7	

Sl. no	District / Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD			Remarks
				Total	Fresh Water	Treated Water	
6	Kolar Taluk						
		Narasapura-Kolar	700.75	12	5	7	
		Vemagal	666.41	5	2	3	
		Vemagal II Phase	457.91	5	2	3	
		CHIKKABALLAPUR District					
7	Gowribidanur Taluk	Gowribidanur Ist, 2nd, 3rd	1495	20	10	10	
		Gowribidanur (Proposed)	1500				
8	Srinvasapura Taluk	Mastenahalli 1st & 2nd Phase	932	10	5	5	
		Mastenahalli (Proposed)	600				
		Srinivasapura Taluk (Proposed)	1273	10	5	5	
		Proposed Industrial Areas					
9	Bagepalli Taluk	Bagepalli	1000	10	5	5	
10	Chintamani Taluk	Chintamani	500	5	2	3	
11	Shidlagatta Taluk	Chikkaballapura Shidlagatta	2500	20	10	10	
		Total	35816.29	310.00	169.50	140.50	

Sl.no	District	Extent in Acres	Total Water Requirement in MLD		
			Total	Fresh Water	Treated Water
1	Bengaluru Rural District	19975.15	172	104.5	67.5
2	Chikkaballapura	9800	75	37	38
3	Kolar	6041.14	63	28	35
	Total	35816.29	310	169.5	140.5

Sl. no	District / Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD			Remarks
				Total	Fresh Water	Treated Water	

B. TUMAKURU

1	Tumakuru Taluk	Vasanthanarasapura Industrial Area 1st Phase	513.21	3.85	3.85	0.00	
		Vasanthanarasapura Industrial Area 2nd Phase	650.43	4.88	4.88	0.00	
		Vasanthanarasapura Industrial Area 2nd Phase (Sub Layout)	76.19	0.57	0.57	0.00	
		Vasanthanarasapura Industrial Area 3rd Phase	352.25	2.64	2.64	0.00	
		Tumakuru Machine Tool Park (TMTP)	338.19	2.54	2.54	0.00	
		Japanese Industrial Park	320.73	2.41	2.41	0.00	
		Vasanthanarasapura Industrial Area 3rd Phase (Sub Layout)	74.74	0.56	0.56	0.00	
		Vasanthanarasapura Industrial Area 1st Phase (Annexe)	36.44	0.27	0.27	0.00	
		Antharasanahalli Industrial Area, 1st Phase	184.99	1.39	1.39	0.00	
		Antharasanahalli Industrial Area, 2nd Phase	206.77	1.55	1.55	0.00	
		Sathyamangala Industrial Area	47.26	0.35	0.35	0.00	
		Hirehalli Industrial Area	137.34	1.03	1.03	0.00	
2	Sira Taluk	Sira Industrial Area	366.04	2.75	2.75	0.00	
3	Kunigal Taluk	Kunigal Industrial Area, 1st Phase	96.17	0.72	0.72	0.00	
		Kunigal Industrial Area, 2nd Phase	51.13	0.38	0.38	0.00	
			3451.88	25.89	25.89	0.00	

Sl. no	District / Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD			Remarks
				Total	Fresh Water	Treated Water	
	Chitradurga District						
1	Chitradurga Taluk	Kelagote Industrial Area	75.14	5.64	5.64	0.00	
2	Challakere Taluk	Ullarthikaval Industrial Area	62.59	4.69	4.69	0.00	
3	Hiriyur Taluk	Metikurkke Industrial Area	764.63	57.35	57.35	0.00	Formation of layout is under progress
			902.36	67.68	67.68	0.00	

Sl.no	District	Extent in Acres	Total Water Requirement in MLD		
			Total	Fresh Water	Treated Water
1	Tumakuru	3451.88	25.89	25.89	0.00
2	Chitradurga	902.36	67.68	67.68	0.00
	Total	4354.24	93.57	93.57	0.00

C. DAVANAGERE

1	Davanagere/ Davanagere	Davanagere I.A.	94.50	0.22	...	0.22	
2	Davanagere/ Davanagere	Karur	102.76	0.22	...	0.22	
3	Davanagere/Harihara	Haralapura 1 st Phase	56.97	0.10	...	0.10	
4	Davanagere/Harihara	Hanagawadi 1 st Phase	50.00	0.10	...	0.10	
5	Davanagere/Harihara	Kurubarahalli-Sarathi 1 st Stage	290.35	1.00	...	1.00	
6	Davanagere/Harihara	Kurubarahalli-Sarathi 2 nd Stage	336.05	1.00	...	1.00	
Total:			930.63	2.64		2.64	

Sl. no	District / Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD			Remarks
				Total	Fresh Water	Treated Water	
1	Shivamogga/Bhadravathi	Machenahalli	381.00	4.50	...	4.50	
2	Shivamogga/Shivamogga	Nidige Industrial Area	57.00				
3	Shivamogga/Shivamogga	Mandli Kallur	42.13	0.10	...	0.10	
4	Shivamogga/Shivamogga	Auto Complex	19.35	0.05	...	0.05	
5	Shivamogga/Shikaripura	Sanda, (Shikaripura)	208.00	0.22	...	0.22	
6	Shivamogga/Sagara	Mangalabeesu	10.35	0.05	...	0.05	
7	Shivamogga/Shivamogga	Devakatikoppa	464.24	4.50	...	4.50	
Total:			1182.07	9.42		9.42	

Sl.no	District	Extent in Acres	Total Water Requirement in MLD		
			Total	Fresh Water	Treated Water
1	Davanagere	930.63	2.64	...	2.64
2	Shivamogga	1182.07	9.42	...	9.42
Total:		2112.7	12.06	...	12.06

D. MYSORE

1	Mysuru / Mysuru	Hebbal	1603.00		2512.16		
2	Mysuru / Mysuru	Hebbal Weavers colony			36.58		
3	Mysuru / Mysuru	Hebbal Housing Area			121.65		
4	Mysuru / Mysuru	Hootagally	426.00		931.45		
5	Mysuru / Mysuru	Belavadi	238.00		35.19		
6	Mysuru / Mysuru	Koorgally	472.00		496.51		
7	Mysuru /Nanjangud	Nanjangud	535.00		1856.60		
8	Mysuru /Nanjangud	Thandya	144.00		1983.10		
9	Mysuru /Mysuru	Kadakola	255.65		778.52		

Sl. no	District / Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD			Remarks
				Total	Fresh Water	Treated Water	
10	Mysuru /Nanjangud	Adakanahalli	538.22		1101.32		
11	Mysuru /Nanjangud	Immavu	500.00		945.97		
12	Mysuru /Nanjangud	Women's En. Park -1	48.03		27.13		
13	Mysuru /Nanjangud	Women's En. Park -2	68.64		59.23		
14	Mysuru /Nanjangud	Thandya 2nd Phase	626.70		140.29		
15	Mandya/ Mandya	Tubinakere	141.00		32.58		
16	Mandya/ Maddur	Somanahally	154.00		111.77		
17	Mandya/ Maddur	Gejjalagere	78.30		159.23		
18	Mandya/ Srirangapatna	Hebbal 2nd Phase	193.46		84.97		
19	Kodagu/ Kushalnagara	Kushalnagar	250.00		218.67		
20	Chamarajanagara/ Chamarajanagara	Badanguppe - Kellamballi	1460.47		377.96		
Total:			7732.47	0.00	12010.87	0.00	

Water requirement for KIADB Industrial Areas

	Zone: Mysuru						
Sl. no	District / Taluk	Exisitng Industrial Area	Total Extent in Acres				
				Allocated in MLD	Source		Existing
					Surface	Ground	
			Existing				
1	Mysuru / Mysuru	Hebbal	1603.00	22.5	Cauvery		2.51
2	Mandya/ Srirangapatna	Hebbal 2nd Phase	193.46				0.08
3	Mysuru / Mysuru	Hebbal Weavers colony					0.04
4	Mysuru / Mysuru	Hebbal Housing Area					0.12
5	Mysuru / Mysuru	Hootagally	426.00				0.93
6	Mysuru / Mysuru	Belavadi	238.00				0.04
7	Mysuru / Mysuru	Koorgally	472.00				0.50
8	Mandya/ Mandya	Tubinakere	141.00				0.03
9	Mysuru /Nanjangud	Nanjangud	535.00	22.5	Kabini		1.86
10	Mysuru /Nanjangud	Thandya	144.00				1.98
11	Mysuru /Mysuru	Kadakola	255.65				0.78
12	Mysuru /Nanjangud	Adakanahalli	538.22				1.10
13	Mysuru /Nanjangud	Immavu	500.00				0.95

14	Mysuru /Nanjangud	Women's En. Park -1	48.03				0.03
15	Mysuru /Nanjangud	Women's En. Park -2	68.64				0.06
16	Mysuru /Nanjangud	Thandya 2nd Phase	626.70				0.14
17	Chamarajanagara/ Chamarajanagara	Badanguppe - Kellamballi Phase-1	1460.47				0.38
19		Badanguppe - Kellamballi Phase-2					-
20	Mandya/ Maddur	Somanahally	154.00			Borewell	0.11
	Mandya/ Maddur	Gejjalagere	78.30			Borewell	0.16
	Kodagu/Kushalnagara	Kushalnagar	250.00			Borewell	0.22
	Total		7732.47				12.01

Kabini- 22.5 MLD			
Cauvery - 22.5 MLD			
Fresh Water in MLD	Treated Water		Remarks
	Existing		
	-		Source Cauvery with an allocation of 22.5 MLD
	-		
	-		
	-		
	-		
	-		
	-		
	-		
	-		Source -
	-		
	-		
	-		
	-		

	-		Kabini with an allocation of 22.5 MLD
	-		
	-		
	-		
	-		Borewell
	-		
	-		
	0.00		

Water requirement of Industrial Areas Coming under the Jurisdictions of Executive Engineer-2, KIADB Zonal Office, Bangalore

Sl. no	District / Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD			Remarks
				Total	Fresh Water	Treated Water	
1	2	3	4	5	6	7	8
1	Bengaluru Rural	Hoskote	413.37	1.50	1.50	-	
2	Bengaluru Urban	Attibele	250.45	1.00	1.00	-	
3		Bommasandra 1st, 2nd & 3rd Phase	903.52	2.75	2.75	-	
4		Bommasandra 4th Phase	214.36	1.00	1.00	-	
5		Bommasandra Jigani Link Road	712.00	2.50	2.50	-	
6		Doddanekundi	364.00	1.20	1.20	-	
7		Electronic City Phase-II	307.00	1.00	1.00	-	
8		Electronic City Phase-III	114.07	0.50	0.50	-	
9		EOIZ	14.00	0.01	0.01	-	
10		EPIP	554.20	1.75	1.75	-	
11		Jigani I & II Phase	648.00	2.25	2.25	-	
12		Kadugodi	76.80	0.30	0.30	-	
13		Sadaramangala	100.00	0.30	0.30	-	
14		Veerasandra	107.27	0.40	0.40	-	
15		Yarandahalli	27.00	0.10	0.10	-	
16		Kachanayakanahalli Sub Layout	34.86	0.10	0.10	-	
17		Dyavasandra	161.00	0.50	0.50	-	
18	Kolar	Vemgal 1st Phase	666.41	2.25	1.75	0.50	
19		Vemgal 2nd Phase	457.91	1.50	1.00	0.50	
20		Narasapura	700.75	2.50	2.00	0.50	
21		Jakkasandra	627.47	2.10	1.70	0.40	
22		Malur 4 th Phase	412.00	1.50	1.00	0.50	
23		Jakkasandra 2nd phase (Mindahalli Village)	335.41	1.15	0.85	0.30	
24		Bhavanahalli	722.05	2.50	2.00	0.50	
25		Malur 1st & 2nd Phase	210	0.75	0.50	0.25	
26		Malur 3rd Phase	295	1.00	0.60	0.40	
27		Tamaka	117.01	0.40	0.20	0.20	

Sl. no	District / Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD			Remarks
				Total	Fresh Water	Treated Water	
1	2	3	4	5	6	7	8
28		Bangarpete	88.00	0.30	0.15	0.15	

Sl. no	District / Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD			Remarks
				Total	Fresh Water	Treated Water	
1	2	3	4	5	6	7	8
29	Chikkaballapura	Chikkaballapura	96.00	0.30	-	-	
30		Gowribidanur 1st Phase	239.38	0.75	-	-	
31		Gowribidanur 2nd Phase	453.13	1.50	-	-	
32		Gowribidanur 3rd Phase	824.07	0.00	-	-	
33		Masthenahalli 1st Phase	516.96	1.75	1.00	0.75	
34		Masthenahalli 2nd Phase	414.65	1.50	0.75	0.75	

Total Requirement of Water in KIADB Industrial Areas.

Zone: Mangalore

1	Dakshina Kannada / Mangaluru	Karnad		65.85	0.00	65.85	0.08	0.08	0.00				
2	Dakshina Kannada / Mangaluru	E.P.I.P.		205.16	0.00	205.16	0.35	0.35	0.00				
3	Dakshina Kannada / Ullal	IT-SEZ & Non- SEZ		146.125	0.00	146.13	0.26	0.26	0.00				
4	Udupi / Kapu	Nandikur		86.64	0.00	86.64	0.11	0.11	0.00				
5	Udupi / Kapu	Belapu Industrial Area		68.00	0.00	68.00	0.03	0.03	0.00				
6	Udupi / Karkala	Miyar Industrial Area		20.00	0.00	20.00	0.00	0.00	0.00				
Total				591.78	0.00	591.78	0.83	0.83	0.00				

Requirement of Water in KIADB Industrial Areas												
ABSTRACT												
Sl.no	District	Extent in Acres			Water Requirement in MLD			Allocation in MLD	Source	Utilisation in MLD	Additional Water Requirement in MLD	Remarks
		Existing	Proposed	Total	Fresh Water	Treated Water	Total Water Requirement in MLD					
1	2	3	4	3+4=5	6	7	6+7=8	9	10	11	6-9=12	13
1	Bengaluru Rural District	7068	3215	10283	68.5125	51.775	120.2875	22.14	BWSSB Yettinaholle	Utilised (Nil)	46.37	Fresh Water - a. BWSSB, from Yelahanka Plant . B. Additional requirement from Yettinaholle c. Proposal to lift 15 MLD water from Tippagondanahalli Reservior Treated Water 40 MLD Treatment Plant at Hitech Defence & Aerospace Park 1st phase. is proposed to meet the TTP Water Demand.
2	Ramanagara	5204.06	0	5204.06	39.5	20.25	59.75	13.5	BWSSB	4	26.00	
3	Kolar	Err:509	Err:509	Err:509	Err:509	Err:509	Err:509	0		0	Err:509	Fresh Water Probable Source- Yettinaholle Treated Water 40 MLD TTP at Narasapura Kolar
4	Chikkaballapura	Err:509	Err:509	Err:509	Err:509	Err:509	Err:509	0		0	Err:509	Probable Source -Yettinaholle
	A. Sub- Total	Err:509	Err:509	Err:509	Err:509	Err:509	Err:509	35.64			Err:509	

Sl.no	District	Extent in Acres			Water Requirement in MLD			Allocation in MLD	Source	Utilisation in MLD	Additional Water Requirement in MLD	Remarks
		Existing	Proposed	Total	Fresh Water	Treated Water	Total Water Requirement in MLD					
1	2	3	4	3+4=5	6	7	6+7=8	9	10	11	6-9=12	13
5	Tumakuru	6691.82	9627.00	16318.82	84.07	47.27	131.35	1.55	Hemavathi	Utilised	67.01	an enhancement of water from existing Hemavathi.
								15.51	Yettinaholle	0		Treated Water
6	Chitradurga	1304.73	1000.00	2304.73	11.00	5.00	16.00	0	Proposed Vani Villas (Upper Badra)	0	10.00	30 MLD TTP is proposed to meet Fresh Water Proposed Vani Villas Saga for Metikurke only Treated Water 5 MLD TTP water from 30 MLD Plant at Vasanthanarasapura Phase-3. For Industrial areas with Borewells supply, fresh water requirement is not considered in the Additional Water Requirement calculation
	B. Sub- Total	7996.55	10627.00	18623.55	95.07	52.27	147.35	15.51			77.01	
7	Davanagere	930.63	0.00	930.63	6.16	0.00	6.16	0	Tungabadra River 3Km Away	0	4.54	Fresh Water Proposed 1 MGD (4.54 MLD) from Tungabadra River WHICH IS 3 Kms. For Industrial areas with Borewells supply, fresh water requirement is not considered in the Additional Water Requirement calculation
8	Shivamogga	1182.07	0	1182.07	5.91	0.00	1.37	4.54	Badra	4.54	1.37	Fresh Water Source- Badra River 15 Km Away
	c. Sub- Total	2112.70	0.00	2112.70	12.07	0.00	7.53	4.50				

Sl.no	District	Extent in Acres			Water Requirement in MLD			Allocation in MLD	Source	Utilisation in MLD	Additional Water Requirement in MLD	Remarks
		Existing	Proposed	Total	Fresh Water	Treated Water	Total Water Requirement in MLD					
1	2	3	4	3+4=5	6	7	6+7=8	9	10	11	6-9=12	13
9	Mysuru (incl Mandya Chamrajanagar Kodagu)	7800.47	2949.6	10750.07	53.75	0.00	53.75	22.5	Kabini	7.27	0.00	
								36	Cauvery	4.25		
	D. Sub- Total	7800.47	2949.60	10750.07	53.75	0.00	53.75	58.50			0.00	
10	Mangaluru	1478.22	1091	2569.22	14.87	0.00	14.87	9.08	Tumbe Dam & Gurupura River	0.96	5.79	
	E. Sub- Total	1478.22	1091.00	2569.22	14.87	0.00	14.87	9.08			5.79	
11	Yadgir	3306.33	0.00	3306.33	16.53	0.00	16.53	24.5	Bheema River	2	0.00	Source of Water from Bhima River (Gudur-Joladadgi Barrage Back water)
12	Kalaburgi	1919.21	0.00	1919.21	9.55	0.00	9.55	0	Krishna	0	9.55	Fresh Water Proposed Samurthi Barrage 35-40 Kms
13	Bidar	2268.37	0.00	2268.37	11.44	0.00	11.44	0	Karanja Reservoir	0	11.44	.
	F. Sub- Total	7493.91	0.00	7493.91	37.52	0.00	37.52	24.50			20.99	
14	Ballari	2248.41	154	2402.41	12.65	0.00	12.65	0	TB Dam(HLC)	0	12.65	Proposed 20 MLD for allocation from TB Dam
15	Vijayanagar	128.61	0	128.61	0.65	0	0.65	0	Ground Water	0	0.00	For Industrial areas with Borewells supply, fresh water requirement is not considered in the Additional Water Requirement calculation
	G. Sub- Total	2377.02	154.00	2531.02	13.30	0.00	13.30	0.00			12.65	
16	Koppal	308.11	0	308.11	0.70	0.00	0.70	0	Ground Water	0	0.00	For Industrial areas with Borewells supply, fresh water requirement is not considered in the Additional Water Requirement calculation
17	Raichur	2570.69	2072.18	4642.87	21.05	1.80	22.85	10	CMC (Krishna)	8.75	11.05	Fresh Water Additional 10 MLD proposed for Allocation fromCMC (Krishna River) Treated Water Proposed to be utilised from 4 MLD TTP from Housing Layout
	H. Sub- Total	2878.80	2072.18	4950.98	21.75	1.80	23.55	10.00			11.05	
18	Belagavi	1987.51	576.1	2563.61	13.15	0.00	13.15	18.20		18.2	0.00	Fresh Water Additional 5.96 MLD proposed for Allocation from Krishna River

Sl.no	District	Extent in Acres			Water Requirement in MLD			Allocation in MLD	Source	Utilisation in MLD	Additional Water Requirement in MLD	Remarks
		Existing	Proposed	Total	Fresh Water	Treated Water	Total Water Requirement in MLD					
1	2	3	4	3+4=5	6	7	6+7=8	9	10	11	6-9=12	13
19	Bagalkot	293.63	0	293.63	1.50	0.00	1.50	10.20	Krishna	10.2	0.00	For Industrial areas with Borewells supply, fresh water requirement is not considered in the Additional Water Requirement calculation
20	Vijaypura	2353.06	2480	4833.06	24.40	0.00	24.40	0.00			24.40	
	I. Sub- Total	4634.20	3056.10	7690.30	39.05	0.00	39.05	18.20			24.40	
21	Hassan	2452.08	1377.25	3829.33	24.2	0	24.2	22.5	Hemavati	20.1	0.00	Additional Water not Required.
22	Chikkamagaluru	381.42	0	381.42	2	0	2					
	J. Sub- Total	2833.50	1377.25	4210.75	26.20	0.00	26.20	22.50			0.00	
23	Dharwad	12079.79	0.00	12079.79	60.27	0.00	60.27	12	Malaprabha	12	0.00	Additional Water is Required from Malaprabha
								45	Ghatapraha	0		Allocation Reserved for BMIC Project from Ghatapraha Reservoir For Industrial areas with Borewells supply, fresh water requirement is not considered in the Additional Water Requirement calculation
	K. Sub- Total	12079.79	0.00	12079.79	60.27	0.00	60.27	57.00			0.00	
	Grand Total	Err:509	Err:509	Err:509	Err:509	Err:509	Err:509	255.43			Err:509	

Within- Cauvery Basin.							
SI No	District/ Taluk	Industrial Area		Fresh Water MLD	Total required discharge (TMC)	Total required discharge (m ³ /sec)	Basin
		Existing Industrial Areas	Proposed Industrial Areas				
1	2	3	4	5	6	7	8
1	Bengaluru Rural/ Nelamangala Taluk	Dobaspet 1st and 2nd Phase		1.37	0.018	0.019	Cauvery Basin
2		Dobaspet 3rd Phase (Sompura1st & 2nd)		5.28	0.068	0.073	Cauvery Basin
3		Dobaspet 4th Phase		3.38	0.044	0.047	Cauvery Basin
4		Dobaspet 5th Phase		4.16	0.054	0.058	Cauvery Basin
5		Oblapura (Dobaspet 6th Phase)		4.21	0.054	0.058	Cauvery Basin
6			KWIN	26.50	0.342	0.368	Cauvery Basin
7			Dobaspet 7th Phase (Proposed)	2.60	0.034	0.036	Cauvery Basin
8			Nelamangala Proposed	10.00	0.129	0.139	Cauvery Basin
9			Nelamangala (Proposed Airport)	14.58	0.188	0.203	Cauvery Basin
10			Hanumanthapura (Proposed)	2.48	0.032	0.034	Cauvery Basin
	Sub Total (Nelamangala)			74.56	0.961	1.04	
1	Bengaluru Rural/ Doddaballapura Taluk	DB pura General (Obedenahalli)		2.50	0.032	0.035	Cauvery Basin
2		Appeara Park 1st Phase		0.65	0.008	0.009	Cauvery Basin
		Appeara Park 2nd Phase		0.86	0.011	0.012	Cauvery Basin
4		Adinarayana Hosahalli 1st Phase		0.43	0.005	0.006	Cauvery Basin
5		Adinarayana Hosahalli 2nd Phase		5.00	0.064	0.069	Cauvery Basin
	Sub Total (Doddaballapura)			9.43	0.122	1.58	Cauvery Basin

SI No	District/ Taluk	Industrial Area		Fresh Water MLD	Total required discharge (TMC)	Total required discharge (m ³ /sec)	Basin
		Existing Industrial Areas	Proposed Industrial Areas				
1	Bengaluru Rural/ Devanahalli	Devanahalli General 1st phase		7.00	0.090	0.097	Cauvery Basin
2			Devanahalli General 2nd phase (Proposed)	5.00	0.064	0.069	Cauvery Basin
	Sub Total (Devanahalli)			12.00	0.155	0.167	
	Bangalore Rural District Total			95.99	1.237	2.78	
Outside of the Cauvery Basin							
1	Bengaluru Rural/ Devanahalli	HitechAerospace Park 1st phase		14.00	0.180	0.194	South Pennar
2		Hitech Aerospace Park 2nd phase		6.00	0.077	0.083	South Pennar
5			Hitech Aerospace Park 3rd phase	7.50	0.097	0.104	South Pennar
	Sub Total (Devanahalli)			27.50	0.354	0.382	
1	Bengaluru Rural/ Hoskote	Hoskote IA		2.00	0.026	0.028	South Pennar
2			Hoskote (Proposed)	5.00	0.064	0.069	South Pennar
	Sub Total (Hoskote)			7.00	0.090	0.097	
	Bangalore Rural District Total			34.50	0.445	0.479	
1	Chikkabalapura	Gowribidanur 1st, 2nd, 3rd		7.00	0.090	0.097	North Pennar
2			Gowribidanur (Proposed)	7.00	0.090	0.097	North Pennar
	Total (Chikkaballapura)			14.00	0.180	0.19	South Pennar
1	Kolar	Malur 1st, 2nd, 3rd and 4th Phase		5.00	0.064	0.069	South Pennar
2		Bhavanahalli		4.00	0.052	0.056	South Pennar
3		Jakkasandra		3.50	0.045	0.049	South Pennar
4		Jakkasandra 2nd phase (Mindahalli)		2.50	0.032	0.035	South Pennar
5			Shivarapatna	6.00	0.077	0.083	South Pennar

SI No	District/ Taluk	Industrial Area		Fresh Water MLD	Total required discharge (TMC)	Total required discharge (m³/sec)	Basin
		Existing Industrial Areas	Proposed Industrial Areas				
			KGF New Proposed IA	10.00	0.129	0.139	Palar
6		Narasapura-Kolar		3.50	0.045	0.049	Palar
7		Vemgal 1st and 2nd Phase +(3rd Phase proposed)		8.00	0.103	0.111	Palar
	Total (Kolar)			42.50	0.548	0.590	
3	Chikkaballapura	Mastenahalli 1st & 2nd Phase		4.00	0.052	0.056	Palar
4			Mastenahalli (Proposed)	2.50	0.032	0.035	Palar
			Jangamakote (Proposed)	12.00	0.155	0.167	South Pennar
6			Bagepalli	5.00	0.064	0.069	North Pennar
8			Chikkaballapura Shidlagatta	12.50	0.161	0.174	South Pennar
			Srinivasapura (Proposed)	6.00	0.077	0.083	Palar
			Srinivasapura (Future Development)	15.00	0.193	0.208	Palar
7			Chintamani	2.50	0.032	0.035	Palar
	Total (Chikkaballapura)			59.50	0.767	0.826	
Grand Total				246.49	3.177	3.424 Cumecs	

Present Status /withdrawals in Cauvery Basin (Abstract-District wise)												
SI No	District/ Taluk	Total Extent in Acres	Total Water Requirement				Treated Water being supplied in MLD	Fresh Water required in MLD	Existing Schemes from Cauvery River		Additional fresh water requirement	
			in MLD			In TMC			in MLD	In TMC	in MLD	In TMC
1	Bengaluru Rural	10,283.00	120.29			1.55	51.78	68.51	2.75	0.04	65.76	0.85
2	Ramanagara	5,204.06	59.75			0.77	20.25	39.50	-	-	39.50	0.51
3	Tumakuru	679.58	3.75			0.05	1.88	1.87	-	-	1.88	0.02
4	Mysore	10,750.07	53.75			0.69	-	53.75	58.50	0.75	-4.75	-0.06
5	Hassan	3,829.33	24.20			0.31	-	24.20	22.50	0.29	1.70	0.02
6	Chikkamagaluru	144.47	1.00			0.01	-	1.00	-	-	1.00	0.01
	Total	30,890.51	262.74			3.39	73.90	188.84	83.75	1.08	105.09	1.36
Water Requirements for Industrial areas around Bengaluru												
		Within Cauvery basin					Outside Cauvery Basin					
SI No	District/ Taluk	Total Extent in Acres	Total Water Requirement				Total Extent in Acres	Total Water Requirement				
			in MLD	In TMC	Potable, in TMC	Treated, in TMC		in MLD	In TMC	Potable, in TMC	Treated, in TMC	
1	Bengaluru Rural	10,283.00	120.29	1.55	1.04	0.51	-	73.62	0.95	0.59	0.36	
2	Ramanagara	5,204.06	59.75	0.77	0.50	0.27	-	-	-	-	-	
3	Tumakuru	679.58	3.75	0.0483	0.05	-0.00	15,852.65	127.59	1.64	1.10	0.54	
4	Kolar	-	-	-	-	-	6,041.13	73.00	0.94	0.62	0.32	
5	Chikkaballapur	-	-	-	-	-	9,800.00	80.00	1.03	0.67	0.36	
	Total	16,166.64	183.79	2.37	1.59	0.78	31,693.78	354.21	4.57	2.98	1.59	
	Less Allocation if any			0					1.64	1.10	0.54	
	Less Kolar								-	-		
	Total	16,166.64	183.79	2.37	1.59	0.78	31,693.78	354.21	2.93	1.88	1.04	
1	DPR TO BE PREPARED FOR POTABLE WATER FROM CAUVERY, THROUGH INTERNAL ALLOCATION FROM 17.64 TMC OF (SHARE IN BALANCE WATER OF CWDT PAGE NO.325, SC ORDER DTD.FEB16, 2018				3.47	TMC	Covers portable water for All Inudtrial Areas of Cauvery Basin and Non Cauvery Basin Industrial Areas					
2	DPR for conveyance of Treated water from TTPs of BWSSB for				1.82	TMC	Covers Treated water cauvery and Non Cauvery Basin Industrial Area HighTech Defence Aerospace Park, Kolar, Chikkaballapur, Gouribidnur etc.					

Note:

1

Status of Water Within Cauvery basin

Additional water requirement = **2.37 TMC**
Present withdrawals for outhter areas within basin = 1.08 TMC
Total requirement = 2.37+1.08=3.45 TMC
Allocation available as per CWDT = 4.00 TMC
Surplus water still available in Cauvery basin=0.55 TMC

2

Status of Water OUTSIDE Cauvery basin

Additional water requirement, outside basin = **1.98 TMC**
From surplus in Cauvery basin=0.55 TMC
From Yettinahole allocation to devanahalli industrial area = 0.50 TMC
Sourcing from Yettinahole savings=0.93 TMC
Bengaluru but outside cauvery basin
=0.55+0.50+0.93 = **1.98 TMC**

DPRs can be prepared for supply of water for all Industrial areas, around BENGALURU falling both within the Cauvery basin and outside the Cauvery basin.

Present Status /withdrawals in Cauvery Basin (Abstract-District wise)												
SI No	District/ Taluk	Total Extent in Acres	Total Water Requirement				Treated Water being supplied in MLD	Fresh Water required in MLD	Existing Schemes from Cauvery River		Additional fresh water requirement	
			in MLD			In TMC			in MLD	In TMC	in MLD	In TMC
1	Bengaluru Rural	10,283.00	120.29			1.55	51.78	68.51	2.75	0.04	65.76	0.85
2	Ramanagara	5,204.06	59.75			0.77	20.25	39.50	-	-	39.50	0.51
3	Tumakuru	679.58	3.75			0.05	1.88	1.87	-	-	1.88	0.02
4	Mysore	10,750.07	53.75			0.69	-	53.75	58.50	0.75	-4.75	-0.06
5	Hassan	3,829.33	24.20			0.31	-	24.20	22.50	0.29	1.70	0.02
6	Chikkamagaluru	144.47	1.00			0.01	-	1.00	-	-	1.00	0.01
	Total	30,890.51	262.74			3.39	73.90	188.84	83.75	1.08	105.09	1.36
Water Requirements for Industrial areas around Bengaluru												
		Within Cauvery basin					Outside Cauvery Basin					
SI No	District/ Taluk	Total Extent in Acres	Total Water Requirement				Total Extent in Acres	Total Water Requirement				
			in MLD	In TMC	Potable, in TMC	Treated, in TMC		in MLD	In TMC	Potable, in TMC	Treated, in TMC	
1	Bengaluru Rural	10,283.00	120.29	1.55	1.04	0.51	-	73.62	0.95	0.59	0.36	
2	Ramanagara	5,204.06	59.75	0.77	0.50	0.27	-	-	-	-	-	
3	Tumakuru	679.58	3.75	0.0483	0.05	-0.00	15,852.65	127.59	1.64	1.10	0.54	
4	Kolar	-	-	-	-	-	6,041.13	73.00	0.94	0.62	0.32	
5	Chikkaballapur	-	-	-	-	-	9,800.00	80.00	1.03	0.67	0.36	
	Total	16,166.64	183.79	2.37	1.59	0.78	31,693.78	354.21	4.57	2.98	1.59	
	Less Allocation if any			0					1.64	1.10	0.54	
	Less Kolar								-	-		
	Total	16,166.64	183.79	2.37	1.59	0.78	31,693.78	354.21	2.93	1.88	1.04	
1	DPR TO BE PREPARED FOR POTABLE WATER FROM CAUVERY, THROUGH INTERNAL ALLOCATION FROM 17.64 TMC OF (SHARE IN BALANCE WATER OF CWDT PAGE NO.325, SC ORDER DTD.FEB16, 2018				3.47	TMC	Covers all las of Cauvery basin including FOXCON, KHIR and MMLP					
2	DPR for conveyance of Treated water from TTPs of BWSSB for				1.82	TMC	Covers HighTech Defence Aerospace Park, Kolar, Chikkaballapur, Gouribidnur etc.					

Note:

1

Status of Water Within Cauvery basin

Additional water requirement = 2.37

Present withdrawals for outhar areas within basin = 1.08

Total requirement = 2.37+1.08=3.45

Allocation available as per CWDT = 4.00

Surplus water still available in Cauvery basin=0.55

2

Status of Water OUTSIDE Cauvery basin

Additional water requirement, outside basin

1.98

TMC

From surplus in Cauvery basin=0.55

TMC

From Yettinahole allocation to devanahalli industrial area = 0.50

TMC

Sourcing from Yettinahole savings=0.93

TMC

Bengaluru but outside cauvery basin =0.55+0.50+0.93 = 1.98

TMC

DPRs can be prepared for supply of water for all Industrial areas, around BENGALURU falling both within the Cauvery basin and outside the Cauvery basin.

CAUVERY BASIN - PROPOSED LIFTING SCHEME								
SI No	District/ Taluk	Total Extent in Acres			Water Allocation			Basin
		Existing	Proposed	Total Extent in Acres	Total Water Requirement in MLD	Bifurcation of Required Water in MLD		
						Fresh Water	Treated Water	
1	Bangalore Rural District Total	8054	4415	12469	120.42	80.93	39.50	Cauvery Basin
2	Ramanagara	5204.06		5204.06	59.74	38.72	20.98	Cauvery Basin
3	Tumkur	679.58		679.58	3.75	3.75	0.00	Cauvery Basin
	Grand Total	13937.64	4415.00	18352.64	183.91	123.39	60.48	

CAUVERY BASIN - PROPOSED LIFTING SCHEME													
SI No	District/ Taluk	Industrial Area		Total Extent in Acres			As per Present Data			As per Revised			Basin
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres	Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Total Water Requirement in MLD	Bifurcation of Required Water in MLD		
								Fresh Water	Treated Water		Fresh Water	Treated Water	
1	2	3	4	5	6	7=5+6	8=9+10	9	10	11=12+13	12	13	14
1	Bengaluru Rural/ Nelamangala Taluk	Dabaspete 1st and 2nd Phase		343		343	2.74	1.37	1.37	2.56	1.72	0.84	Cauvery Basin
2		Dabaspete 3rd Phase (Sompura1st & 2nd)		1321		1321	10.57	5.28	5.28	9.84	6.60	3.24	Cauvery Basin
3		Dabspete 4th Phase		844		844	6.75	3.38	3.38	6.29	4.22	2.07	Cauvery Basin
4		Dabspete 5th Phase		1040		1040	8.32	4.16	4.16	7.75	5.20	2.55	Cauvery Basin
5		Oblapura & MMLP		842		842	8.42	4.21	4.21	6.27	4.21	2.06	Cauvery Basin
7			KHIR		2200	2200	30.00	15.00	15.00	35.00	25.00	10.00	Cauvery Basin
8			Sompura 28(4)		520	520	5.20	2.60	2.60	3.87	2.60	1.27	Cauvery Basin
9			Hanumanthapura, Bidluru, Kodipalya 28(1)		495	495	4.95	2.48	2.48	3.69	2.48	1.21	Cauvery Basin
	Sub Total (Nelamangala)			4390	3215	7605	76.95	38.48	38.48	75.27	52.03	23.24	
1	Bengaluru Rural/ Doddaballapura Taluk	DB pura General Industrial Area		352		352	1.76	1.76	0.00	2.62	1.76	0.86	Cauvery Basin
2		Appearal Park 1st and 2nd phase		453		453	2.27	2.27	0.00	3.37	2.27	1.11	Cauvery Basin
3		Obedenahalli		697		697	3.49	3.49	0.00	5.19	3.49	1.71	Cauvery Basin
4		Adinarayana Hosahalli 1st Phase		195		195	0.98	0.98	0.00	1.45	0.98	0.48	Cauvery Basin
5		Adinarayana Hosahalli 2nd Phase		981		981	10.79	7.85	2.94	7.31	4.91	2.40	Cauvery Basin
	Sub Total (Doddaballapura)			2678	0.00	2678	19.28	16.33	2.94	19.95	13.39	6.56	Cauvery Basin
1	Bengaluru Rural/ Devanahalli	Devanahalli General IA 1st phase		986		986	20.00	15.00	5.00	7.35	4.93	2.42	Cauvery Basin
2			Devanahalli General IA 2nd phase		1200.00	1200	15.00	10.00	5.00	8.94	6.00	2.94	Cauvery Basin
	Sub Total (Devanahalli)			986	1200	2186	35.00	25.00	10.00	16.29	10.93	5.36	
	Bangalore Rural District Total			8054	4415	12469	131.23	79.81	51.42	111.50	76.35	35.16	
		For Future Development					32.81	19.95	12.86	8.92	4.58	4.34	
		Total (Bengaluru Rural)		8054	4415	12469	164.04	99.76	64.28	120.42	80.93	39.50	
	AS per the Final Water Allocation									120.22	80.68	39.54	

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			As per Present Data			As per Revised			Basin	
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres	Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Total Water Requirement in MLD	Bifurcation of Required Water in MLD			
								Fresh Water	Treated Water		Fresh Water	Treated Water		
	Ramanagara	Bidadi 1st Phase		862.31		862.31	7.50	5.00	2.50	7.50	5.00	2.50	Cauvery Basin	
		Bidadi 2nd Phase-Sector-1		183.13		183.13	7.00	5.00	2.00	7.00	5.00	2.00	Cauvery Basin	
		Bidadi 2nd Phase-Sector-2		452.81		452.81							Cauvery Basin	
		Harohalli 1st Phase		250.39		250.39	3.00	2.00	1.00	1.80	1.00	0.80	Cauvery Basin	
		Harohalli 2nd Phase		919.16		919.16	12.00	8.00	4.00	12.00	8.00	4.00	Cauvery Basin	
		Harohalli 3rd Phase		1210.90		1210.90	15.00	10.00	5.00	15.00	10.00	5.00	Cauvery Basin	
		Women Entrepreneur's Park Harohali 3rd Phase		60.87		60.87	0.75	0.50	0.25	0.62	0.30	0.27	Cauvery Basin	
		Harohalli 4th Phase		352.36		352.36	1.50	1.00	0.50	2.82	1.41	1.41	Cauvery Basin	
		Harohalli 5th Phase		912.13		912.13	13.00	8.00	5.00	13.00	8.00	5.00	Cauvery Basin	
		Total (Ramanagara)		5204.06		5204.06	59.75	39.50	20.25	59.74	38.72	20.98		
AS per the Final Water Allocation										59.74	38.79	20.95		
	Tumkur	Antharasanahalli Industrial Area, 1st Phase		208.00	0.00	208.00	1.00	0.50	0.5	1.00	1.00	0	Cauvery Basin	
		Antharasanahalli Industrial Area, 2nd Phase		256.84	0.00	256.84	1.50	0.75	0.75	1.50	1.50	0	Cauvery Basin	
		Sathyamangala Industrial Area		54.04	0.00	54.04	0.25	0.13	0.125	0.25	0.25	0	Cauvery Basin	
		Hirehalli Industrial Area		160.70	0.00	160.70	1.00	0.50	0.5	1.00	1.00	0	Cauvery Basin	
			Total (Tumakuru)	679.58	0.00	679.58	3.75	1.88	1.88	3.75	3.75	0.00		
	AS per the Final Water Allocation										3.75	3.75	0.00	
	Grand Total			13937.64	4415.00	18352.64	227.54	141.14	86.40	183.91	123.39	60.48		
	Allocation of water In TMC For Cauvery Basin										2.37	1.59	0.78	

SOUTH PENNAR - PROPOSED LIFTING SCHEME

SI No	District/ Taluk	Total Extent in Acres			Water Allocation			Basin
		Existing	Proposed	Total Extent in Acres	Total Water Requirement in MLD	Bifurcation of Required Water in MLD		
						Fresh Water	Treated Water	
1	2	5	6	7=5+6				
1	Total (Bengaluru Rural)	4611.15	2770	7381.15	73.36	45.96	27.40	South Pennar
2	Total (Kolar)	1880	2336	4216	50.22	33.10	17.12	South Pennar
3	Total (Chikkaballapura)	0.0	2500.0	2500.0	19.3	12.50	6.75	South Pennar
Grand Total		6491.01	7606.21	14097.22	142.83	91.56	51.27	

NORTH- PENNAR - PROPOSED LIFTING SCHEME

SI No	District/ Taluk	Total Extent in Acres			As per Revised			Basin
		Existing	Proposed	Total Extent in Acres	Total Water Requirement in MLD	Bifurcation of Required Water in MLD		
						Fresh Water	Treated Water	
1	2	5	6	7=5+6				
	Total (Chikkaballapura)	2427.0	3100.0	5527.0	45.4	29.50	15.93	
Grand Total		2427.00	3100.00	5527.00	45.43	29.50	15.93	

PALAR - PROPOSED LIFTING SCHEME

SI No	District/ Taluk	Total Extent in Acres			As per Present Data			As per Revised			Basin
		Existing	Proposed	Total Extent in Acres	Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Total Water Requirement in MLD	Bifurcation of Required Water in MLD		
						Fresh Water	Treated Water		Fresh Water	Treated Water	
1	2	5	6	7=5+6	8	9	10=9+8				
	Total (Kolar)	1825		1825	17.00	8.50	8.50	22.80	15.00	7.80	Palar Basin
	Total (Chikkaballapura)		1773.0	1773.0	11.0	5.5	5.5	15.4	10.00	5.40	Palar Basin
Grand Total		1825.07	1773.00	3598.07	28.00	14.00	14.00	38.20	25.00	13.20	

NON-CAUVERY BASIN - PROPOSED LIFTING SCHEME

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			As per Present Data			As per Revised			Basin	
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres	Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Total Water Requirement in MLD	Bifurcation of Required Water in MLD			
								Fresh Water	Treated Water		Fresh Water	Treated Water		
1	2	3	4	5	6	7=5+6	8	9	10=9+8					
1	Bengaluru Rural/ Devanahalli	Hitech Defence & Aerospace Park 1st phase		3009		3009	30.09	15.05	15.05	24.07	15.05	9.03	South Pennar	
2		Hitech Defence & Aerospace Park 2nd phase		1200		1200	12.00	6.00	6.00	9.60	6.00	3.60	South Pennar	
5			Hitech Defence & Aerospace Park 3rd phase			1770	1770	17.70	8.85	8.85	14.16	8.85	5.31	South Pennar
	Sub Total (Devanahalli)			4209	1770	5979	59.79	29.90	29.90	47.83	29.90	17.94		
1	Bengaluru Rural/ Hoskote	Hoskote IA		402.15		402.15	8.00	4.00	4.00	3.11	1.97	1.14	South Pennar	
2			Hoskote (Proposed)			1000				1000	7.74	4.90	2.84	South Pennar
	Sub Total (Hoskote)			402.15	1000	1402.15	8.00	4.00	4.00	10.86	6.87	3.98		
	Bangalore Rural District Total			4611.15	2770	7381.15	67.79	33.895	33.895	58.69	36.77	21.92		
	For Future Development						16.95	8.47	8.47	14.67	9.19	5.48		
	Total (Bengaluru Rural)			4611.15	2770	7381.15	84.7375	42.36875	42.36875	73.36	45.96	27.40		
	As per the Allocation									73.62	45.77	27.85		
1	Kolar	Malur 1st, 2nd, 3rd and 4th Phase		917		917	10.00	5.00	5.00	7.60	5.00	2.60	South Pennar	
2		Bhavanahalli			722	722	20.00	10.00	10.00	15.20	10.00	5.20	South Pennar	
3		Jakkasandra		627		627	6.00	3.00	3.00	7.60	5.00	2.60	South Pennar	
4		Jakkasandra II Phase (Mindahalli)		335		335	2.00	1.00	1.00	4.62	3.10	1.52	South Pennar	
5			Malur (Proposed)			1614	1614	18.00	8.00	10.00	15.20	10.00	5.20	South Pennar
6		Narasapura-Kolar		701		701	6.00	3.00	3.00	7.60	5.00	2.60	Palar	
7		Vemagal		666		666	6.00	3.00	3.00	7.60	5.00	2.60	Palar	
8		Vemagal II Phase		458		458	5.00	2.50	2.50	7.60	5.00	2.60	Palar	
	Total (Kolar)			3705	2336	6041	73.00	35.50	37.50	73.02	48.10	24.92		
	As per the Allocation									73.00	48.10	24.90		

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			As per Present Data			As per Revised			Basin
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres	Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Total Water Requirement in MLD	Bifurcation of Required Water in MLD		
								Fresh Water	Treated Water		Fresh Water	Treated Water	
1	Chikkabalapura	Gowribidanur Ist, 2nd, 3rd		1495.0		1495	25.00	15.00	10.00	12.32	8.00	4.32	North Pennar
2			Gowribidanur (Proposed)		1500.0	1500				12.32	8.00	4.32	North Pennar
3		Mastenahalli 1st & 2nd Phase		932.0		932	16.00	8.00	8.00	7.70	5.00	2.70	North Pennar
4			Mastenahalli (Proposed)		600.0	600				5.39	3.50	1.89	North Pennar
6			Bagepalli		1000.0	1000	8.00	3.00	5.00	7.70	5.00	2.70	North Pennar
8			Chikkaballapura Shidlagatta		2500.0	2500	20.00	10.00	10.00	19.25	12.50	6.75	South Pennar
5			Srinivasapura Taluk (Proposed)		1273.0	1273	6.00	3.00	3.00	10.78	7.00	3.78	Palar
7			Chintamani		500.0	500	5.00	2.50	2.50	4.62	3.00	1.62	Palar
	Total (Chikkaballapura)			2427.0	7373.0	9800.0	80.0	41.5	38.5	80.1	52.00	28.08	
	As per the Allocation									80.00	51.98	28.02	
Grand Total				10743.08	12479.21	23222.29	237.74	119.37	118.37	226.46	146.06	80.40	
Allocation of water In TMC For Non-Cauvery Basin										2.92	1.88	1.04	

Requirement of Water in KIADB Industrial Areas					
ABSTRACT - BASIN & DISTRICT WISE					
Sl.no	Basin	District	Extent of Area in Acres	Total Water Requirement in MLD	Total Water Requirement in TMC
1	Cauvery Basin	Bengaluru Rural District	10,252.21	128.49	
			9,597.93	120.29	
2		Ramanagara	5,204.06	59.75	
3		Mysuru (incl Mandya Chamrajanagar Kodagu)	10,750.07	53.75	
4		Tumakuru	16,318.82	3.76	
5		Hassan	3,829.33	24.20	
6		Chikkamagaluru	381.42	1.00	
	Cauvery Basin Total		56,333.84	391.24	5.04
7	Krishna Basin	Chikkamagaluru		1.00	
8		Ballari	2,402.41	12.65	
9		Vijayanagar	128.61	0.65	
10		Koppal	308.11	0.70	
11		Raichur	4,642.87	22.85	
12		Belagavi	2,563.61	13.15	
13		Bagalkot	293.63	1.50	
14		Vijayapura	4,833.06	24.40	
15		Tumakuru		127.60	
16		Chitradurga	2,304.73	16.00	
17		Davanagere	930.63	6.16	
18		Yadgir	3,306.33	16.53	
19		Kalaburgi	1,919.21	9.55	
20		Shivamogga	1,182.07	1.37	
21		Dharwad	12,079.79	55.85	
22		Bidar	2,268.37	3.00	
		Krishna Basin Total	39163.43	312.96	4.03
23	Godavari Basin	Bidar		8.44	
		Godavari Basin Total	0	8.44	0.11
24	West flowing Basin	Dharwad		4.42	
25	West flowing Basin	Mangaluru	2,569.22	14.87	
		West flowing Basin Total	2569.22	19.29	0.25
26	Palar Basin	Kolar	6,041.14	17.00	
27	Palar Basin	Chikkaballapura	9,800.00	11.00	
		Palar Basin Total	15,841.14	28.00	0.36
28	South Pennar Basin	Kolar		56.00	
29	South Pennar Basin	Bengaluru Urban District		128.49	
30	South Pennar Basin	Chikkaballapura		20.00	

Sl.no	Basin	District	Extent of Area in Acres	Total Water Requirement in MLD	Total Water Requirement in TMC
		South Pennar Basin Total	-	204.49	2.64
31	North pennar	Chikkaballapura		49.00	
		North pennar Basin Total	0	49.00	0.63
		Grand Total	113,907.63	1013.41	13.06

INDUSTRIAL AREAS IN KARNATAKA STATE (District wise)
(Developed / Under Developed / Proposed)

S.No	District	Industrial Area (Acres)
1	Bengaluru Rural	19,850.15
2	Ramanagara	5,204.06
3	Kolar	6,041.14
4	Chikkaballapura	9,800.00
5	Tumakuru	16,318.82
6	Chitradurga	2,304.73
7	Davanagere	930.63
8	Shivamogga	1,182.07
9	Mysuru	10,750.07
10	Mangaluru	2,569.22
11	Yadgir	3,306.33
12	Kalaburgi	1,919.21
13	Bidar	2,268.37
14	Ballari	2,402.41

S.No	District	Industrial Area (Acres)
15	Vijayanagar	128.61
16	Koppal	308.11
17	Raichur	4,642.87
18	Belagavi	2,563.61
19	Bagalkot	293.63
20	Vijaypura	4,833.06
21	Hassan	3,829.33
22	Chikkamagaluru	381.42
23	Dharwad	12,079.79
	Grand Total	113,907.64

KIADB				
INDUSTRIAL AREA IN KARNATAKA STATE (District wise)				
(Developed / Under Development/ Proposed)				
Fresh Water Requirement Details				
S.No	District	Industrial Area (Acres)	Water Requirement (MLD)	Water Requirement (TMC)
1	Bengaluru Rural	19,850.15	248.78	3.21
2	Ramanagara	5,204.06	59.75	0.77
3	Kolar	6,041.14	73.00	0.94
4	Chikkaballapura	9,800.00	80.00	1.03
5	Tumakuru	16,318.82	131.35	1.69
6	Chitradurga	2,304.73	16.00	0.21
7	Davanagere	930.63	6.16	0.08
8	Shivamogga	1,182.07	1.37	0.02
9	Mysuru	10,750.07	53.75	0.69
10	Mangaluru	2,569.22	14.87	0.19
11	Yadgir	3,306.33	16.53	0.21
12	Kalaburgi	1,919.21	9.55	0.12
13	Bidar	2,268.37	11.44	0.15
14	Ballari	2,402.41	12.65	0.16
15	Vijayanagar	128.61	0.65	0.01
16	Koppal	308.11	0.70	0.01
17	Raichur	4,642.87	22.85	0.29
18	Belagavi	2,563.61	13.15	0.17
19	Bagalkot	293.63	1.50	0.02
20	Vijayapura	4,833.06	24.40	0.31
21	Hassan	3,829.33	24.20	0.31
22	Chikkamagaluru	381.42	2.00	0.03
23	Dharwad	12,079.79	60.27	0.78
	Grand Total	113,907.64	884.92	11.41

KIADB			
INDUSTRIAL AREA IN KARNATAKA STATE (District & Basin wise)			
Sl.no	District	Water Requirement MLD	Water Requirement TMC
Cauvery Basin			
1	Bengaluru Rural	120.29	1.55
2	Ramanagara	59.75	0.77
3	Mysuru	53.75	0.69
4	Tumakuru	3.76	0.05
5	Hassan	24.20	0.31
6	Chikkamagaluru	1.00	0.01
	Cauvery Basin Total	262.74	3.39
Krishna Basin			
7	Chikkamagaluru	1.00	0.01
8	Ballari	12.65	0.16
9	Vijayanagar	0.65	0.01
10	Koppal	0.70	0.01
11	Raichur	22.85	0.29
12	Belagavi	13.15	0.17
13	Bagalkot	1.50	0.02
14	Vijaypura	24.40	0.31
15	Tumakuru	127.60	1.64
16	Chitradurga	16.00	0.21
17	Davanagere	6.16	0.08
18	Yadgir	16.53	0.21
19	Kalaburgi	9.55	0.12
20	Shivamogga	1.37	0.02
21	Dharwad	55.85	0.72
22	Bidar	3.00	0.04
	Krishna Basin Total	312.96	4.03
Godavari Basin			
23	Bidar	8.44	0.11
	Godavari Basin Total	8.44	0.11
West flowing Basin			
24	Dharwad	4.42	0.06
25	Mangaluru	14.87	0.19
	West flowing Basin Total	19.29	0.25
Palar Basin			
26	Kolar	17.00	0.22
27	Chikkaballapura	11.00	0.14
	Palar Basin Total	28.00	0.36

Sl.no	District	Water Requirement MLD	Water Requirement TMC
South Pennar Basin			
28	Kolar	56.00	0.72
29	Bengaluru Urban	128.49	1.66
30	Chikkaballapura	20.00	0.26
	South Pennar Basin Total	204.49	2.64
North pennar			
31	Chikkaballapura	49.00	0.63
	North pennar Basin Total	49.00	0.63
	Grand Total	884.92	11.41

KIADB			
INDUSTRIAL AREA IN KARNATAKA STATE (Basin wise)			
Sl.no	BASIN	Water Requirement (MLD)	Water Requirement (TMC)
1	Cauvery Basin	262.74	3.39
2	Krishna Basin	312.96	4.03
3	Godavari Basin	8.44	0.11
4	West flowing Basin	19.29	0.25
5	Palar Basin	28.00	0.36
6	South Pennar Basin	204.49	2.64
7	North pennar Basin	49.00	0.63
	Grand Total	884.92	11.41

KIADB

INDUSTRIAL AREAS IN CAUVERY BASIN

SI No	District/ Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water	Treated Water	Allocation in MLD only for Fresh water	Source	Remarks
	Cauvery Basin								3.39
1	Bengaluru Rural	Dabaspete 1st and 2nd Phase	343	2.744	1.372	1.372	NII	TGR	Proposal to lift 15 MLD water from Tippagondanahalli Reservior
		Dabaspete 3rd Phase (Sompura1st & 2nd)	1321	10.568	5.284	5.284			
		Dabspete 4th Phase	844	6.752	3.376	3.376			
		Dabspete 5th Phase	1040	8.32	4.16	4.16			
		Oblapura & MMLP	842	8.42	4.21	4.21			
		KHIR	2200	30	15	15	NII		
		Sompura 28(4)	520	5.2	2.6	2.6			
		Hanumanthapura, Bidlu	495	4.95	2.475	2.475			
		Sub Total (Nelamangala)	7605	76.954	38.477	38.477			
		DB pura General Industrial Area	352	1.76	1.76	0	2.75	BWSSB Yelahanka	dt:07.02.2004 b. Treated Water 5 MLD TTP water is to be drawn from exitsing 40 MLD TTP, in Hitech Defence & Aerospace Park 1st
		Appearal Park 1st and 2nd phase	453	2.265	2.265	0			
		Obedenahalli	697	3.485	3.485	0			
		Adinarayana Hosahalli 1st Phase	195	0.975	0.975	0			
		Adinarayana Hosahalli 2nd Phase	981	10.791	7.848	2.943			
		Sub Total (Doddaballapura)	2678	19.276	16.333	2.943	2.75		
			10283	96.23	54.81	41.42	2.75		
		For Future Development		24.0575	13.7025	10.355			
		Total (Bengaluru Rural)	10283	120.2875	68.5125	51.775	2.75		
2	Ramanagara	Bidadi 1st Phase	862.31	7.5	5	2.5	13.5	BWSSB	
		Bidadi 2nd Phase-Sector-1	183.13	7	5	2			
		Bidadi 2nd Phase-Sector-2	452.81						
		Harohalli 1st Phase	250.39	3	2	1			
		Harohalli 2nd Phase	919.16	12	8	4			
		Harohalli 3rd Phase	1210.9	15	10	5			
		Women Entrepreneur's Park							
		Harohali 3rd Phase	60.87	0.75	0.5	0.25			
		Harohalli 4th Phase	352.36	1.5	1	0.5			
		Harohalli 5th Phase	912.13	13	8	5			
		Total (Ramanagara)	5204.06	59.75	39.5	20.25			

SI No	District/ Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water	Treated Water	Allocation in MLD only for Fresh water	Source	Remarks
3	Tumakuru	Antharasanahalli Industrial Area, 1st Phase	208	1	0.5	0.5			
		Antharasanahalli Industrial Area, 2nd Phase	256.84	1.5	0.75	0.75			
		Sathyamangala Industrial Area	54.04	0.25	0.125	0.125			
		Hirehalli Industrial Area	160.7	1	0.5	0.5			
		Total (Tumakuru)	679.58	3.75	1.875	1.875			
4	Mysuru	Hebbal	1603	8.015	8.015	0	36	Cauvery	
		Hebbal Weavers colony							
		Hebbal Housing Area							
		Hootagally	426	2.13	2.13	0			
		Belavadi	238	1.19	1.19	0			
		Koorgally	472	2.36	2.36	0			
		Hebbal 2nd Phase	193.46	0.9673	0.9673	0			
		Kadakola	255.65	1.27825	1.27825	0	22.5	Kabini	Source - Kabini with an allocation of 22.5 MLD
		Kochanahalli IA(EMC)	235.54	1.1777	1.1777	0			
		Nanjangud	535	2.675	2.675	0			
		Thandya	144	0.72	0.72	0			
		Adakanahalli	538.22	2.6911	2.6911	0			
		Immavu	500	2.5	2.5	0			
		Women's En. Park -1	48.03	0.24015	0.24015	0			
		Women's En. Park -2	68.64	0.3432	0.3432	0			
		Thandya 2nd Phase	626.7	3.1335	3.1335	0			
		Thandya 2nd Stage 1st Phase	68	0.34	0.34	0			
		Sinduvallipura	449	2.245	2.245	0			
		Badanguppe - Kellamballi Phase-1	1460.47	7.30235	7.30235	0			
		Badanguppe - Kellamballi Phase-2	907.06	4.5353	4.5353	0			
		Somanahally	154	0.77	0.77	0		Borwell	
		Gejjalagere	78.3	0.3915	0.3915	0		Borwell	
		Tubinakere	141	0.705	0.705	0		KUWSSB Mandya	
		Kushalnagar	250	1.25	1.25	0		Borwell	
		Kuduragundi	109	0.545	0.545	0			
		Bachanahalli	1249	6.245	6.245	0			
		Total (Mysore, Mandya)	10750.07	53.75035	53.7504				
5	Hassan	Hassan Growth Centre (Including Sublayouts & SEZ's)	2245.09	11	11	0	4.95 MGD (22.5 MLD)	Hemavathi	Source- Hemavathi with an allocation of 22.5 MLD , therefore Additional Water not required.
		B.Katihalli	102.97	0.5	0.5	0			
		Holenarasipura	28.95	0.1	0.1	0			
		Thimmanahalli	75.07	0.35	0.35	0			
		Hassan Industrial Area	1057.6	10.55	10.55	0			
		Doothanuru Kaval	177.49	1	1	0	Borewell		
		Mylanahalli	142.16	0.7	0.7	0			
			3829.33	24.2	24.2	0			
6	Chikkamangaluru	Amble Industrial Area	144.47	1	1	0	Borewell		
	Total (Chikkamagaluru)		144.47	1	1	0			

Requirement of Water in KIADB Industrial Areas									
ABSTRACT - BASIN & DISTRICT WISE									
SI No	District/ Taluk	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water in MLD	Treated Water in MLD	Allocation in MLD only for Fresh water	Allocation in TMC only for Fresh water	Deficit Fresh Water in MLD	Deficit Fresh Water in TMC
	Cauvery Basin								
1	Bengaluru Rural	10283.00	120.29	68.51	51.78	2.75	0.035	65.76	0.848
2	Ramanagara	5204.06	59.75	39.50	20.25	0	0.000	39.50	0.509
3	Tumakuru	679.58	3.75	1.88	1.88	0	0.000	1.88	0.024
4	Mysore	10750.07	53.75	53.75	0.00	58.5	0.754	-4.75	-0.061
5	Hassan	3829.33	24.20	24.20	0.00	22.5	0.290	1.70	0.022
6	Chikkamagaluru	144.47	1.00	1.00	0.00	0	0.000	1.00	0.013
		30890.51	262.74	188.84	73.90	83.75	1.08	105.09	1.355
				2.450	0.96	1.09			
						2.05			

Fresh Water Requirement	1.355	TMC
Present Water Supply Schemes	1.080	TMC
Total Allocation under Cauvery Basin	4	TMC
Balance water available for Use	1.565	TMC

KIADB													
INDUSTRIAL AREAS IN KRISHNA BASIN													
SI No	District/ Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water	Treated Water	Allocation in MLD only for Fresh water	Source	Remarks				
	Krishna Basin												
1	Tumkuru	Vasanthanarasapura Industrial Area 1st Phase	4107.67	20.50	10.05	10.25	1.55	Hemavathi	a. Fresh Water Source - 1.55 MLD allocated from Hemavathi , & 15.54 MLD is allocated from Yetthinaholle, Balance 24.08 MLD additional requirement Treated Water 20 MLD Treated Water is proposed to be utilised for Vasanthanarasapura Phase 1, 2 ,3 (5 MLD) and Vasanthanarasapura Phase 4 5 6 (10 MLD) and Sira IA (5 MLD)				
2		Vasanthanarasapura Industrial Area 2nd Phase											
3		Vasanthanarasapura Industrial Area 2nd Phase (Sub Layout)											
4		Vasanthanarasapura Industrial Area 3rd Phase											
5		Vasanthanarasapura Industrial Area 3rd Phase (Sub Layout)											
6		Vasanthanarasapura Industrial Area 1st Phase (Annexe)											
7		Sira IA	844.92	5.00	2.50	2.5	15.51	Yetthinaholle					
8		Vasanthanarasapura Industrial Area 4th Phase	9627.00	97.00	67.00	30.00							
9		Vasanthanarasapura Industrial Area 5th Phase											
10		Vasanthanarasapura Industrial Area 6th Phase											
11	Chitradurga	Kelagote Industrial Area	75.14	0.50	0.50	0.00		Borewell					
12	Davanagere	Davanagere I.A.	94.50	0.50	0.50	0.00		Borewell					
13		Karur	102.76	0.56	0.56	0.00		Borewell					
14		Haralapura 1 st Phase	56.97	0.35	0.35	0.00		Borewell					
15		Hanagawadi 1 st Phase	50.00	0.25	0.25	0.00		Borewell					
16		Kurubarahalli-Sarathi 1 st Stage	290.35	2.25	2.25	0.00		Tungabhadra River	Proposal sent to Govt. for Allocation				
17		Kurubarahalli-Sarathi 2 nd Stage	336.05	2.25	2.25	0.00							
18	Shivamogga	Machenahalli	381.00	2.19	2.19	0.00	1 MGD (4.54 MLD)	Badra	Fresh Water Source- Badra River 15 Km Away				
19		Nidige Industrial Area	57.00										
20		Mandli Kallur	42.13	0.21	0.21	0.00							
21		Auto Complex	19.35	0.10	0.10	0.00							
22		Sanda, (Shikaripura)	208.00	1.04	1.04	0.00							
23		Mangalabeesu	10.35	0.05	0.05	0.00							
24		Devakatikoppa	464.24	2.32	2.32	0.00							
25	Yadgiri	Kadechur I A 1st Phase	3284.28	16.42	16.42	0.00	24.5	Bhima River	Source of Water from Bhima River (Gudur-Joladadgi Barrage Back water)				
26		Kadechur I A 2nd Phase				0.00		Bhima River					
27		Mundargi I A	22.05	0.11	0.11	0.00		Borewell	Source of Water from KIADB Borewells				
28	Kalaburgi	Nandur Industrial Area 1st Phase	620	3.000	3.000	0.00			Fresh Water Proposed Samurthi Barrage 35-40 Kms				
29		Nandur Industrial Area 2nd Phase	198.36	1.000	1.000	0.00							
30		Nandur Industrial Area 3rd Phase (as Per Project Report)	595.22	3.000	3.000	0.00							
31		Kapnoor Industrial Area 1st Phase	110	0.55	0.55	0.00							
32		Kapnoor Industrial Area 2nd Phase	208.63	1.00	1.00	0.00							
33		Kapnoor Industrial Area 3rd Phase	187	1	1	0.00							
34	Ballari	Mundargi 1st Stage	52.59	0.25	0.25	0.00	Nil		Handed over to corporation Ballari				
35		Mundargi 2nd Stage	166.38	1.00	1.00	0.00							
36		Mundargi 3rd Stage	88.84	0.50	0.50	0.00							
37		Mundargi 4th Stage	64.26	0.30	0.30	0.00			Handed over to corporation Ballari				
38		Ananthapura Road	21.79	0.1	0.1	0.00							
39		Kuduthini 1st phase	601.27	10.00	10.00	0.00		Surface					
40		Women Entrepreneurs park	43.91			0.00		Proposed 20 MLD for allocation from TB Dam					
41		Kuduthini 2nd phase	538.43			0.00							
42		Kuduthini 3rd phase	670.94			0.00							
43	Vijaynagara	Sanjeevrayanakote	154	0.50	0.50	0.00							
44		Sankalapura	102.51	0.65	0.65	0.00		Bore					
45			26.1			0.00		Bore					
46	Belagavi	KANGRALI	58.79	0.30	0.30		18.2		Directly supplied by KUWS & DB to End Users				
47		KAKATI	74.25	0.35	0.35	0		Raw Water	Source from KUWS & DB				
48		HONAGA	209.50	1.00	1.00	0			Bore Well Source				
49		GOKAK	109.18	0.55	0.55	0			Bore Well Source				
50		KANABARGI	267.00	1.35	1.35	0			Source from KUWS & DB				
51		KITTUR	433.19	2.50	2.50	0			Bore Well Source				
52		BK KANGRALI SUB-LAYOUT	17.50	0.10	0.10	0			Newly Formed IA				
53		KANAGALA Phase 1 Phase 2	1394.20	7.00	7.00	0		Raw Water	Own Source from Hidkal Dam Reservoir				
54	Bagalkote	NAVANAGAR AGROTECH PARK	157.50	0.80	0.80	0			Bore Well Source				
55		ASANGI	42.10	0.20	0.20	0			Bore Well Source				
56		BALAKUNDI	94.03	0.50	0.50	0			Newly Formed IA				
57	Vijaypur	MAHALBHAGAYAT	218.16	1.00	1.00				Source from KUWS & DB				
58		ALIYABAD BLOCK I	158.16	0.80	0.80				Source from KUWS & DB				
59		ALIYABAD BLOCK II	117.51	0.60	0.60				Source from KUWS & DB				
60		MULAWAD PHASE I	564.50	10.00	10	0.00			Own Source from Krishna River for 18.20 MLD				
61		MULAWAD PHASE II	555.86										
62		MULAWAD PHASE III	738.87						Newly Formed IA				
63		Vijayapura Airport	730.00	3.50	3.50	0.00							
64	Koppal	Madabhavi, Buranapur & Aliyabad IA	1750.00	8.50	8.50	0.00			Fresh Water Source Krishna River				
65		Kustagi I.A.	38.08	0.20	0.20	0.00		Bore					
66		Kydiduppa I.A	270.03	0.50	0.50	0.00		Bore					

67	Raichur	Raichur Industrial Area	155.88	0.75	0.75	0.00	10	CMC (Krishna)	Fresh Water Additional 11 MLD proposed for Allocation from CMC (Krishna River) Treated Water Proposed to be utilised from 4 MLD TTP from Housing Layout
68		Deosugur Industrial Area	214.86	1.00	1.00	0.00			
69		Raichur Growth Centre Industrial Area	1745.31	8.50	8.50	0.00			
70		Manvi General Industrial Area	48.00	0.30	0.30	0.00			
71		Manvi Auto Nagar Industrial Area	11.70			0.00			
72		Yarmaras Industrial Area	41.62	0.25	0.25	0.00			
73		Housing Layout	353.32	1.80	0.00	1.80			
74		Manvi	51.37	0.25	0.25	0.00			
75		Chandrabhanda	690.13	3.5	3.5	0.00			
76		Vadluru	260.38	1.5	1.5	0.00			
77		Kadangadoddi	1070.30	5	5	0.00			
78	Chikkamangaluru	Amble Industrial Area	144.47	1	1	0	Borewell		
79		Nagadiyath Kavala	236.95	1	1	1.8			
80	Dharwad	Belur	2065.48	10.00	10.00	0.00	12	Malaprabha	Water Source Malaprabha River Near Budhihal
81		Tata Motors Tata Hitachi Tata Marcopolo	684.00	3.50	3.50	0.00			Water Source Malaprabha River Near Budhihal
82		Lakkammanahalli	71.23	0.50	0.50	0.00			water Source Borewell
83		Sattur	52.37	0.30	0.30	0.00			water Source Borewell
84		Rayapur 1st and 2nd Phase	370.28	1.90	1.90	0.00			water Source Borewell
85		Tarihal	293.74	1.50	1.50	0.00			water Source Borewell
86		Tarihal Sub-Layout	19.05	0.10	0.10	0.00			water Source Borewell
87		Kotur-Belur EMC	593.00	3.00	3.00	0.00	45	Ghataprabha	Water Source Malaprabha River Near Budhihal
88		Mummigatti	509.48	2.50	2.50	0.00			Water Source Malaprabha River Near Budhihal
89		Gamanagatti 1st and 2nd Phase	387.95	2.00	2.00	0.00			water Source Borewell
90		Gamanagatti Women's Park	30.00	0.20	0.20	0.00			water Source Borewell
91		Kelageri SC/ST Cluster	20.00	0.10	0.10	0.00			water Source Borewell
92		Mummigatti Narendra Housing Area	111.00	0.50	0.50	0.00			Water Source Malaprabha River Near Budhihal
93		Kelageri Housing Area	20.00	0.10	0.10	0.00			water Source Borewell
94		Gamanagatti Housing Area(Site)	28.06	0.15	0.15	0.00			water Source Borewell
95		BMIC-Dharwad Node	6042.26	30.00	30.00	0.00			Water Source Ghataprabha River Near Gataprabha
96	Gadag	Narasapur	162.75	0.80	0.80	0.00			water Source Borewell
97	Haveri	Magodu	100.00	0.50	0.50	0.00			water Source Borewell

Sl No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation	Remarks				
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water	Quantity	Source						
1	2	3	4	5	6	7=5+6	8	9	10=9+8	11	12	13	14				
1	Bengaluru Rural	Dabaspete 1st and 2nd Phase		343		343	2.74	1.37	1.37	Nil	TGR	Nil	Proposal to lift 15 MLD water from Tippagondanahalli Reservoir				
2		Dabaspete 3rd Phase (Sompura1st & 2nd)		1321		1321	10.57	5.28	5.28								
3		Dabspete 4th Phase		844		844	6.75	3.38	3.38								
4		Dabspete 5th Phase		1040		1040	8.32	4.16	4.16								
5		Oblapura & MMLP		842		842	8.42	4.21	4.21								
6		DB pura General Industrial Area		352		352	1.76	1.76	0.00								
7		Appearal Park 1st and 2nd phase		453		453	2.27	2.27	0.00								
8		Devanahalli General IA 1st phase		986		986	20.00	15.00	5.00								
			Devanahalli General IA 2nd phase		1200	1200	15.00	10.00	5.00								
9	Ramanagara	Bidadi 1st Phase		862.31		862.31	7.50	5.00	2.50	13.5	BWSSB						
10		Bidadi 2nd Phase-Sector-1		183.13		183.13	7.00										
11		Bidadi 2nd Phase-Sector-2		452.81		452.81		5.00	2.00								
12		Harohalli 1st Phase		250.39		250.39	3.00	2.00	1.00								
13		Harohalli 2nd Phase		919.16		919.16	12.00	8.00	4.00								
14		Harohalli 3rd Phase		1210.90		1210.90	15.00	10.00	5.00								
		Women Entrepreneur's Park Harohalli 3rd Phase					0.75										
				60.87		60.87		0.50	0.25								
15			Harohalli 4th Phase		352.36		352.36	1.50	1.00			0.50					
		Harohalli 5th Phase		912.13		912.13	13.00	8.00	5.00								
16	Tumkuru	Antharasanahalli Industrial Area, 1st Phase		208.00	0.00	208.00	1.00	0.50	0.5								
17		Antharasanahalli Industrial Area, 2nd Phase		256.84	0.00	256.84	1.50	0.75	0.75								
18		Sathyamangala Industrial Area		54.04	0.00	54.04	0.25	0.13	0.125								
19		Hirehalli Industrial Area		160.70	0.00	160.70	1.00	0.50	0.5								
20	Mysuru / Mysuru	Hebbal	-	1603.00	0.00	1603.00	8.02	8.02	0.00	36.00	Cauvery	7.27	Source Cauvery with an allocation of 36.00 MLD (Near Belagola & Srirangapatna)				
21	Mysuru / Mysuru	Hebbal Weavers colony	-		0.00												
	Mysuru / Mysuru	Hebbal Housing Area	-		0.00												
23	Mysuru / Mysuru	Hootagally	-	426.00	0.00	426.00	2.13	2.13	0.00								
24	Mysuru / Mysuru	Belavadi	-	238.00	0.00	238.00	1.19	1.19	0.00								
25	Mysuru / Mysuru	Koorgally	-	472.00	0.00	472.00	2.36	2.36	0.00								
26	Mandya / Srirangapatna	Hebbal 2nd Phase	-	193.46	0.00	193.46	0.97	0.97	0.00								
27	Mysuru / Mysuru	Kadakola	-	255.65	0.00	255.65	1.28	1.28	0.00								
	Mysuru / Mysuru	Kochanahalli IA(EMC)	-	0.00	235.54	235.54	1.18	1.18	0.00								
29	Mysuru / Nanjangud	Nanjangud	-	535.00	0.00	535.00	2.68	2.68	0.00	22.5	Kabini	4.25	Source - Kabini with an allocation of 22.5 MLD				
30	Mysuru / Nanjangud	Thandya	-	144.00	0.00	144.00	0.72	0.72	0.00								
31	Mysuru / Nanjangud	Adakanahalli	-	538.22	0.00	538.22	2.69	2.69	0.00								
32	Mysuru / Nanjangud	Immavu	-	500.00	0.00	500.00	2.50	2.50	0.00								
	Mysuru / Nanjangud	Women's En. Park -1	-	48.03	0.00	48.03	0.24	0.24	0.00								
	Mysuru / Nanjangud	Women's En. Park -2	-	68.64	0.00	68.64	0.34	0.34	0.00								
35	Mysuru / Nanjangud	Thandya 2nd Phase	-	626.70	0.00	626.70	3.13	3.13	0.00								
36	Mysuru / Nanjangud	Thandya 2nd Stage 1st Phase	-	68.00	0.00	68.00	0.34	0.34	0.00								
	Mysuru / Nanjangud	-	Sinduvallipura	0.00	449.00	449.00	2.25	2.25	0.00								
	Chamarajanagara / Chamarajanagara	Badanguppe - Kellamballi Phase-1	-	1460.47	0.00	1460.47	7.30	7.30	0.00								
39	Chamarajanagara / Chamarajanagara	Badanguppe - Kellamballi Phase-2	-	0.00	907.06	907.06	4.54	4.54	0.00								
40	Mandya/ Maddur	Somanahally	-	154.00	0.00	154.00	0.77	0.77	0.00		Borwell						
41	Mandya/ Maddur	Gejjalagere	-	78.30	0.00	78.30	0.39	0.39	0.00		Borwell						
42	Mandya/ Mandya	Tubinakere	-	141.00	0.00	141.00	0.71	0.71	0.00		KUWSSB Mandya						

43	Kodagu/Kushalnagara	Kushalnagar	-	250.00	0.00	250.00	1.25	1.25	0.00		Borwell		
	Mandya	-	Kuduragundi	0.00	109.00	109.00	0.55	0.55	0.00				
	Mandya / Mallavalli	-	Bachanahalli	0.00	1249.00	1249.00	6.25	6.25	0.00				
44	Hassan	Hassan Growth Centre (Including Sublayouts & SEZ's)		2245.09	0	2245.09	11	11	0	4.95 MGD (22.5 MLD)	Hemavath i		
45		B.Katihalli		102.97	0	102.97	0.5	0.5	0				
46		Holenarasipura		28.95	0	28.95	0.1	0.1	0				
47		Thimmanahalli		75.07	0	75.07	0.35	0.35	0				
48			Hassan Industrial Area	0	1057.6	1057.6	10.55	10.55	0				
49			Doothanuru Kaval	0	177.49	177.49	1	1	0	Borewell			
50			Mylanahalli	0	142.16	142.16	0.7	0.7	0				
				Total Area in Acres		26466.8	205.02935		Total Water in MLD				

Requirement of Water in KIADB Industrial Areas

ABSTRACT - BASIN & DISTRICT WISE

SI No	District/ Taluk	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water in MLD	Treated Water in MLD	Allocation in MLD only for Fresh water	Deficit Fresh Water in MLD	Deficit Fresh Water in TMC
	South Pennar Basin							
1	Bengaluru Rural	9567.15	128.49	73.62	54.87	19.39	54.23	0.699
2	Kolar	4216.07	56.00	27.00	29.00	0	27.00	0.348
3	Chikkaballapura	2500.00	20.00	10.00	10.00	0	10.00	0.129
	Total	16283.22	204.49	110.62	93.87	19.39	91.23	1.176

0.2516

Fresh Water Requirement	1.176	TMC
Present Water Supply Schemes	0.252	TMC
Balance water available for Use	0.924	TMC

Requirement of Water in KIADB Industrial Areas

ABSTRACT - BASIN & DISTRICT WISE

SI No	District/ Taluk	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water in MLD	Treated Water in MLD	Allocation in MLD only for Fresh water	Deficit Fresh Water in MLD	Deficit Fresh Water in TMC
North Pennar Basin								
1	Chikkabalapura	5527.00	49.00	26.00	23.00	0.00	26.00	0.335
	Total	5527.00	49.00	26.00	23.00	0.00	26.00	0.335

0.0000

Fresh Water Requirement	0.335	TMC
Present Water Supply Schemes	0.000	TMC
Balance water available for Use	0.335	TMC

Requirement of Water in KIADB Industrial Areas

ABSTRACT - BASIN & DISTRICT WISE

SI No	District/ Taluk	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water in MLD	Treated Water in MLD	Allocation in MLD only for Fresh water	Deficit Fresh Water in MLD	Deficit Fresh Water in TMC
	Palar Basin							
1	Kolar	1825.07	17.00	8.50	8.50	0.00	8.50	0.110
2	Chikkaballapura	1773.00	28.00	14.00	14.00	0.00	14.00	0.180
	Total	3598.07	45.00	22.50	22.50	0.00	22.50	0.29

0.0000

Fresh Water Requirement	0.290	TMC
Present Water Supply Schemes	0.000	TMC
Balance water available for Use	0.290	TMC

Requirement of Water in KIADB Industrial Areas									
ABSTRACT - BASIN WISE									
SI No	Basins	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water in MLD	Fresh Water in TMC	Treated Water in MLD	Allocation in MLD only for Fresh water	Deficit Fresh Water in MLD	Deficit Fresh Water in TMC
	South pennar Basin, North Pennar Basin, Palar Basin.								
1	South Pennar Basin	16283.22	204.49	110.62	1.43	93.87	19.39	91.23	1.18
2	North Pennar Basin	5527.00	49.00	26.00	0.34	23.00	0.00	26.00	0.34
3	Palar Basin	3598.07	45.00	22.50	0.29	22.50	0.00	22.50	0.29
	Total	25408.29	298.49	159.12	2.05	139.37	19.39	139.73	1.80
				1.435302323			0.25		
	Fresh Water Requirement			1.80	TMC				
	Present Water Supply Schemes			0.25	TMC				
	Balance water available for Use			1.55	TMC				

Total Requirement of Water in KIADB Industrial Areas.

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Basin	Allocation in MLD only for Fresh water		Present Utilisation
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water		Quantity	Source	
1	2	3	4	5	6	7=5+6	8	9	10=9+8		11	12	13

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Basin	Allocation in MLD only for Fresh water		Present Utilisation
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water		Quantity	Source	
1	Bengaluru Rural/ Devanahalli	Hitech Defence & Aerospace Park 1st phase		3009		3009	30.09	15.05	15.05	South Pennar	19.39	Yeethinaha olle	Nil
2		Hitech Defence & Aerospace Park 2nd phase		1200		1200	12.00	6.00	6.00	South Pennar			
3		Devanahalli General IA 1st phase		986		986	20.00	15.00	5.00	South Pennar			
5			Hitech Defence & Aerospace Park 3rd phase		1770	1770	17.70	8.85	8.85	South Pennar			
6			Devanahalli General IA 2nd phase		1200	1200	15.00	10.00	5.00	South Pennar			
		Sub Total (Devanahalli)		5195	2970	8165	94.79	54.90	39.90		19.39	0	0
1	Bengaluru Rural/ Hoskote	Hoskote IA		402.15		402.15	8.00	4.00	4.00	South Pennar	Nil	Nil	Nil
2			Hoskote (Proposed)		1000	1000				South Pennar			
		Sub Total (Hoskote)		402.15	1000	1402.15	8.00	4.00	4.00		0		
Bangalore Rural District Total				5597.15	3970	9567.15	102.79	58.895	43.895	19.39			
For Future Development							25.70	14.72	10.97				
Total (Bengaluru Rural)				5597.15	3970	9567.15	128.4875	73.61875	54.86875	19.39			

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Basin	Allocation in MLD only for Fresh water		Present Utilisation
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water		Quantity	Source	
1	Kolar	Malur 1st, 2nd, 3rd and 4th Phase		917	0	917	10.00	5.00	5.00	South Pennar	Nil	Nil	Nil
2		Bhavanahalli		0	722.05	722.05	20.00	10.00	10.00	South Pennar			
3		Jakkasandra		627.45	0	627.45	6.00	3.00	3.00	South Pennar			
4		Jakkasandra II Phase (Mindahalli)		335.41	0	335.41	2.00	1.00	1.00	South Pennar			
5			Malur (Proposed)	0	1614.16	1614.16	18.00	8.00	10.00	South Pennar			
		Total (Kolar)		1879.86	2336.21	4216.07	56.00	27.00	29.00		0		
8			Chikkaballapura Shidlagatta	0.0	2500.0	2500	20.00	10.00	10.00	South Pennar			
		Total (Chikkaballapura)		0	2500	2500	20.00	10.00	10.00		0		
		Grand Total		7477.01	8806.21	16283.22	204.49	110.62	93.87		19.39		

Net Requirement for Fresh Water upto year 2075 = 261.88 -22.14 = 239.74 MLD

Remarks
14

[illegible]

Remarks
Fresh Water Probable Source- Yettinaholle Treated Water 40 MLD TTP at Narasapura Kolar

Total Requirement of Water in KIADB Industrial Areas.

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Basin	Allocation in MLD only for Fresh water		Present Utilisation
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water		Quantity	Source	
1	2	3	4	5	6	7=5+6	8	9	10=9+8		11	12	13
1	Chikkabalapur a	Gowribidanur 1st, 2nd, 3rd		1495.0	0.0	1495	25.00	15.00	10.00	North Pennar	NIL	-	-
2			Gowribidanur (Proposed)	0.0	1500.0	1500				North Pennar			
3		Mastenahalli 1st & 2nd Phase		932.0	0.0	932	16.00	8.00	8.00	North Pennar		-	-
4			Mastenahalli (Proposed)	0.0	600.0	600				North Pennar			
6			Bagepalli		0.0	1000.0	1000	8.00	3.00	5.00		North Pennar	
		Total (Chikkaballapura)		2427	3100	5527	49.00	26.00	23.00		0		
		Grand Total		2427.00	3100.00	5527.00	49.00	26.00	23.00		0.00		

Net Requirement for Fresh Water upto year 2075 = 261.88 -22.14 = 239.74 MLD

Remarks
14
Probable Source -Yettinaholle

Total Requirement of Water in KIADB Industrial Areas.

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Basin	Allocation in MLD only for Fresh water		Present Utilisation	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water		Quantity	Source		
1	2	3	4	5	6	7=5+6	8	9	10=9+8		11	12	13	14
6	Kolar	Narasapura-Kolar		700.75	0	700.75	6.00	3.00	3.00	Palar				
7		Vemagal		666.41	0	666.41	6.00	3.00	3.00	Palar				
8		Vemagal II Phase		457.91	0	457.91	5.00	2.50	2.50	Palar				
		Total (Kolar)		1825.07	0	1825.07	17.00	8.50	8.50		0			
5	Chikkaballapura		Srinivasapura Taluk (Proposed)	0.0	1273.0	1273	6.00	3.00	3.00	Palar		-	-	
7			Chintamani	0.0	500.0	500	5.00	2.50	2.50	Palar		-	-	
		Total (Chikkaballapura)		0	1773	1773	11.00	5.50	5.50		0			
		Grand Total		1825.07	1773.00	3598.07	28.00	14.00	14.00		0.00			

Net Requirement for Fresh Water upto year 2075 = 261.88 - 22.14 = 239.74 MLD

KIADB									
INDUSTRIAL AREAS IN WESTREN FLOW BASIN									
Sl No	District/ Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water	Treated Water	Allocation in MLD only for Fresh water	Source	Remarks
Westren flow Basin									
1	Dakshina Kannada	Karnad	65.85	0.33	0.33	0.00		1 MGD (4.54 MLD)	Additional Requirement of 5.79 MLD
2		E.P.I.P.	205.16	4.54	4.54	0.00			
3		Plastic Park, EPIP	104.28						
4		Kolluru, Balakunje and Ulepadi	1091	5.46	5.46	0.00	1 MGD (4.54 MLD)		
5		IT-SEZ & Non-SEZ	517.93	4.54	4.54	0			
6		Canara Industrial Area	585						
7	Uttar Kannada	Shirwad	34.14	0.20	0.20	0.00		water Source Borewell	
8		Ambewadi Autonagar	5.00	0.02	0.02	0.00		water Source Borewell	

KIADB									
INDUSTRIAL AREAS IN GODAVARI BASIN									
SI No	District/ Taluk	Industrial Area	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water	Treated Water	Allocation in MLD only for Fresh water	Source	Remarks
Godavari BASIN									
1	Bidar	Naubad Housing Area	72	0.30	0.30	0.00	Nil		Handed over to Municipal Corporation
2		Naubad Autonagar	28	0.14	0.14	0.00			
3		Naubad Industrial Area	93.53	0.50	0.50	0.00			
4		Kolhar Industrial Area 1st Phase	895.98	4.50	4.50	0.00		Karanja Reservoir	
5		Kolhar Industrial Area 2nd Phase	600	3.00	3.00	0.00			
6		Humnabad Industrial Area	482.3	2.50	2.50	0.00			
7		Basavakalyan Industrial Area	96.56	0.50	0.50	0.00			

CAUVERY BASIN ABSTRACT DISTRICT WISE						
SI No	District/ Taluk	Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Deficit Fresh Water	Remarks
			Fresh Water	Treated Water		
1	2	8	9	10=9+8		14
1	Bangalore Rural District	96.23	54.81	41.42		
2	For Future Development	24.06	13.70	10.36		
3	Bengaluru Rural	120.29	68.51	51.78	68.51	
4	Ramanagara	59.75	39.50	20.25	39.50	
5	Mysore , Mandya , Chamarajnagara	53.75	53.75		0.00	Source : Cauvery with an allocation of 36.00 MLD (Near Belagola & Srirangapatana) Source : Kabini with an allocation of 22.5 MLD
6	Tumakuru	3.75	1.88	1.88	1.88	
7	Hassan	24.20	24.20	0.00	1.70	Source- Hemavathi with an allocation of 22.5 MLD , therefore Additional Water not required.
8	Chikkamagaluru	1.00	1.00	0.00	1.00	
		262.74	188.84	73.90	112.59	

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD				Bifurcation of Required Water in MLD		Basin	Allocation in MLD only for Fresh water		Present Utilisation	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres					Fresh Water	Treated Water		Quantity	Source		
1	2	3	4	5	6	7=5+6	8				9	10=9+8	Cauvery Basin	11	12	13	14
1	Bengaluru Rural/ Nelamangala Taluk	Dabaspete 1st and 2nd Phase		343		343	2.74	0.00			1.37	1.37	Cauvery Basin	Nil	TGR	Nil	Proposal to lift 15 MLD water from Tippagondanahalli Reservoir
2		Dabaspete 3rd Phase (Sompura1st & 2nd)		1321		1321	10.57	0.00			5.28	5.28	Cauvery Basin				
3		Dabspete 4th Phase		844		844	6.75	0.00			3.38	3.38	Cauvery Basin				
4		Dabspete 5th Phase		1040		1040	8.32	0.00			4.16	4.16	Cauvery Basin				
5		Oblapura & MMLP		842		842	8.42	0.00			4.21	4.21	Cauvery Basin				
7			KHIR		2200	2200	30.00	0.00			15.00	15.00	Cauvery Basin	Nil		Nil	
8			Sompura 28(4)		520	520	5.20	0.00			2.60	2.60	Cauvery Basin				
9			Hanumanthapura, Bidluru, Kodipalya 28(1)		495	495	4.95	0.00			2.48	2.48	Cauvery Basin				
		Sub Total (Nelamangala)		4390	3215	7605	76.95	0.00			38.48	38.48		0.00	0	0	0
1	Bengaluru Rural/ Doddaballapura Taluk	DB pura General Industrial Area		352		352	1.76	0.00			1.76	0.00	Cauvery Basin	2.75	BWSSB Yelahanka	Nil	a. Fresh Water Source - 0.5 MGD allocated from BWSSB Pumping Station Yelahanka vide Oder dt:07.02.2004 b. Treated Water 5 MLD TTP water is to be drawn from exitsing 40 MLD TTP, in Hitech Defence & Aerospace Park 1st phase.
2		Appearal Park 1st and 2nd phase		453		453	2.27	0.00			2.27	0.00	Cauvery Basin				
3		Obedenahalli		697		697	3.49	0.00			3.49	0.00	Cauvery Basin				
4		Adinarayana Hosahalli 1st Phase		195		195	0.98	0.00			0.98	0.00	Cauvery Basin				
5		Adinarayana Hosahalli 2nd Phase		981		981	10.79	0.00			7.85	2.94	Cauvery Basin				
		Sub Total (Doddaballapura)		2678	0.00	2678	19.28	0.00			16.33	2.94		2.75	0	0	0
	Bangalore Rural District Total			7068	3215	10283	96.23				54.81	41.42		2.75			
	For Future Development						24.06				13.70	10.36					
	Total (Bengaluru Rural)			7068	3215	10283	120.2875				68.5125	51.775		2.75			

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD				Bifurcation of Required Water in MLD		Basin	Allocation in MLD only for Fresh water		Present Utilisation	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres					Fresh Water	Treated Water		Quantity	Source		
	Ramanagara	Bidadi 1st Phase		862.31		862.31	7.50	0.00			5.00	2.50	Cauvery Basin	13.5	BWSSB		
		Bidadi 2nd Phase-Sector-1		183.13		183.13	7.00	0.00			5.00	2.00	Cauvery Basin				
		Bidadi 2nd Phase-Sector-2		452.81		452.81							Cauvery Basin				
		Harohalli 1st Phase		250.39		250.39	3.00	0.00			2.00	1.00	Cauvery Basin				
		Harohalli 2nd Phase		919.16		919.16	12.00	0.00			8.00	4.00	Cauvery Basin				
		Harohalli 3rd Phase		1210.90		1210.90	15.00	0.00			10.00	5.00	Cauvery Basin				
		Women Entrepreneur's Park Harohali 3rd Phase		60.87		60.87	0.75	0.00			0.50	0.25	Cauvery Basin				
		Harohalli 4th Phase		352.36		352.36	1.50	0.00			1.00	0.50	Cauvery Basin				
		Harohalli 5th Phase		912.13		912.13	13.00	0.00			8.00	5.00	Cauvery Basin				
		Total (Ramanagara)		5204.06		5204.06	59.75				39.5	20.3					
	Tumakuru	Antharasanahalli Industrial Area, 1st Phase		208.00	0.00	208.00	1.00	0.00			0.50	0.5	Cauvery Basin				
		Antharasanahalli Industrial Area, 2nd Phase		256.84	0.00	256.84	1.50	0.00			0.75	0.75	Cauvery Basin				
		Sathyamangala Industrial Area		54.04	0.00	54.04	0.25	0.00			0.13	0.125	Cauvery Basin				
		Hirehalli Industrial Area		160.70	0.00	160.70	1.00	0.00			0.50	0.5	Cauvery Basin				
19			Total (Tumakuru)	679.58	0.00	679.58	3.75	0.00			1.88	1.88					
1	Mysuru / Mysuru	Hebbal	-	1603.00	0.00	1603.00	8.02	0.00			8.02	0.00	Cauvery Basin				
2	Mysuru / Mysuru	Hebbal Weavers colony	-		0.00								Cauvery Basin				

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD				Bifurcation of Required Water in MLD		Basin	Allocation in MLD only for Fresh water		Present Utilisation	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres					Fresh Water	Treated Water		Quantity	Source		
3	Mysuru / Mysuru	Hebbal Housing Area	-		0.00								Cauvery Basin	36.00	Cauvery	7.27	Source Cauvery with an allocation of 36.00 MLD (Near Belagola & Srirangapatana)
4	Mysuru / Mysuru	Hootagally	-	426.00	0.00	426.00	2.13	0.00			2.13	0.00	Cauvery Basin				
5	Mysuru / Mysuru	Belavadi	-	238.00	0.00	238.00	1.19	0.00			1.19	0.00	Cauvery Basin				
6	Mysuru / Mysuru	Koorgally	-	472.00	0.00	472.00	2.36	0.00			2.36	0.00	Cauvery Basin				
7	Mandya / Srirangapatna	Hebbal 2nd Phase	-	193.46	0.00	193.46	0.97	0.00			0.97	0.00	Cauvery Basin				
8	Mysuru / Mysuru	Kadakola	-	255.65	0.00	255.65	1.28	0.00			1.28	0.00	Cauvery Basin	22.5	Kabini	4.25	Source - Kabini with an allocation of 22.5 MLD
9	Mysuru / Mysuru	Kochanahalli IA(EMC)	-	0.00	235.54	235.54	1.18	0.00			1.18	0.00	Cauvery Basin				
10	Mysuru / Nanjangud	Nanjangud	-	535.00	0.00	535.00	2.68	0.00			2.68	0.00	Cauvery Basin				
11	Mysuru / Nanjangud	Thandya	-	144.00	0.00	144.00	0.72	0.00			0.72	0.00	Cauvery Basin				
12	Mysuru / Nanjangud	Adakanahalli	-	538.22	0.00	538.22	2.69	0.00			2.69	0.00	Cauvery Basin				
13	Mysuru / Nanjangud	Imnavu	-	500.00	0.00	500.00	2.50	0.00			2.50	0.00	Cauvery Basin				
14	Mysuru / Nanjangud	Women's En. Park -1	-	48.03	0.00	48.03	0.24	0.00			0.24	0.00	Cauvery Basin				
15	Mysuru / Nanjangud	Women's En. Park -2	-	68.64	0.00	68.64	0.34	0.00			0.34	0.00	Cauvery Basin				
16	Mysuru / Nanjangud	Thandya 2nd Phase	-	626.70	0.00	626.70	3.13	0.00			3.13	0.00	Cauvery Basin				
17	Mysuru / Nanjangud	Thandya 2nd Stage 1st Phase	-	68.00	0.00	68.00	0.34	0.00			0.34	0.00	Cauvery Basin				
18	Mysuru / Nanjangud	-	Sinduvallipura	0.00	449.00	449.00	2.25	0.00			2.25	0.00	Cauvery Basin				
19	Chamarajanagara / Chamarajanagara	Badanguppe - Kellamballi Phase-1	-	1460.47	0.00	1460.47	7.30	0.00			7.30	0.00	Cauvery Basin				
20	Chamarajanagara / Chamarajanagara	Badanguppe - Kellamballi Phase-2	-	0.00	907.06	907.06	4.54	0.00			4.54	0.00	Cauvery Basin				
21	Mandya/ Maddur	Somanahally	-	154.00	0.00	154.00	0.77	0.00			0.77	0.00	Cauvery Basin		Borwell		
22	Mandya/ Maddur	Gejjalagere	-	78.30	0.00	78.30	0.39	0.00			0.39	0.00	Cauvery Basin		Borwell		
23	Mandya/ Mandya	Tubinakere	-	141.00	0.00	141.00	0.71	0.00			0.71	0.00	Cauvery Basin		KUWSSB Mandya		
24	Kodagu/Kushalnagara	Kushalnagar	-	250.00	0.00	250.00	1.25	0.00			1.25	0.00	Cauvery Basin		Borwell		

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD				Bifurcation of Required Water in MLD		Basin	Allocation in MLD only for Fresh water		Present Utilisation	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres					Fresh Water	Treated Water		Quantity	Source		
25	Mandya	-	Kuduragundi	0.00	109.00	109.00	0.55	0.00			0.55	0.00	Cauvery Basin				
26	Mandya / Mallavalli	-	Bachanahalli	0.00	1249.00	1249.00	6.25	0.00			6.25	0.00	Cauvery Basin				
			Total (Mysore, Mandya , Chamarajnagar, Kodagu)	7800.47	2949.6	10750.07	53.75				53.75						
1	Hassan	Hassan Growth Centre (Including Sublayouts & SEZ's)		2245.09	0	2245.09	11	0.00			11	0	Cauvery Basin	4.95 MGD (22.5 MLD)	Hemavathi		Source- Hemavathi with an allocation of 22.5 MLD , therefore Additional Water not required.
2		B.Katihalli		102.97	0	102.97	0.5	0.00			0.5	0	Cauvery Basin				
3		Holenarasipura		28.95	0	28.95	0.1	0.00			0.1	0	Cauvery Basin				
4		Thimmanahalli		75.07	0	75.07	0.35	0.00			0.35	0	Cauvery Basin				
5			Hassan Industrial Area	0	1057.6	1057.6	10.55	0.00			10.55	0	Cauvery Basin	Borewell			
6			Doothanuru Kaval	0	177.49	177.49	1	0.00			1	0	Cauvery Basin				
7			Mylanahalli	0	142.16	142.16	0.7	0.00			0.7	0	Cauvery Basin				
	Total (Hassan)			2452.08	1377.25	3829.33	24.2				24.2	0					
1	Chikkamangaluru	Amble Industrial Area		144.47	0	144.47	1	0.00			1	0	Cauvery Basin	Borewell			
	Total (Chikkamagaluru)			144.47	0	144.47	1				1	0					
		Grand Total		23348.66	7541.85	30890.51	262.74	-23085.92			188.84	73.90		2.75			

CAUVERY BASIN - PROPOSED LIFTING SCHEME											
SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Basin	
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water		
1	2	3	4	5	6	7=5+6	8	9	10=9+8		
1	Bengaluru Rural/ Nelamangala Taluk	Dabaspete 1st and 2nd Phase		343		343	2.74	1.37	1.37	Cauvery Basin	
2		Dabaspete 3rd Phase (Sompura1st & 2nd)		1321		1321	10.57	5.28	5.28	Cauvery Basin	
3		Dabspete 4th Phase		844		844	6.75	3.38	3.38	Cauvery Basin	
4		Dabspete 5th Phase		1040		1040	8.32	4.16	4.16	Cauvery Basin	
5		Oblapura & MMLP		842		842	8.42	4.21	4.21	Cauvery Basin	
7			KHIR			2200	2200	30.00	15.00	15.00	Cauvery Basin
8				Sompura 28(4)		520	520	5.20	2.60	2.60	Cauvery Basin
9				Hanumanthapura, Bidluru, Kodipalya 28(1)		495	495	4.95	2.48	2.48	Cauvery Basin
			Sub Total (Nelamangala)		4390	3215	7605	76.95	38.48	38.48	
1	Bengaluru Rural/ Doddaballapura Taluk	DB pura General Industrial Area		352		352	1.76	1.76	0.00	Cauvery Basin	
2		Appearl Park 1st and 2nd phase		453		453	2.27	2.27	0.00	Cauvery Basin	
3		Obedenahalli		697		697	3.49	3.49	0.00	Cauvery Basin	
4		Adinarayana Hosahalli 1st Phase		195		195	0.98	0.98	0.00	Cauvery Basin	
5		Adinarayana Hosahalli 2nd Phase		981		981	10.79	7.85	2.94	Cauvery Basin	
		Sub Total (Doddaballapura)		2678	0.00	2678	19.28	16.33	2.94	Cauvery Basin	
Bangalore Rural District Total				7068	3215	10283	96.23	54.81	41.42		
For Future Development							24.06	13.70	10.36		
Total (Bengaluru Rural)				7068	3215	10283	120.2875	68.51	51.775		
	Ramanagara	Bidadi 1st Phase		862.31		862.31	7.50	5.00	2.50	Cauvery Basin	
		Bidadi 2nd Phase-Sector-1		183.13		183.13	7.00			Cauvery Basin	
		Bidadi 2nd Phase-Sector-2		452.81		452.81		5.00	2.00	Cauvery Basin	
		Harohalli 1st Phase		250.39		250.39	3.00	2.00	1.00	Cauvery Basin	
		Harohalli 2nd Phase		919.16		919.16	12.00	8.00	4.00	Cauvery Basin	
		Harohalli 3rd Phase		1210.90		1210.90	15.00	10.00	5.00	Cauvery Basin	
		Women Entrepreneur's Park					0.75			Cauvery Basin	
		Harohali 3rd Phase		60.87		60.87		0.50	0.25	Cauvery Basin	
		Harohalli 4th Phase		352.36		352.36	1.50	1.00	0.50	Cauvery Basin	
		Harohalli 5th Phase		912.13		912.13	13.00	8.00	5.00	Cauvery Basin	
		Total (Ramanagara)		5204.06		5204.06	59.75	39.5	20.3		
21	Mandya/ Maddur	Somanahally	-	154.00	0.00	154.00	0.77	0.77	0.00	Cauvery Basin	
22	Mandya/ Maddur	Gejjalagere	-	78.30	0.00	78.30	0.39	0.39	0.00	Cauvery Basin	
23	Mandya/ Mandya	Tubinakere	-	141.00	0.00	141.00	0.71	0.71	0.00	Cauvery Basin	
25	Mandya	-	Kuduragundi	0.00	109.00	109.00	0.55	0.55	0.00	Cauvery Basin	
26	Mandya / Mallavalli	-	Bachanahalli	0.00	1249.00	1249.00	6.25	6.25	0.00	Cauvery Basin	

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Basin
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water	
		Total (Mysore , Mandya , Chamarajnagara)	Total	373.3	1358	1731.30	8.66	8.66		
	Tumkur	Antharasanahalli Industrial Area, 1st Phase		208.00	0.00	208.00	1.00	0.50	0.5	Cauvery Basin
		Antharasanahalli Industrial Area, 2nd Phase		256.84	0.00	256.84	1.50	0.75	0.75	Cauvery Basin
		Sathyamangala Industrial Area		54.04	0.00	54.04	0.25	0.13	0.125	Cauvery Basin
		Hirehalli Industrial Area		160.70	0.00	160.70	1.00	0.50	0.5	Cauvery Basin
			Total (Tumakuru)	679.58	0.00	679.58	3.75	1.88	1.88	
		Grand Total		13324.94	4573.00	17897.94	192.44	118.54	73.90	

Requirement of Water in KIADB Industrial Areas

ABSTRACT

Sl.no	District		Total Water Requirement in
		Total Extent in acre	MLD
1	2	3	4
1	Bengaluru Rural and Urban District	19850.15	248.78
2	Ramanagara	5204.06	59.75
3	Kolar	6041.14	73
4	Chikkaballapura	9800	80
5	Tumakuru	16318.82	131.35
6	Chitradurga	2304.73	16.00
7	Davanagere	930.63	6.16
8	Shivamogga	1182.07	1.37

Sl.no	District		Total Water Requirement in MLD
		Total Extent in acre	
1	2	3	4
9	Mysuru (incl Mandya Chamrajanagar Kodagu)	10750.07	53.75
10	Mangaluru	2569.22	14.87
11	Yadgir	3306.33	16.53
12	Kalaburgi	1919.21	9.55
13	Bidar	2268.37	11.44
14	Ballari	2402.41	12.65
15	Vijayanagar	128.61	0.65
16	Koppal	308.11	0.70
17	Raichur	4642.87	22.85
18	Belagavi	2563.61	13.15
19	Bagalkot	293.63	1.50
20	Vijaypura	4833.06	24.40
21	Hassan	3829.33	24.2
22	Chikkamagaluru	381.42	2
23	Dharwad	12079.79	60.27
	Grand Total	113907.64	884.92 MLD
		in TMC	11.41 MLD

S. NO	BASIN	WATER REQUIREMENT, MLD			REMARKS
		TOTAL	FRESH	TREATED	
1	South Pennar Basin	204.49	110.62	93.87	
2	North Pennar Basin	49.00	26.00	23.00	
3	Palar Basin	28.00	14.00	14.00	
		281.49	150.62	130.87	
	in TMC	3.63	1.94	1.69	

Fresh Water Requirement	1.94	TMC
Available Fresh water from Yettinahole	0.25	TMC
Balance Fresh water Quantity Required for Industrial Supply	1.69	TMC

S. NO	BASIN	WATER REQUIREMENT, MLD			
		TOTAL	FRESH	TREATED	Present drawls
1	Cauvery basin	262.74	188.84	73.90	81.00
	in TMC	3.39	2.43	0.95	1.04

Fresh Water Requirement	1.45	TMC
Availble Fresh water from Yettinahole	0	TMC
Balance Fresh water Quantity Required for Industrial Supply	1.45	TMC

SI No.	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water	Quantity	Source		
1	2	3	4	5	6	7=5+6	8=9+10	9	10	11	12	13	14
1	Tumkur	Vasanthanarasapura Industrial Area 1st Phase		747.42	Nil	4107.67	20.50	10.05	10.25	1.55	Hemavathi	1.55 utilised	a. Fresh Water Source - 1.55 MLD allocated from Hemavathi , & 15.54 MLD is allocated from Yetthinaholle, Balance 24.08 MLD additional requirement Treated Water 20 MLD Treated Water is proposed to be utilised for Vasanthanarasapura Phase 1, 2 ,3 (5 MLD) and Vasanthanarasapura Phase 4 5 6 (10 MLD) and 5.54 MLD
2		Vasanthanarasapura Industrial Area 2nd Phase		1263.77									
3		Vasanthanarasapura Industrial Area 2nd Phase (Sub Layout)		100.00									
4		Vasanthanarasapura Industrial Area 3rd Phase		1832.20									
5		Vasanthanarasapura Industrial Area 3rd Phase (Sub Layout)		113.00									
		Vasanthanarasapura Industrial Area 1st Phase (Annexe)		51.28									
		Tumakuru Machine Tool Park (TMTP)		539.42	0	539.42	2.70	1.35	1.35				
		Japanese Industrial Park		520.23	0	520.23	2.60	1.30	1.30				
		Antharasanahalli Industrial Area, 1st Phase		208.00	0.00	208.00	1.00	0.50	0.5				
		Antharasanahalli Industrial Area, 2nd Phase		256.84	0.00	256.84	1.50	0.75	0.75				
		Sathyamangala Industrial Area		54.04	0.00	54.04	0.25	0.13	0.125				

SI No.	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water	Quantity	Source		
1	2	3	4	5	6	7=5+6	8=9+10	9	10	11	12	13	14 Sira IA (5 MLD)
		Hirehalli Industrial Area		160.70	0.00	160.70	1.00	0.50	0.5				
		Sira IA		844.92	0.00	844.92	5.00	2.50	2.5				
6			Vasanthanarasapura Industrial Area 4th Phase	0.00	1722.00	9627.00	97.00	67.00	30.00	15.51	Yetthinaholle	Nil	
7			Vasanthanarasapura Industrial Area 5th Phase	0.00	3174.00								
8			Vasanthanarasapura Industrial Area 6th Phase	0.00	4731.00								
19			Total (Tumakuru)	6691.82	9627.00	16318.82	131.55	84.07	47.27				

20	Chitradurga	Kelagote Industrial Area		75.14	0.00	75.14	0.50	0.50	0.00		Borewell		
21		Ullarthikaval Industrial Area		62.59	0.00	62.59	0.50	0.50	0.00		Borewell		
22		Metikurkke Industrial Area		1167.00	1000.00	2167.00	15.00	10.00	5.00		Vanivilas Dam		
			Total (Chitradurga)	1304.73	1000.00	2304.73	16.00	11.00	5.00				

Total Requirement of Water in KIADB Industrial Areas.

Zone: Davanagere

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Require ment in MLD	Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water	Quantity	Source		
1	2	3	4	5	6	7 = 5+6	8 = 9+10	9	10	11	12	13	14
1	Davanagere	Davanagere I.A.	-	94.50	0.00	94.50	0.50	0.50	0.00		Borewell		
2		Karur	-	102.76	0.00	102.76	0.56	0.56	0.00		Borewell		
3		Haralapura 1 st Phase	-	56.97	0.00	56.97	0.35	0.35	0.00		Borewell		
4		Hanagawadi 1 st Phase	-	50.00	0.00	50.00	0.25	0.25	0.00		Borewell		
5		Kurubarahalli-Sarathi 1 st Stage	-	290.35	0.00	290.35	2.25	2.25	0.00		Tungabhadra River		Proposal sent to Govt. for Allocation
6		Kurubarahalli-Sarathi 2 nd Stage	-	336.05	0.00	336.05	2.25	2.25	0.00				
Total (Davangere)				930.63	0.00	930.63	6.16	6.16	0.00				
1	Shivamogga	Machenahalli	-	381.00	0.00	381.00	2.19	2.19	0.00	1 MGD (4.54 MLD)	Badra	1 MGD (4.54 MLD)	Fresh Water Source- Badra River 15 Km Away
2		Nidige Industrial Area	-	57.00	0.00	57.00							
3		Mandli Kallur	-	42.13	0.00	42.13	0.21	0.21	0.00				
4		Auto Complex	-	19.35	0.00	19.35	0.10	0.10	0.00				
5		Sanda, (Shikaripura)	-	208.00	0.00	208.00	1.04	1.04	0.00				
6		Mangalabeesu	-	10.35	0.00	10.35	0.05	0.05	0.00				
7		Devakatikoppa	-	464.24	0.00	464.24	2.32	2.32	0.00				
Total (Shivamogga)				1182.07	0.00	1182.07	5.91	5.91	0.00				

Total Water requirement in KIADB Industrial Areas

Zone: Mangalore

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water	Quantity	Source		
1	2	3	4	5	6	7=5+6	8=9+10	9	10	11	12	13	14
1	Dakshina Kannada / Mangaluru	Karnad		65.85	0.00	65.85	0.33	0.33	0.00			0.96	Additional Requirement of 5.79 MLD
2	Dakshina Kannada / Mangaluru	E.P.I.P.		205.16	0.00	205.16	4.54	4.54	0.00	1 MGD (4.54 MLD)			
3		Plastic Park, EPIP		104.28	0.00	104.28							
4		Kolluru, Balakunje and Ulepadi		0.00	1091	1091	5.46	5.46	0.00				
5	Dakshina Kannada / Ullal	IT-SEZ & Non-SEZ		517.93	0.00	517.93	4.54	4.54	0	1 MGD (4.54 MLD)			
6	Canara Industrial Area			585	0.00	585							
		Total (Mangaluru)		1478.22	1091	2569.22	14.87	14.87	0	9.08			

Total Requirement of Water in KIADB Industrial Areas.

Zone : Kalaburgi

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirem ent in MLD	Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation in MLD	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water	Quantity in MLD	Source		
1	2	3	4	5	6	7=5+6	8=9+10	9	10	11	12	13	14
1	Yadgir	Kadechur I A 1st Phase		3284.28	0	3284.28	16.42	16.42	0.00	24.5	Bhima River		Source of Water from Bhima River (Gudur-Joladadgi Barrage Back water)
2		Kadechur I A 2nd Phase							0.00		Bhima River		
3		Mundargi I A		22.05	0	22.05	0.11	0.11	0.00		Borewell		Source of Water from KIADB Borewells
		Total (Yadgir)		3306.33	0.00	3306.33	16.53	16.53	0.00				
1	Kalaburagi	Nandur Industrial Area 1st Phase		620	0	620	3	3	0.00				Fresh Water Proposed Samurthi Barrage 35-40 Kms
2		Nandur Industrial Area 2nd Phase		198.36	0	198.36	1	1	0.00				
3		Nandur Industrial Area 3rd Phase (as Per Project Report)		595.22	0	595.22	3	3	0.00				
4		Kapnoor Industrial Area 1st Phase		110.00	0	110	0.55	0.55	0.00				
5		Kapnoor Industrial Area 2nd Phase		208.63	0	208.63	1.00	1.00	0.00				
6		Kapnoor Industrial Area 3rd Phase		187.00	0	187	1	1	0.00				
		Total (Kalaburagi)		1919.21	0.00	1919.21	9.55	9.55	0.00				

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirem ent in MLD	Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation in MLD	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water	Quantity in MLD	Source		
1	Bidar	Naubad Housing Area		72.00	0	72	0.30	0.30	0.00	Nil			Handed over to Municipal Corporation
2		Naubad Autonagar		28.00	0	28	0.14	0.14	0.00				
3		Naubad Industrial Area		93.53	0	93.53	0.50	0.50	0.00				
4		Kolhar Industrial Area 1st Phase		895.98	0	895.98	4.50	4.50	0.00		Karanja Reservoir	Nil	
5		Kolhar Industrial Area 2nd Phase		600.00	0	600	3.00	3.00	0.00				
6		Humnabad Industrial Area		482.30	0	482.3	2.50	2.50	0.00				
7		Basavakalyan Industrial Area		96.56	0	96.56	0.50	0.50	0.00				
		Total (Bidar)		2268.37	0.00	2268.37	11.44	11.44	0.00				

Total Requirement of Water in KIADB Industrial Areas.

SI No	District/ Taluk	Industrial Area		Total Extent in Acres				Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation in MLD	Remarks		
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water	Treated Water	Quantity in MLD	Source				
1	2	3	4	5	6	7=5+6	8=9+10	9	10	11	12	13	14		
1	Ballari	Mundargi 1st Stage		52.59	0	52.59	0.25	0.25	0.00	Nil		Nil	Handed over to corporation Ballari		
2		Mundargi 2nd Stage		166.38	0	166.38	1.00	1.00	0.00						
3		Mundargi 3rd Stage		88.84	0	88.84	0.50	0.50	0.00						
4		Mundargi 4th Stage		64.26	0	64.26	0.30	0.30	0.00						
5		Ananthapura Road		21.79	0	21.79	0.1	0.1	0.00				Surface	Handed over to corporation Ballari	
6		Kuduthini 1st phase		601.27	0	601.27	10.00	10.00	0.00						Proposed 20 MLD for allocation from TB Dam
7		Women Entrepreneurs park		43.91	0	43.91			0.00						
8		Kuduthini 2nd phase		538.43	0	538.43			0.00						
9		Kuduthini 3rd phase		670.94	0	670.94			0.00						
10			Sanjeevrayana kote		0.00	154.00	154	0.50	0.50	0.00					
Total (Ballari)				2248.41	154	2402.41	12.65	12.65	0						
1	Vijayanagar	Sankalapura		102.51	0.00	102.51	0.65	0.65	0.00		Bore Bore				
2				26.1	0.00	26.1			0.00						
Total (Vijayanagara)				128.61	0.00	128.61	0.65	0.65	0						

Total Requirement of Water in KIADB Industrial Areas.

SI No	District/ Taluk	Industrial Area		Total Extent in Acres				Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation in MLD	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water	Treated Water	Quantity in MLD	Source		
1	2	3	4	5	6	7=5+6	8=9+10	9	10	11	12	13	14
1	Koppal	Kustagi I.A.		38.08	0.00	38.08	0.20	0.20	0.00		Bore		
2		Kydeguppa I.A		270.03	0.00	270.03	0.50	0.50	0.00		Bore		
Total (Koppal)				308.11	0.00	308.11	0.70	0.70	0.00				
1	Raichur	Raichur Industrial Area		155.88	0.00	155.88	0.75	0.75	0.00	10	CMC (Krishna)	8.75	Fresh Water Additional 11 MLD proposed for Allocation fromCMC (Krishna River) Treated Water Proposed to be utilised from 4 MLD TTP from Housing Layout
2		Deosugur Industrial Area		214.86	0.00	214.86	1.00	1.00	0.00				
3		Raichur Growth Centre Industrial Area		1745.31	0.00	1745.31	8.50	8.50	0.00				
4		Manvi General Industrial Area		48.00	0.00	48.00	0.30	0.30	0.00				
5		Manvi Auto Nagar Industrial Area		11.70	0.00	11.70			0.00				
6		Yarmaras Industrial Area		41.62	0.00	41.62	0.25	0.25	0.00				
7		Housing Layout		353.32	0.00	353.32	1.80	0.00	1.80				
8		Manvi		0.00	51.37	51.37	0.25	0.25	0.00				
9		Chandrabhanda		0.00	690.13	690.13	3.5	3.5	0.00				
10		Vadluru		0.00	260.38	260.38	1.5	1.5	0.00				
11		Kadangadoddi		0.00	1070.30	1070.30	5	5	0.00				

SI No	District/ Taluk	Industrial Area		Total Extent in Acres				Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation in MLD	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres	Total Water Requirement in MLD	Fresh Water	Treated Water	Quantity in MLD	Source		
1	2	3	4	5	6	7=5+6	8=9+10	9	10	11	12	13	14
Total (Raichur)				2570.69	2072.18	4642.87	22.85	21.05	1.80	10.00			

Total Requirement of Water in KIADB Industrial Areas.

Zone : Belagavi

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation in MLD	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water	Quantity	Source		
1	2	3	4	5	6	7 = 5+6	8 = 9+10	9	10	11	12	13	14
1	BELAGAVI	KANGRALI		58.79	0.00	58.79	0.30	0.30		18.2		18.2	Directly supplied by KUWS & DB to End Users
2		KAKATI		74.25	0.00	74.25	0.35	0.35	0		Raw Water		Source from KUWS & DB
3		HONAGA		209.5	0.00	209.50	1.00	1.00	0				Bore Well Source
4		GOKAK		109.18	0.00	109.18	0.55	0.55	0				Bore Well Source
5		KANABARGI		267	0.00	267.00	1.35	1.35	0				Source from KUWS & DB
6		KITTUR		433.19	0.00	433.19	2.50	2.50	0				Bore Well Source
7		BK KANGRALI SUB-LAYOUT		17.5	0.00	17.50	0.10	0.10	0				Newly Formed IA
8		KANAGALA Phase 1 Phase 2		818.1	576.10	1394.20	7.00	7.00	0		Raw Water		Own Source from Hidkal Dam Reservoir
			Total	1987.51	576.10	2563.61	13.15	13.15	0.00				
1	BAGALKOT												
2		NAVANAGAR AGROTECH PARK		157.5	0.00	157.50	0.80	0.80	0				Bore Well Source
3		ASANGI		42.1	0.00	42.10	0.20	0.20	0				Bore Well Source
4		BALAKUNDI		94.03	0.00	94.03	0.50	0.50	0				Newly Formed IA
			Total	293.63	0.00	293.63	1.5	1.5	0.00				

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation in MLD	Remarks
		Existing Industrial Areas	Propose d Industria l Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treate d Water	Quantity	Source		
1	2	3	4	5	6	7 = 5+6	8 = 9+10	9	10	11	12	13	14
1	VIJAYPUR												
2		MAHALBHAGAYAT		218.16	0.00	218.16	1.00	1.00					Source from KUWS & DB
3		ALIYABAD BLOCK I		158.16	0.00	158.16	0.80	0.80					Source from KUWS & DB
4		ALIYABAD BLOCK II		117.51	0.00	117.51	0.60	0.60					Source from KUWS & DB
5		MULAWAD PHASE I		564.5	0.00	564.50	10.00	10	0.00				Own Source from Krishna River for 18.20 MLD Newly Formed IA
6		MULAWAD PHASE II		555.86	0.00	555.86							
7		MULAWAD PHASE III		738.87	0.00	738.87							
		Vijayapura Airport			730.00	730.00	3.50	3.50	0.00				Fresh Water Source Krishna River
		Madabhavi, Buranapur & Aliyabad IA			1750.00	1750.00	8.50	8.50	0.00				
			Total	2353.06	2480.00	4833.06	24.40	24.40	0.00				
	Grand Total			4634.2	3056.10	7690.3	39.05	39.05	0.00				

Total Requirement of Water in KIADB Industrial Areas.

Zone: Hassan

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation in MLD	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water	Quantity in MLD	Source		
1	2	3	4	5	6	7=5+6	8=9+10	9	10	11	12	13	14
1	Hassan	Hassan Growth Centre (Including Sublayouts & SEZ's)		2245.09	0	2245.09	11	11	0	4.95 MGD (22.5 MLD)	Hemavathi	Source-Hemavathi with an allocation of 22.5 MLD , therefore Additional Water not required.	
2		B.Katihalli		102.97	0	102.97	0.5	0.5	0				
3		Holenarasipura		28.95	0	28.95	0.1	0.1	0				
4		Thimmanahalli		75.07	0	75.07	0.35	0.35	0				
5			Hassan Industrial Area	0	1057.6	1057.6	10.55	10.55	0	Borewell			
6			Doothanuru Kaval	0	177.49	177.49	1	1	0				
7			Mylanahalli	0	142.16	142.16	0.7	0.7	0				
Total (Hassan)				2452.08	1377.25	3829.33	24.2	24.2	0				
1	Chikkamagaluru	Amble Industrial Area		144.47	0	144.47	1	1	0	Borewell			
2		Nagadiyath Kavala		236.95	0	236.95	1	1	0				
Total (Chikkamagaluru)				381.42	0	381.42	2	2	0				

Grand Total	2833.5	1377.25	4210.75	26.2	26.2	0				
-------------	--------	---------	---------	------	------	---	--	--	--	--

Total Requirement of Water in KIADB Industrial Areas.

Zone : Dharwad

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation in MLD	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water	Quantity in MLD	Source		
1	2	3	4	5	6	7=5+6	8=9+10	9	10	11	12	13	14
1	DHARWAD	Belur	-	2065.48	0.00	2065.48	10.00	10.00	0.00	12	Malaprabha	12	Water Source Malaprabha River Near Budhihal
2		Tata Motors Tata Hitachi Tata Marcopolo	-	684.00	0.00	684.00	3.50	3.50	0.00				Water Source Malaprabha River Near Budhihal
3		Lakkammanahalli	-	71.23	0.00	71.23	0.50	0.50	0.00				water Source Borewell
4		Sattur	-	52.37	0.00	52.37	0.30	0.30	0.00				water Source Borewell
5		Rayapur 1st and 2nd Phase	-	370.28	0.00	370.28	1.90	1.90	0.00				water Source Borewell
6		Tarihal	-	293.74	0.00	293.74	1.50	1.50	0.00				water Source Borewell
7		Tarihal Sub-Layout	-	19.05	0.00	19.05	0.10	0.10	0.00				water Source Borewell
8		Kotur-Belur EMC	-	593.00	0.00	593.00	3.00	3.00	0.00	45	Ghatapraba	Nil	Water Source Malaprabha River Near Budhihal
9		Mummigatti	-	509.48	0.00	509.48	2.50	2.50	0.00				Water Source Malaprabha River Near Budhihal
10		Gamanagatti 1st and 2nd Phase	-	387.95	0.00	387.95	2.00	2.00	0.00				water Source Borewell
11		Gamanagatti Women's Park	-	30.00	0.00	30.00	0.20	0.20	0.00				water Source Borewell

SI No	District/ Taluk	Industrial Area		Total Extent in Acres			Total Water Requirement in MLD	Bifurcation of Required Water in MLD		Allocation in MLD only for Fresh water		Present Utilisation in MLD	Remarks
		Existing Industrial Areas	Proposed Industrial Areas	Existing	Proposed	Total Extent in Acres		Fresh Water	Treated Water	Quantity in MLD	Source		
1	2	3	4	5	6	7=5+6	8=9+10	9	10	11	12	13	14
12	DHARWAD	Kelageri SC/ST Cluster	-	20.00	0.00	20.00	0.10	0.10	0.00				water Source Borewell
13		Mummigatti Narendra Housing Area	-	111.00	0.00	111.00	0.50	0.50	0.00				Water Source Malaprabha River Near Budhihal
14		Kelageri Housing Area	-	20.00	0.00	20.00	0.10	0.10	0.00				water Source Borewell
15		Gamanagatti Housing Area(Site)	-	28.06	0.00	28.06	0.15	0.15	0.00				water Source Borewell
16		BMIC-Dharwad Node	-	6042.26	0.00	6042.26	30.00	30.00	0.00				Water Source Ghataprabha River Near Gataprabha
17	GADAG	Narasapur	-	162.75	0.00	162.75	0.80	0.80	0.00				water Source Borewell
18	UTTAR KANNADA	Shirwad	-	34.14	0.00	34.14	0.20	0.20	0.00				water Source Borewell
19		Ambewadi Autonagar	-	5.00	0.00	5.00	0.02	0.02	0.00				water Source Borewell
20		Mudagere	-	73.00	0.00	73.00	0.40	0.40	0.00				water Source Borewell
21	HAVERI	Magodu	-	100.00	0.00	100.00	0.50	0.50	0.00				water Source Borewell
22		Koluru-Ganajuru	-	407.00	0.00	407.00	2.00	2.00	0.00				water Source Borewell
	Total			12079.79	0.00	12079.79	60.27	60.27	0.00				