



1. All paving shall be over compacted earth. Remove all topsoil, debris, and organic material prior to paving operations. All paving shall be sloped as shown on the drawings and/or as required for proper surface drainage from all locations. Pockets in paving shall not be acceptable.
2. All concrete walks shall be 6" thick with 6x6-10/10 Welded wire Reinforcing, placed on compacted earth. Remove all debris and organic material prior to paving operations. Provide expansion joint with filler where walks abut vertical masonry or concrete walls. Provide scored control joints in walks at maximum 10' intervals. Provide a minimum 1/4" slope for 10'-0" maximum and/or as shown on the plans. All walks abutting or flush with buildings to be constructed with a minimum 1/4" positive drainage away from building.
3. All parking lines indicated on the plan shall be 4" wide white paint. Where designated on the plans to be handicapped, the Contractor shall paint the international symbol of accessibility for the handicapped with the words "HANDICAPPED PARKING" directly below the symbol.

