Version 7.2.16

PVsyst - Simulation report

Grid-Connected System

Project: Kopellis_ 2 Axis

Variant: 114 kW pitch 10m vertical, ew

Trackers single array

System power: 114 kWp

Thessaloniki/Livadákion - Greece

Author

PVsyst V7.2.16
VC0, Simulation date:
14/07/22 21:50
with v7.2.16

Project summary

Geographical Site
Thessaloniki/Livadákion
Greece

Situation

Latitude	40.52 °N
Longitude	22.97 °E
Altitude	4 m
Time zone	UTC+2

Project settings
Albedo 0.20

Meteo data
Thessaloniki/Livadákion
Meteonorm 8.0 (1994-2006), Sat=14% - Synthetic

System summary

Grid-Connected System

Trackers single array

PV Field Orientation
Orientation
Tracking plane, two axis

Tracking algorithm
Astronomic calculation

Near Shadings
Linear shadings

System information

PV Array

Nb. of modules	216 units
Pnom total	114 kWp

Inverters

Nb. of units	1 unit
Pnom total	111 kWac
Pnom ratio	1.031

User's needs
Unlimited load (grid)

Results summary

Produced Energy	216.5 MWh/year	Specific production	1891 kWh/kWp/year	Perf. Ratio PR	84.01 %

Table of contents

PVsyst V7.2.16
VC0, Simulation date:
14/07/22 21:50
with v7.2.16

General parameters

Grid-Connected System | **Trackers single array**

PV Field Orientation

Orientation	Tracking algorithm	Trackers configuration
Tracking plane, two axis	Astronomic calculation	Nb. of trackers 12 units
		Single array
		Sizes
		Tracker Spacing 30.0 m
		Collector width 10.4 m
		Ground Cov. Ratio (GCR) 34.6 %
		Tilt min / max. 10.0 / 40.0 °
		Azimut min / max. -/+ 120.0 °

Models used

Transposition	Perez
Diffuse	Perez, Meteonorm
Circumsolar	separate

Horizon	Near Shadings	User's needs
Average Height 7.4 °	Linear shadings	Unlimited load (grid)

PV Array Characteristics

PV module

Manufacturer	Generic
Model	JKM-530M-72HL4-V
(Custom parameters definition)	
Unit Nom. Power	530 Wp
Number of PV modules	216 units
Nominal (STC)	114 kWp
Modules	8 Strings x 27 In series
At operating cond. (50°C)	
Pmpp	104 kWp
U mpp	1002 V
I mpp	104 A

Inverter

Manufacturer	Generic
Model	SG111-HV
(Original PVsyst database)	
Unit Nom. Power	111 kWac
Number of inverters	1 unit
Total power	111 kWac
Operating voltage	780-1450 V
Pnom ratio (DC:AC)	1.03

Total PV power

Nominal (STC)	114 kWp
Total	216 modules
Module area	557 m²

Total inverter power

Total power	111 kWac
Number of inverters	1 unit
Pnom ratio	1.03

Array losses

Array Soiling Losses
Loss Fraction 1.5 %

Thermal Loss factor
Module temperature according to irradiance
Uc (const) 29.0 W/m²K
Uv (wind) 0.0 W/m²K/m/s

DC wiring losses
Global array res. 106 mΩ
Loss Fraction 1.0 % at STC

Module Quality Loss
Loss Fraction 0.0 %

Module mismatch losses
Loss Fraction 0.6 % at MPP

IAM loss factor
Incidence effect (IAM): Fresnel, AR coating, n(glass)=1.526, n(AR)=1.290

0°	30°	50°	60°	70°	75°	80°	85°	90°
1.000	0.999	0.987	0.962	0.892	0.816	0.681	0.440	0.000

PVsyst V7.2.16
VC0, Simulation date:
14/07/22 21:50
with v7.2.16

System losses

Auxiliaries loss
Proportionnal to Power 4.0 W/kW
0.0 kW from Power thresh.

AC wiring losses

Inv. output line up to MV transfo

Inverter voltage	540 Vac tri
Loss Fraction	0.21 % at STC

Inverter: SG111-HV

Wire section (1 Inv.)	Copper 1 x 3 x 240 mm²
Wires length	70 m

AC losses in transformers

MV transfo

Grid voltage	20 kV

Operating losses at STC

Nominal power at STC	113 kVA
Iron loss (24/24 Connexion)	0.11 kW
Loss Fraction	0.10 % at STC
Coils equivalent resistance	3 x 25.76 mΩ
Loss Fraction	1.00 % at STC

PVsyst V7.2.16
VC0, Simulation date:
14/07/22 21:50
with v7.2.16

Horizon definition

Horizon from PVGIS website API, Lat=39°37"58', Long=22°13"41', Alt=153m

Average Height	7.4 °	Albedo Factor	0.40
Diffuse Factor	0.89	Albedo Fraction	100 %

Horizon profile

Azimuth [°]	-180	-173	-165	-158	-143	-135	-128	-120	-113	-105	-98	-90
Height [°]	1.9	3.4	4.6	5.7	7.3	6.5	4.6	4.2	5.3	6.1	5.7	5.3
Azimuth [°]	-83	-75	-68	-60	-53	-45	-38	-30	-23	-15	0	8
Height [°]	4.6	4.2	3.4	3.1	2.3	1.9	0.4	1.1	1.5	1.1	1.1	3.4
Azimuth [°]	15	23	38	45	135	143	150	158	165	173	180	
Height [°]	6.5	11.5	11.5	14.9	14.9	8.0	8.0	5.3	1.9	1.5	1.9	

Sun Paths (Height / Azimuth diagram)



PVsyst V7.2.16
VC0, Simulation date:
14/07/22 21:50
with v7.2.16

Near shadings parameter

Perspective of the PV-field and surrounding shading scene



Iso-shadings diagram

Orientation #1



PVsyst V7.2.16
VC0, Simulation date:
14/07/22 21:50
with v7.2.16

Main results

System Production

Produced Energy	216.5 MWh/year	Specific production	1891 kWh/kWp/year
		Performance Ratio PR	84.01 %

Normalized productions (per installed kWp)



Performance Ratio PR



Balances and main results

	GlobHor kWh/m²	DiffHor kWh/m²	T_Amb °C	GlobInc kWh/m²	GlobEff kWh/m²	EArray MWh	E_Grid MWh	PR ratio
January	52.6	29.21	4.95	95.7	84.0	9.54	9.23	0.842
February	76.4	39.36	6.71	124.7	113.2	12.73	12.36	0.866
March	118.0	57.36	9.91	174.7	161.7	17.92	17.41	0.870
April	150.3	77.02	13.73	200.9	187.3	20.46	19.89	0.865
May	195.0	84.41	19.52	258.4	242.1	25.74	25.04	0.847
June	218.4	75.24	24.54	289.6	274.7	28.49	27.70	0.836
July	214.7	82.15	27.83	285.4	269.3	27.63	26.88	0.823
August	194.0	76.29	27.71	271.6	252.6	25.98	25.28	0.813
September	144.2	53.93	21.67	216.0	200.6	21.10	20.51	0.829
October	94.1	43.87	16.53	153.4	139.9	15.17	14.72	0.838
November	57.9	29.79	11.46	102.4	92.0	10.18	9.85	0.840
December	43.4	24.96	6.66	78.5	70.2	7.93	7.64	0.850
Year	1559.1	673.58	15.99	2251.3	2087.4	222.86	216.52	0.840

Legends

GlobHor	Global horizontal irradiation
DiffHor	Horizontal diffuse irradiation
T_Amb	Ambient Temperature
GlobInc	Global incident in coll. plane
GlobEff	Effective Global, corr. for IAM and shadings
EArray	Effective energy at the output of the array
E_Grid	Energy injected into grid
PR	Performance Ratio

PVsyst V7.2.16
VC0, Simulation date:
14/07/22 21:50
with v7.2.16

Loss diagram



PVsyst V7.2.16
VC0, Simulation date:
14/07/22 21:50
with v7.2.16

Special graphs

Daily Input/Output diagram



System Output Power Distribution