

- (13) Other tests as required by the authority having jurisdiction.
- (14) Signatures of tester and approved authority representative.
- (15) Disposition of problems identified during test (e.g., owner notified, problem corrected/successfully retested, device abandoned in place).

Testing Frequency. Testing shall be performed in accordance with an approved schedule.

FMS.22 The hospital has a fire suppression system available in the required area(s).

FMS.22.1 The hospital has a functional sprinkler system.

FMS.22.2 The hospital has clean agent suppression system.

FMS.22.3 The hospital has wet chemical system.

FMS.22.4 The hospital has stand pipes and hose system.

Standard Intent:

In a wide range of applications where human lives and material assets need to be protected against the effects, reliable fire extinguishing systems need to be properly installed and maintained.

Hospitals need to ensure that such systems (sprinklers, clean agent suppression, wet chemical, stand pipes and hose systems) are properly installed (depending on room functions), that their functions are by any means not interrupted due surrounding practices (improper storage, adjacent construction activities, and that their functions are regularly inspected and maintained.

FMS.23 There are fire exits that are properly located in the hospital.

FMS.23.1 Fire exits are available and are properly located in the hospital.

FMS.23.2 Fire exits are not locked.

FMS.23.3 Fire exits are not obstructed.

FMS.23.4 Fire exits have panic hardware.

FMS.23.5 Fire exits are fire resistant.

FMS.23.6 Fire exits are clearly marked with illuminated exit sign.