



Informe diario

CP020 · BBS Mexico · 5 ago 2026

Registro operativo

Proyecto

CP020 · BBS Mexico

Cliente

IMPC Gmbh

Fecha

5 ago 2026

Trabajador

Gabriel Santos

Estado

Aprobado

Relacionado con la seguridad

Sí

Planta / turno

Plant 1 · First Shift (07:00 - 17:00)

Minutos de parada

0

Motivo de espera

None · Normal continuous operation

Resumen

Commissioned Allen Bradley ControlLogix safety zones and validated Siemens S7-1500 interlocks for Stations 10 to 14. Supervised trial production run with 0 safety incidents.

Tareas completadas

Safety circuit checkout, servo axis tuning, HMI alarm messaging verified

Problemas encontrados

Photoelectric sensor bracket on station 12 was misaligned

Acciones correctivas

Re-aligned bracket and tightened mounting bolts; retested trigger window