

Department of Water Supply & Sanitation, Punjab

Website: www.pbdwss.gov.in

WQ: Report2

Water Quality District Profile(BP)

As on : 17-Nov-17

Sr. No.	Name of District	Name of Division	Name of Laboratory	Name of Block	Name of Scheme	Scheme ID	Village covered under Scheme	Village ID	Source	Colour (Units on Pt-Co scale)	Odour (Qualitative)	Turbidity	pH	Total Alkalinity	Total Hardness	Calcium	Chloride	Sulphates	Fluorides	Nitrate	Iron	Total Dissolved Solids	Coliform
										5	Agreeable	1 NTU	6.5-8.5	200 mg/l	200 mg/l	75 mg/l	250 mg/l	200 mg/l	1.0 mg/l	45 mg/l	1.0 mg/l	500 mg/l	0 MPN/100 ml
										25	Agreeable	5 NTU	No Relaxation	600 mg/l	600 mg/l	200 mg/l	1000 mg/l	400 mg/l	1.5 mg/l	No Relaxation	No Relaxation	1000 mg/l	-
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1	North Zone	North Zone	test_lab	North Zone	1	1	1	100	Vill1Src	10.20	1.20	4.50											
2	North Zone	North Zone	test_lab	North Zone	2	2	2	1	Vill2Src	5.60													

Version 1.0