

**Himachal Pradesh  
Jal Shakti Vibhag  
Water Testing Laboratory, Kandaghat  
TEST REPORT**

Environmental condition:

Temp 24.8 °C

Humidity: 45%


|               |                  |
|---------------|------------------|
| Sample No. 5d | Date: 15.05.2026 |
|---------------|------------------|


|                               |                                                                             |                            |            |
|-------------------------------|-----------------------------------------------------------------------------|----------------------------|------------|
| Name and Address of customer: | Principal, D.A.V (Devbhoomi Adarsh Vidyalaya) Subathu                       | Sample Quantity:           | 500 ml     |
| Customer ref. No.:            | JSSD-Parwanoo-water sample/2026 27 Camp, Dated 14.05.2026                   | Date of sample collection: | 15.05.2026 |
| Name of scheme:               | Tap water                                                                   | Sample Receipt date:       | 15.05.2026 |
| Sample Description:           | Water                                                                       | Test start Date            | 15.05.2026 |
| Sample Type:                  | Treated Water                                                               | Test End Date:             | 18.05.2026 |
| Sample Location:              | D.A.V (Devbhoomi Adarsh Vidyalaya) Subathu, Village Kalyan near kainchi mod | Issue Date:                | 18.05.2026 |

| Sr. No.                    | Test                   | Unit        | Test Method                   | Result    | Requirement<br>As per IS 10500:2012             |                                                            |
|----------------------------|------------------------|-------------|-------------------------------|-----------|-------------------------------------------------|------------------------------------------------------------|
|                            |                        |             |                               |           | Acceptable Limit                                | permissible limit in the<br>absence of alternate<br>source |
| Physical Parameters        |                        |             |                               |           |                                                 |                                                            |
| 1                          | Temperature            | °C          | APHA 24 <sup>th</sup> Edition | -         | -----                                           | -----                                                      |
| 2                          | Colour                 | Hazen Units | IS 3025-Part 4                | BDL       | 5                                               | 15                                                         |
| 3                          | Odour                  | -           | IS 3025-Part 6                | Agreeable | Agreeable                                       | Agreeable                                                  |
| 4                          | Taste                  | -           | IS 3025-Part (7,8)            | Agreeable | Agreeable                                       | Agreeable                                                  |
| 5                          | Turbidity              | NTU         | IS 3025- Part 10              | 2.7       | 1.0                                             | 5.0                                                        |
| 6                          | pH                     | -           | IS 3025- Part 11              | 7.60      | 6.5                                             | 8.5                                                        |
| Chemical Parameters        |                        |             |                               |           |                                                 |                                                            |
| 7                          | TDS                    | mg/l        | IS 3025- Part 16              | 446.3     | 500                                             | 2000                                                       |
| 8                          | Total Alkalinity       | mg/l        | IS 3025- Part 23              | 281.3     | 200                                             | 600                                                        |
| 9                          | Chlorides              | mg/l        | IS 3025- Part 32              | 61.3      | 250                                             | 1000                                                       |
| 10                         | Total Hardness         | mg/l        | IS 3025- Part 21              | 364.0     | 200                                             | 600                                                        |
| 11                         | Calcium                | mg/l        | IS 3025- Part 40              | 113.8     | 75                                              | 200                                                        |
| 12                         | Magnesium              | mg/l        | APHA 24 <sup>th</sup> Edition | 19.48     | 30                                              | 100                                                        |
| 13                         | Iron                   | mg/l        | APHA 24 <sup>th</sup> Edition | -         | 0.1                                             | 1                                                          |
| 14                         | Nitrate                | mg/l        | APHA 24 <sup>th</sup> Edition | -         | 45                                              | No relaxation                                              |
| 15                         | Fluoride               | mg/l        | APHA 24 <sup>th</sup> Edition | -         | 1.0                                             | 1.5                                                        |
| 16                         | Sulphate               | mg/l        | APHA 24 <sup>th</sup> Edition | 136.2     | 200                                             | 400                                                        |
| 17                         | Ammonia                | mg/l        | APHA 24 <sup>th</sup> Edition | -         | 0.5                                             | No relaxation                                              |
| 18                         | Manganese              | mg/l        | APHA 24 <sup>th</sup> Edition | -         | 0.1                                             | 0.3                                                        |
| 19                         | Total Arsenic          | mg/l        | APHA 24 <sup>th</sup> Edition | -         | 0.01                                            | 0.05                                                       |
| 20                         | Free Residual Chlorine | mg/l        | APHA 24 <sup>th</sup> Edition | 1.0       | 0.2                                             | 1.0                                                        |
| Bacteriological Parameters |                        |             |                               |           |                                                 |                                                            |
| 1                          | Total Coliform         | Per 100ml   | IS 15185:2016                 | Absent    | Shall not be detectable in<br>any 100 ml sample | Shall not be detectable<br>in any 100 ml sample            |
| 2                          | E. Coli                | Per 100ml   | IS 15185:2016                 | Absent    | Shall not be detectable in<br>any 100 ml sample | Shall not be detectable<br>in any 100 ml sample            |

**Note:** This report should not be produced partly or fully without approval of signatory authority for legal purpose.

The results refer only to tested samples and parameters tested.

  
Assistant Chemist  
Water Testing Lab  
Kandaghat

  
Assistant Engineer  
Jal Shakti Sub Division  
Kandaghat