

WATER TESTING LABORATORY

Jal Shakti Sub-Division.....Araki..... Distt.....Solan.....

Based Upon 10500-2012

Lab Ref.No. 1829

Date.....14/07/2025.....

Name and Address of Sender-AE Jal Shakti Sub-Division.....Subathu.....

Name of District.....Solan.....Block.....Dharmapur.....Section.....Subathu

Gram Panchayat.....Tadla.....Village.....Kalyan.....

Name of Scheme & Source.....D.A.V. (Derbhoomi Adarsh Vidyalaya).....

Date and Time of Collection.....10/07/2025.....8:30 a.m......

Date & Time of Receipt and Laboratory.....10/07/2025.....10:30 a.m......

Date & time Of Commencing.....10/07/2025.....11:00 a.m......

Type of Sample :- 1. Raw Water 2. Filtered Water 3. Chlorinated 4. Distributed system

(Pvt. Tap, Public stand post) 5. Hand pump

A.	PHYSICAL TEST :-	1	2	3
Sr.No	TEST	DESIRABLE LIMIT	PERMISSIBLE LIMIT	ACTUAL RESULT
1	Temperature			25
2	Colour	5	15	05 C
3	Odour	Agreeable	Agreeable	Nil
4	Taste	Agreeable	Agreeable	Nil
5	Turbidity	1 NTU	5 NTU	01 NTU
6	TDS/Conductivity	500mg/l	2000gm/l	730 mg/l

B. CHEMICAL TEST :-

7	pH	6.5	8.5	7.81	mg/l
8	Total Alkalinity	200mg/l	600mg/l	310	mg/l
9	Chlorides	250mg/l	1000mg/l	20.52	mg/l
10	Fluoride	1.5mg/l	1.5mg/145mg/l	Nil	mg/l
11	Nitrate	45mg/l	45mg/l	Nil	mg/l
12	Sulphate	200mg/l	400mg/l	Nil	mg/l
13	Total Hardness	200mg/l	600mg/l	415	mg/l
14	Iron	1.0mg/l	0.3mg/l	Nil	mg/l
15	Manganese	1.0mg/l	0.3mg/l	Nil	mg/l
16	Total Arsenic	0.01mg/l	0.01mg/l	Nil	mg/l
17	Residual Chlorine	1.2mg/l	1mg/l	0.1	mg/l

C. BACTERIOLOGICAL TEST:-

18	Total Coli-Form	0MNP	0MNP	0	MNP
19	E.Coli/Thermo Tolerant Coil From	0MNP	0MNP	Nil	MNP

Remarks.....All the water sample tested parameters are in permissible limit.

Assistant Chemist
Water Testing Lab.....Araki.....
For Cont.Jyoti Trading Company

In-Engineer
Jal shakti Section.....Araki.....

Assistant Engineer
Jal shakti Sub-Division.....Araki.....