

Assessment of a MACsec-based security system for use in critical Infrastructure Communication

Lukas Füreder

Technical University of Applied Sciences Regensburg (OTH)

Laboratory for Safe and Secure Systems (LaS³)

Regensburg, Germany

lukas.fuereder@oth-regensburg.de

Supervisor: *Prof. Dr. Jürgen Mottok*

Abstract

This paper investigates the integration of Media Access Control Security (MACsec) into the communication of critical infrastructure, specifically within power grid applications, such as Substation Automation Systems (SAS) using the IEC 61850 standard. Building on the principles of both standards, this study aims to determine if MACsec can meet the security and performance requirements set by IEC 62351 for power system communications.

Furthermore, a test environment containing a number of Intelligent Electronic Devices (IEDs) supporting communication compliant to all IEC 61850 message types is established to evaluate this integration. The results of the measurements executed in this environment indicate that MACsec could secure all types of messages, such as Manufacturing Message Specification (MMS), Sampled-Value (SV) and Generic Object Oriented Substation Events (GOOSE), within the required time periods without significant delays. Even with additional encryption activated in the cipher suite, the resulting transmission times are well below the required times. This suggests that MACsec can enhance the security goals for industrial communication by providing confidentiality in addition to the already mandated assurance of authenticity and integrity to all messages without compromising performance.

Only the requirement for end-to-end security cannot be met by MACsec in this configuration, as the security system re-encrypts with every hop of the transmission. For this reason, we propose a hybrid approach of Transport Layer Security (TLS) and MACsec as part of future work.

Keywords— MACsec, IEC61850, IEC62351, GOOSE, Secure Communication

I. INTRODUCTION

Companies classified as critical infrastructure, for example water supply facilities, power plants and their corresponding distribution systems, can constitute an attractive target for cyber attacks, which could disrupt the supply of basic resources to entire countries. As a result, laws such as the Network and Information Security Act (NIS-2) [1] of the European Union or the IT Act 2.0 [26] enforced by the German Federal Office for Information Security (BSI) demand a unified level of cybersecurity for these entities. In these regulations, the councils prescribe that the companies must adhere to information security standards, which mandate the current requirements for secure communication and cryptography [2, p. 9]. Furthermore, the extension of the IT Act 2.0 dictates that these companies are obliged to provide proof of compliance with the security requirements over a two-year period [26, §11 (1e)]. This decision is intended to ensure the future operability of the security systems with respect to adapting changes of the latest technologies.

The main objectives of these security standards are the assurance of the security goals authenticity, integrity and confidentiality for applications in critical infrastructure [26, §2 (13)]. Organizations such as the International Electrotechnical Commission (IEC) or the Institute of Electrical and Electronics Engineers (IEEE) develop standards that specify the implementation of these abstract security goals. This paper evaluates the currently established implementation of protection systems securing communication in Substation Automation Systems (SASs) and thereby provides a brief overview of the communication standards used in these facilities. Following this, we propose a Media Access Control Security (MACsec) based security system and evaluate whether this implementation fulfills the requirements of the security goals specified in the IEC 62351 security standards.

The further course of the paper is structured as follows: Chapter II clarifies the technical background of this paper and thereby provides a general overview of the IEC 61850 communication standard and the associated message types. Building on this, the further part of this chapter presents the current state of message security mandated by the IEC 62351 security standard. Following this, a brief introduction into the MACsec security standard is provided, which presents the relevant features used in the implementation later on. Chapter III displays relevant information presented by related work assessing the current state of technology in this topic. In the further course of the paper, Chapter IV explains the test setup used to measure the efficiency of the MACsec-based security system. Lastly, the data gathered from this is then evaluated in chapter V and is placed in the context of the mandated safety requirements.

II. BACKGROUND

A. Overview of the IEC 61850 Standard

Among other standards used for communication in industrial applications, power systems primarily utilize the IEC 61850 standard [5], which is published and maintained by the International Electrotechnical Commission (IEC) [17]. This standard specifies the transmission of diagnostic information, measurement values or control signals among devices structured in a three level architecture [22], as displayed in Figure 1. The major advantage in this type of communication consists of the object-oriented data structure defined in this standard, which makes the integration of various components developed by different vendors possible [4, p. 5643].




Figure 1: Overview of the three architecture levels in IEC 61850 [22]

At the lowest point, the Process level contains devices tasked with the actual power management. Examples for these are: transformers, circuit breakers, Programmable Logic Controllers (PLCs) and measurement units [22]. Upon configuration, Process Level components periodically publish measurement information to all subscribing communication partners in the Bay Level via Sampled-Value (SV) packets [23]. This communication involves LAN-internal multicast packets, which take place exclusively on the second layer (Data Link Layer) of the Open System Interconnection (OSI) model [23].

The Bay Level above contains the Intelligent Electronic Devices (IEDs), each of which represents a transformation field in the substation [7, p. 39]. The IEDs gather the measurement data from the Process Level and initially process them. The resulting information is then communicated through Manufacturing Message Specification (MMS) packets to other IEDs and the Station Level components [10, p. 44]. Simultaneously, the IEDs receive control signals from the Station Level, which are also transmitted via MMS packets [14]. As the Station Level components are not necessarily located in the same LAN as the IEDs, the MMS messaging is implemented through TCP packets on the fourth layer (Transport Layer) of the OSI model [10, p. 45]. In addition to the MMS messaging, the IEDs use Generic Object Oriented Substation Events (GOOSE) to send time-critical information to surrounding IEDs. Similar to SV, GOOSE messages are implemented through multicast Ethernet packets in the LAN [3].

The devices located in the Station Level of the architecture are responsible for controlling the SAS. This is achieved through MMS packets addressed to specific IEDs and the presentation of the processed information in graphical illustrations to the user [22]. For this, the Station Level components typically consist of a Supervisory Control and Data Acquisition (SCADA) component and a Human-Machine-Interface (HMI). Lastly, as displayed in Figure 1, it is possible to transmit GOOSE messages to the Station Level components. For this, the IEC 61850-90-5 standard [11] defines a routable version of the layer two GOOSE frame. For this purpose, the GOOSE packets are extended by adding network and transport layer headers to form a UDP packet, which is routable throughout a Wide Area Network (WAN) [24].

B. Message Security according to IEC 62351

Building on the IEC 61850 message types described in Chapter II-A, the IEC 62351 standard [12] dictates security goals and requirements for cybersecurity solutions. In order to evaluate the proposed MACsec solution for industrial applications, we need to assess the proposed security functions according to the demands of this standard.

With regard to MMS messages, the standard prescribes the protection of authenticity, integrity and confidentiality. IEC 62351-4 directly specifies certificate-based TLS to achieve these security goals [25]. Furthermore, the standard subdivides the assertion of the security requirements according to the layers of the OSI reference model. The upper three layers are summarized in the application profile and the lower four layers in the transport profile [25]. Based on this, the standard specifies that the security system shall verify the authenticity of the communication partner and the integrity of the transmitted messages during the handshake phase of the transport profile [4]. Following this, the system shall provide confidentiality for the outgoing messages in the data transfer phase [25]. With respect to the upper three layers, the standard specifies two possible implementations in the application profile: peer-to-peer security and end-to-end security [4]. The primary difference between them consists in the data origin authentication and message integrity checks, which are only verified during the association establishment in the peer-to-peer implementation, whereas the end-to-end implementation also ensures them in the following data transfer [4].

For GOOSE messages, the standard argues that the strict real-time requirement of a maximum of 3 ms [3] outweighs the security requirements and for this reason, state that security measures which affect the transmission rates are not acceptable [15]. Building on this, the IEC 62351 standard advises against the encryption of GOOSE messages and only proposes the use of digital signatures to verify the authenticity of the GOOSE publisher and the integrity of the message. As similar restrictions arise for SV messages, the standard equally advises the usage of digital signatures for SV packets [4].

C. Fundamentals of the MACsec Security Standard

MACsec represents an information security standard which protects messages on the second layer (Data Link Layer) of the OSI model. In contrast to security standards operating in higher layers of the TCP/IP stack (e.g. Transport Layer Security (TLS)), which provide end-to-end encryption, MACsec verifies the integrity and authenticity of a packet within each hop of the transmission [18]. However, this lower layer implementation close to the PHY enables MACsec to secure communication which takes place exclusively on layer 2 (e.g. SV & GOOSE). The following paragraph explains the most important aspects of the MACsec standard, which are responsible for ensuring the authenticity, integrity and confidentiality of the transmitted packets.




Figure 2: Schematic representation of the MACsec entities [13]

As displayed in Figure 2, the communicating devices are initially grouped in Connectivity Associations (CAs), which represent the logical separation of secured communication areas [13, p. 35]. Each member of a CA possesses the associated Connectivity Association Key (CAK), which is later used to generate the individual session keys. Similar to other encryption systems, the CAK acts as a shared secret between the individual parties and is therefore used to verify the authenticity of incoming MACsec frames. In the IEEE 802.1AE standard, the distribution of the CAK among the participants is only specified as a brief overview of the established methods [13, p. 230]. In our case, we utilize pre-shared keys to configure the CA in the test setup explained in Chapter IV. Within a CA, the connections between the communicating devices are referred to as Secure Channels (SCs). As displayed in Figure 2, an SC is a unidirectional connection from a transmitter to one or more receivers. Each SC can be

identified by the Secure Channel Identifier (SCI), which is added to the MACsec specific field in the secured frame [13, p. 43]. During transmission over an SC, the packets are sent within Security Associations (SAs). These are time intervals in which a single Secure Association Key (SAK) is valid [13, p. 44]. The SAK is the session key, which is derived from the previously described CAK and is only valid for up to $(2^{32} - 1)$ packets, after which a new SAK needs to be generated [13, p. 66]. To be able to monitor the number of transmitted packets in an SA, the MACsec frame contains a packet number field, which is incremented with each subsequent packet. This field additionally ensures that no replay attacks can be carried out on the network [13, p. 145].

To ensure authenticity, confidentiality and integrity of the transmitted frames, MACsec utilizes Authenticated Encryption with Associated Data (AEAD) cipher suites. These encryption systems typically consist of a symmetric block cipher and a Message Authentication Code (MAC) generator [19]. The first entity of which provides the option to encrypt the payload of the message, while the second entity simultaneously generates a MAC over the entire message [3]. For usage, the IEEE 802.1AE standard specifies four variations of the Advances Encryption System in Galois/Counter Mode (AES-GCM) [13, p. 143ff].

III. RELATED WORK

To assess the operating principle of a MACsec-based security system in IEC 61850 compliant communication, it is necessary to understand both the working method of the communication inside a substation as well as the corresponding functionality of the MACsec security standard. The following related work display these important aspects and are therefore relevant for the implementation of an experimental setup for MACsec secured industrial communication.

Mackiewicz [17] describes the overall usage of the IEC 61850 protocol by displaying key features as well as the general aspects of IEC 61850 compliant communication. Since this standard represents a core part of the communication inside of power grid systems, it is vital to understand the corresponding aspects such as communication paths, model structures or data addressing in order to design a representative test environment.

Hussain *et al.* [4] published a paper assessing the IEC 62351 standard and its security mechanisms towards IEC 61850 compliant messaging. The publication initially describes the basic values and security goals of the safety standard and, building on this, which attacks can potentially be carried out on IEC 61850 messages to manipulate the internal workings of a SAS. At this point, the paper primarily focuses on the Ethernet-based message types GOOSE and SV and the associated decision not to encrypt them due to strict real-time delivery requirements.

Lackorzynski *et al.* [16] proposed modifications of the IEEE 802.1AE standard to improve MACsec for usage in industrial applications. In particular, the fragmentation of Ethernet frames was considered. This procedure is necessary, if messages exceed the Maximum Transmission Unit (MTU) and are thus possibly discarded by the recipient of the message. The presented implementation ensures this parameter and splits messages into multiple frames if it is exceeded. Additionally, the authors discuss the usage of different cipher suits instead of the AES-GCM 128/256 specified in the MACsec standard. The evaluation of their study shows that the ChaCha20-Poly1305 cipher is a promising alternative for industrial applications.

Moreira *et al.* [18] evaluate various approaches to introduce cybersecurity in SASs. Initially, a brief outline of the communication structures in substations is presented. Building on this, various established security approaches are explained and evaluated based on the protection objectives of the IEC 62351 standard. The authors also point out possible implementation problems, such as incompatibilities between the security systems and the communication protocols or the handling of redundant packets inside ring-topology networks. In the further course of the paper, they present the idea of MACsec-based communication security in SASs and the associated advantages and challenges that arise with it.

Hussain *et al.* [3] analyzed possible GOOSE security implementations based on their preceding review of the IEC 62351 standard [4]. Especially concerning the decision to abstain from implementing confidentiality in GOOSE messages, the authors argue that the critical payload of these messages demand encryption to provide efficient protection against attacks. However, in order to meet the real-time requirements of the protocol, they suggest replacing the RSA signature with encryption using an AEAD cipher. In the further course of the paper, they compare encryption and signature times between different AEAD ciphers and conclude based on the measurement results that these encryption systems pose a promising solution, which provides the opportunity to encrypt the message while simultaneously meeting the 3 ms timing requirement.

Building on the theoretical proposition of Moreira *et al.* [18], we formulate our evaluation of MACsec carried out for use in substations and other power systems based on the IEC 61850 standard. Along with this, we consider the findings of Hussain *et al.* [4] in relation to the proposed modifications of the security goals for Ethernet-based messaging in IEC 62351 for the implementation of our MACsec test environment. From this, our experimental setup enables us to discuss the advantages and disadvantages of MACsec in comparison with the security goals of the IEC 62351 standard.

IV. IMPLEMENTATION

To test the mode of communication in a SAS, we implement a test environment consisting of three Bay Level components. As the IEDs take part in all forms of message exchange inside the substation architecture, they are perfectly suitable for testing

the communication in conjunction with MACsec. In order to ensure the reproducibility of this study, we decided to use the Raspberry Pi 4 as hardware platform for all devices in the setup. With respect to the software used in the applications, we utilize the open-source library libiec61850¹ to establish the different communication types and data structures of the IEC 61850 standard. To integrate MACsec into the communication, we utilize the MACsec Linux kernel module², which establishes a configurable virtual interface on top of an existing network interface [21]. For the implementation of the time measurement in Chapter IV-C, we integrate the WiringPi³ library into the project. This enables us to access peripherals of the hardware platform and results in precise time measurement across several communication participants.

The remainder of this chapter is structured as follows: Chapter IV-A initially explains the overall structure of the test environment. Building on this, Chapter IV-B describes the additive MACsec configuration and the corresponding entities of the security standard. Lastly, Chapter IV-C elaborates on the subsequent test executions and transmission time measurement.

A. Structure of the Test Environment

As displayed in Figure 3, we configure IED1 as a publishing server and IED2 and IED3 as subscribing clients. Furthermore, the implementation of IED1 contains an XML data structure compliant to the specification of the Substation Configuration Language (SCL) in IEC 61850-6 [6]. This file contains the communication and processing information of the IED itself [17].

In our case, we integrated a measurement unit (MMXU) [9, p. 268] and a control unit (LLN0) [9, p. 164] into the SCL file. During runtime, IED1 continuously populates the data points of the measuring unit with sampled values of a sinusoidal function. In addition to the actual measurement, each sampled value contains a time stamp and a quality index [8, p. 61ff]. These values can then be requested by IED2 and IED3 via MMS messages.




Figure 3: Component Structure of the Test Setup

In addition to the TCP request-response communication via MMS messages, IED1 periodically publishes GOOSE and SV messages in a configurable interval containing the current value of the measurement. The configuration of the GOOSE messages, which contains the corresponding multicast MAC address, VLAN ID and VLAN priority, are equally stored in the control unit of the SCL file [10, p. 189]. For the transmission of the SV packets, an Application Protocol Data Unit (APDU) is configured during the initialization phase of the server. This object contains the floating-point number value of the measurement and a message time stamp. As the application progresses, the content of the APDU is periodically updated and published.

On the subscriber side, the subscription to the corresponding events (in this case GOOSE and SV) is implemented in software in the form of asynchronous handler functions, which subsequently log the incoming information.

B. MACsec integration in the Test Environment

Building on the general structure described in Chapter IV-A, the implementation of MACsec into the test setup can now be explained. Initially, we integrated all devices in the same CA by distributing a pre-shared CAK. Based on this key, the various SCs and SAs can be established as shown in Figure 3. For bidirectional MMS communication between two IEDs, one

¹source: <https://libiec61850.com/>

²source: <https://github.com/torvalds/linux/blob/master/drivers/net/macsec.c>

³source: <https://github.com/WiringPi/WiringPi>

SC is required for each communication direction. Using the example of packet exchange between IED1 and IED2, we have configured the secure channels SC0 and SC1 for this purpose. Each of these channels derives its own SAK from the CAK and establishes a secure connection for the duration of the SA. The establishment of SC3 and SC4 is carried out identically for MMS communication between IED1 and IED3.

With regard to the secure publication of GOOSE and SV packets, we established an additional SC (displayed in Figure 3 as SC2), which is connected to both IED2 and IED3. This configuration enables us to multicast the messages while simultaneously securing the payload and ensuring authenticity and integrity. Since the configuration of this test environment only allows the publication of GOOSE and SV packets originating from IED1, we only need one SC to secure them in MACsec. Consequently, if IED2 and IED3 are also meant to send secure multicast messages, two additional SCs must be configured.

C. Definition of the Test Procedures


To evaluate whether this MACsec implementation fulfills the requirements of the IEC 62351 standard, we conduct a measurement of the transmission times for each of the different message types. In order to achieve a precise time measurement, we expanded the implementation of the server and the client application to toggle a General Purpose Input/Output (GPIO) pin during transmission and reception of the associated frame type. By using an external logic analyzer, the times between the voltage level shifts can be measured. Since this measurement is performed by an external device, we do not need clock synchronization between the communication participants, which significantly reduces the implementation efforts of the measurement.

V. EVALUATION


Based on the implementation design explained in Chapter IV, a number of transmission time measurements can be executed. In the following, we initially compare the times in three different configurations in order to be able to investigate the temporal influence of the security module. The first step here is to measure without frame protection, followed by MACsec with integrity check and encryption and lastly solely MACsec integrity check. These measurements are carried out in the following chapters for all IEC 61850 message types.

A. Temporal Influence of MACsec on SV and GOOSE messages

For the GOOSE and SV measurement, IED1 was configured in the test setup so that the corresponding packets are published periodically at intervals of 500 ms. In the next step, the temporal delay to the handler function of the client side was measured. This measurement was then repeated 1000 times without additional computational load for both configurations and is therefore under ideal conditions. The results of these measurements are displayed in Figures 4a and 4b.



(a) Time comparison of a single GOOSE transmission



(b) Time comparison of a single SV transmission

As can be seen here, both Ethernet-based packets are transmitted in well below the IEC 61850 standard specification of 3 ms [20] regardless of the configuration. Furthermore, securing the packets results solely in an extension of the transmission time

of approximately $100\ \mu\text{s}$ for both message types. Lastly, it can be seen that activating the encryption in the AEAD cipher leads to a minimal increase in transmission time. This is likely due to the necessary rearrangement of the data payload into the Ethernet frame, which is not needed if only integrity checks are performed. Overall, the change in transmission times between these two configurations is nevertheless minimal at around $6\ \mu\text{s}$.

B. Temporal Influence of MACsec on MMS messages

For the MMS measurement, IED1 was configured to only perform the periodic update of the data points in the measurement unit of the internal SCL data structure. During this process, the time required for an MMS request-response sequence is measured on the client side. Since this message exchange involves two MMS messages, the resulting time is divided by two in the next step to determine the average transmission time. Identical to Chapter V-A, the measurement is then repeated 1000 times for all three configurations. The results of these measurements are displayed in Figure 5.




Figure 5: Time comparison of a single MMS transmission

As displayed in Figure 5, the time measurements for MMS messages vary only marginally regardless of which configuration is considered. It can be seen that the transmission times differ by a factor of 10 compared to the Ethernet-based packets from chapter V-A. This is likely due to the overhead caused by the additional processing in the higher layers of the OSI stack. Moreover, the time measurement for MMS transmission contains the application internal management of the SCL datastructure in IED1, which further impacts the absolute time value of the measurements. However, the trend in the variance between the different transmission times is consistent with the other measurements. Analog to GOOSE and SV, the IEC 61850 standard specifies a timing requirement for MMS packets of 100 ms [20]. As demonstrated in this measurement, the transmission time of MMS messaging with an active MACsec security module is well below the required time period.

VI. CONCLUSION

The aim of this paper was to investigate the extent to which the integration of MACsec in industrial communication would provide a viable alternative to the currently established security systems. In order to be able to evaluate this possibility correctly, we implemented a test environment consisting of three IEDs, which can be configured to exchange the desired IEC 61850 messages. Going further, we evaluated, based on our measurement results, whether the time and security requirements of the IEC 61850 and IEC 62351 standards can be considered fulfilled.

With regard to the time requirements of the messages, Chapter V shows that all packets are transmitted in well below the required time periods. In addition to this, the measurements prove that the optionally activatable encryption of the AEAD

cipher does not lead to a major increase in computational overhead. Therefore, confidentiality can be added to the security goals for all message types, regardless of the OSI model layer on which they operate.

Only the IEC 62351 requirement mandating that a complete end-to-end security model for power systems shall be implemented [4] cannot be fulfilled by MACsec. Due to the underlying architecture of this security standard, MACsec provides encryption of Ethernet-based packets, but must therefore be re-encrypted at each hop of the transmission. Other security standards such as TLS would fulfill this requirement, as they operate based on the TCP frame structure and can therefore be routed without a decryption of the message. However, simultaneously, packets below layer 4 of the OSI stack cannot be processed with TLS, which again would result in GOOSE and SV packets being transmitted unencrypted if implemented in a SAS. For this reason, we propose a hybrid implementation of both standards in a SAS for future work. In this scenario, MACsec could be used for LAN-internal communication security, while TLS provides the protection from a gateway component to external communication partners.

REFERENCES

- [1] Council of the European Union. *Directive (EU) 2022/2555 of the European Parliament and of the Council of 14 December 2022 on measures for a high common level of cybersecurity across the Union, amending Regulation (EU) No 910/2014 and Directive (EU) 2018/1972, and repealing Directive (EU) 2016/1148 (NIS 2 Directive)*. L 333, p. 80. Dec. 2022.
- [2] Federal Office for Information Security (BSI). *BSI-Standard 200-1 Information Security Management Systems (ISMS)*. Version 1.0. Oct. 2017.
- [3] S. M. Suhail Hussain, Shaik Mullapathi Farooq, and Taha Selim Ustun. "A method for achieving confidentiality and integrity in IEC 61850 GOOSE messages." In: *IEEE transactions on Power Delivery* 35.5 (2020), pp. 2565–2567.
- [4] S. M. Suhail Hussain, Taha Selim Ustun, and Akhtar Kalam. "A review of IEC 62351 security mechanisms for IEC 61850 message exchanges." In: *IEEE Transactions on Industrial Informatics* 16.9 (2019), pp. 5643–5654.
- [5] *IEC 61850:2023 SER Series – Communication networks and systems for power utility automation – ALL PARTS*. International Standard. Geneva, CH: International Electrotechnical Commission, 2023.
- [6] *IEC 61850:2023 SER Series – Communication networks and systems for power utility automation – Part 6 Configuration description language for communication in power utility automation systems related to IEDs*. International Standard. Geneva, CH: International Electrotechnical Commission, 2010.
- [7] *IEC 61850:2023 SER Series – Communication networks and systems for power utility automation – Part 7-1 Basic Communication Structure – Principles and Models*. International Standard. Geneva, CH: International Electrotechnical Commission, 2011.
- [8] *IEC 61850:2023 SER Series – Communication networks and systems for power utility automation – Part 7-3 Basic Communication Structure – Common data classes*. International Standard. Geneva, CH: International Electrotechnical Commission, 2010.
- [9] *IEC 61850:2023 SER Series – Communication networks and systems for power utility automation – Part 7-4 Basic Communication Structure – Compatible logical node classes and data object classes*. International Standard. Geneva, CH: International Electrotechnical Commission, 2010.
- [10] *IEC 61850:2023 SER Series – Communication networks and systems for power utility automation – Part 8-1 Specific communication service mapping (SCSM) – Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3*. International Standard. Geneva, CH: International Electrotechnical Commission, 2011.
- [11] *IEC 61850:2023 SER Series – Communication networks and systems for power utility automation – Part 90-5: Use of IEC 61850 to transmit synchrophasor information according to IEEE C37.118*. International Standard. Geneva, CH: International Electrotechnical Commission, 2012.
- [12] *IEC 62351:2024 SER Series – Power systems management and associated information exchange - Data and communications security - ALL PARTS*. International Standard. Geneva, CH: International Electrotechnical Commission, 2024.
- [13] *IEEE Std 802.1AE-2018 – IEEE Standard for Local and metropolitan area networks – Media Access Control (MAC) Security*. International Standard. New York, USA: The Institute of Electrical and Electronics Engineers, Inc., 2018.
- [14] Jakub W. Konka et al. "Traffic generation of IEC 61850 sampled values." In: *2011 IEEE First International Workshop on Smart Grid Modeling and Simulation (SGMS)*. 2011, pp. 43–48. DOI: 10.1109/SGMS.2011.6089025.
- [15] Nishchal Singh Kush et al. "Poisoned GOOSE: Exploiting the GOOSE protocol." In: *Proceedings of the Twelfth Australasian Information Security Conference (AISC 2014)[Conferences in Research and Practice in Information Technology, Volume 149]*. Australian Computer Society. 2014, pp. 17–22.
- [16] Tim Lackorzynski et al. "Enabling and optimizing MACsec for industrial environments." In: *IEEE Transactions on Industrial Informatics* 17.11 (2020), pp. 7599–7606.
- [17] Ralph E. Mackiewicz. "Overview of IEC 61850 and Benefits." In: *2006 IEEE Power Engineering Society General Meeting*. IEEE. 2006, 8–pp.

- [18] Naiara Moreira et al. “Cyber-security in substation automation systems.” In: *Renewable and Sustainable Energy Reviews* 54 (2016), pp. 1552–1562.
- [19] *Recommendation for Block Cipher Modes of Operation: Galois/Counter Mode (GCM) and GMAC*. Public Recommendation. Gaithersburg, USA: National Institute of Standards and Technology, 2007.
- [20] Mikel Rodríguez et al. “A fixed-latency architecture to secure GOOSE and sampled value messages in substation systems.” In: *IEEE Access* 9 (2021), pp. 51646–51658.
- [21] Sabrina Dubroca. *ip-macsec(8) – Linux manual page*. <https://man7.org/linux/man-pages/man8/ip-macsec.8.html>. Accessed: 2024-05-13.
- [22] SGRWin - Network Solutions Suite. *Basic understanding of IEC 61850*. <https://www.sgrwin.com/goose-mms-and-sv-protocols/>. Accessed: 2024-04-30.
- [23] Typhoon HIL Inc. *IEC 61850 Sampled Values protocol*. https://www.typhoon-hil.com/documentation/typhoon-hil-software-manual/References/iec_61850_sampled_values_protocol.html. Accessed: 2024-04-30.
- [24] Taha Selim Ustun, Shaik Mullapathi Farooq, and S. M. Suhail Hussain. “Implementing secure routable GOOSE and SV messages based on IEC 61850-90-5.” In: *IEEE Access* 8 (2020), pp. 26162–26171.
- [25] Taha Selim Ustun and S. M. Suhail Hussain. “IEC 62351-4 security implementations for IEC 61850 MMS messages.” In: *IEEE Access* 8 (2020), pp. 123979–123985.
- [26] “Zweites Gesetz zur Erhöhung der Sicherheit informationstechnischer Systeme*.” In: *Bundesgesetzblatt, ausgegeben zu Bonn* (2021). Teil I Nr. 25, pp. 1122–1138.