


 JOKWANG I.L.I <small>SINCE 1968</small>	Specification & Calculation Sheet	 LG Chem Yeosu Complex
---	-----------------------------------	---


DOCUMENT NO.	180760-E2-P-054-2-S-0002
PROJECT NAME	Yeosu No. 2 Complex Project
ITEM NO.	Pressure Safety Valve
COMPANY NAME	LG Chem, Ltd.
SITE LOCATION	Yeosu, Korea
CONTRACTOR NAME	GS E&C
PROJECT NO.	180760
PURCHASE ORDER NO.	180760-E2-GS-PO-P-054-2
VENDOR NAME	Jokwang I.L.I


Action Code	Description
<input type="checkbox"/> 1	Approved without comment, Vendor to submit "FINAL"
<input type="checkbox"/> 2	Approved with comment, Vendor to amend and submit "FOR FINAL"
<input type="checkbox"/> 3	Vendor to amend and re-submit "FOR APPROVAL"
<input type="checkbox"/> 4	Not Reviewed/Considered unacceptable Quality, Vendor to re-submit "FOR APPROVAL"


2	24.MAR.21	FINAL	S.W.PARK	M.J.LEE	J.H.LEEM
1	27.JAN.21	FINAL	S.W.PARK	M.J.LEE	J.H.LEEM
0	30.JUL.20	FOR FINAL	S.W.PARK	J.G.YOON	J.H.LEEM
B	14.JUL.20	FOR APPROVAL	S.W.PARK	J.G.YOON	J.H.LEEM
A	20 APR. 20	FOR APPROVAL	S.W.PARK	J.G.YOON	S.C.KIM
REV.	DATE	DESCRIPTION	PREP'D	CHK'D	APP'D


 JOKWANG I.L.I			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		1 of 20		Rev . No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
		Checked		S.C.KIM		Approved		S.C.KIM		
GENERAL	P&ID No.	1	H465-E2-PID-201 2							
	Tag No.	2	E2-PSV-2104A/B							
	Service Line	3	E-21 0 (Dilution Steam Blowdown Cooler) SS							
	Model No.	4	JSV-FF100		Calculation					
	Quantity	5	2							
TYPE	Nozzle Type	6	Full Nozzle		Calculation of Area $A1 = 13160 \times W1 \times (\sqrt{ZT/M}) / (C \times Kd \times (P \times 1.21 + 101.325) \times Kb \times Kc)$ $= 13160 \times 526 \times (\sqrt{1 \times 455.5 / 18.02}) / (348.47 \times 0.831 \times (794 \times 1.21 + 101.325) \times 1 \times 1)$ $= \underline{\underline{113.159473}} \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	1"X2"		Calculation of Capacity $W = A \times C \times Kd \times (P \times 1.21 + 101.325) \times Kb \times Kc / (13160 \times \sqrt{ZT/M})$ $= 188.39 \times 348.47 \times 0.831 \times (794 \times 1.21 + 101.325) \times 1 \times 1 / (13160 \times \sqrt{1 \times 455.5 / 18.02})$ $= \underline{\underline{876}} \text{ kg/h}$					
	Inlet. Rating / Facing	12	ASME CL.150 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		W Valve Capacity 876 kg/h W1 Required Capacity 526 kg/h P Set Pressure 794 KPag A1 Calculated Area 113.159473 mm ² A Selected Area 188.39 mm ² Kd Coefficient of Discharge 0.831 C Coefficient base on Ratio of Specific Heat 348.47 T Kelvin Temperature 455.5 K M Molecular Weight 18.02 Z Compressibility Factor 1 Kb Correction Factor Due to Back Pressure 1 Kc Correction Factor for a rupture disk 1					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.							
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	Chrome Alloy(SWOSC-B)							
	Bellows	21	None							
BASIS	Approved by	22	KGS UV STAMP		Remarks <u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver) <u>*Remark</u> - Operating Pressure : 2 kgf/cm ² g - Setting Pressure : 8.1 kgf/cm ² g - Design Pressure : 8.1 /FV kgf/cm ² g - Built-up Back Pressure : 0.14 kgf/cm ² g					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520							
	Fire	26	Yes							
	Sizing Basis	27	External Fire							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	Blowdown / GAS		Remarks <u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver) <u>*Remark</u> - Operating Pressure : 2 kgf/cm ² g - Setting Pressure : 8.1 kgf/cm ² g - Design Pressure : 8.1 /FV kgf/cm ² g - Built-up Back Pressure : 0.14 kgf/cm ² g					
	Mol. Weight / Specific Gravity	30	18.02							
	Compressibility Factor	31	1							
	Ratio of Specific Heat	32	1.316							
	Viscosity	33	-							
	Operating / Relieving Temp.	34	133.2 / 182.5 °C							
	Design Min. / Design Max. Temp.	35	-18/150 °C							
	Operating / Set Pressure	36	0.196 / 0.794 MPag							
	Design Pressure / C.D.T.P	37	0.794/FV / 0.80194 MPag							
	Back Pressure	Superimposed - Constant	38	- MPag						
		Superimposed - Variable	39	- MPag						
		Built-up	40	0.014 MPag						
		Total	41	0.014 MPag						
	Allowable Overpressure	42	21 %							
	Closing Pressure / Blowdown(%)	43	Min. 0.73842 MPag / 7%							
SIZING & SELECTION	Required Capacity	44	526 kg/h		*Paint Color(*) Painting : P-5 (RAL 9006 Silver) *Remark - Operating Pressure : 2 kgf/cm ² g - Setting Pressure : 8.1 kgf/cm ² g - Design Pressure : 8.1 /FV kgf/cm ² g - Built-up Back Pressure : 0.14 kgf/cm ² g					
	Valve Actual Capacity	45	876 kg/h							
	Calculated Orifice Area	46	113.159473 mm ²							
	Selected Orifice Area	47	188.39 mm ²							
	Orifice Dia.(mm)	48	E1(15.5)							
ETC	Paint System & Color	49	See Remark		*Paint Color(*) Painting : P-5 (RAL 9006 Silver) *Remark - Operating Pressure : 2 kgf/cm ² g - Setting Pressure : 8.1 kgf/cm ² g - Design Pressure : 8.1 /FV kgf/cm ² g - Built-up Back Pressure : 0.14 kgf/cm ² g					
	Test Gag	50	Yes							
	Bug screen	51	No							


 JOKWANG I.L.I			Pressure Safety & Relief Valve Specification and Calculation Sheet										
			Sheet No.		2 of 20		Rev. No		1				
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO								
			Project No.										
			Date		2021-01-27		By		S.W.PARK				
		Checked		S.C.KIM		Approved		S.C.KIM					
GENERAL	P&ID No.		1	H465-E2-PID-2002A									
	Tag No.		2	E2-PSV-2120									
	Service Line		3	PT-201A (P-201 Steam Turbine)									
	Model No.		4	JSV-FF100		Calculation							
	Quantity		5	1									
TYPE	Nozzle Type		6	Full Nozzle		Calculation of Area							
	Design Type		7	Conventional		$A1 = 190.4 \times W1 / ((P \times 1.1 + 101.325) \times Kd \times Kb \times Kc \times Kn \times Ksh)$ $= 190.4 \times 35753 / ((1765 \times 1.1 + 101.325) \times 0.831 \times 1 \times 1 \times 1 \times 0.872)$ $= \underline{\underline{4598.654269}} \text{ mm}^2$							
	Bonnet Type		8	Open									
	Lever Type		9	Plain Lever									
	Cap Type		10	Plain									
CONN.	Size. Inlet / Outlet		11	6"X8"									
	Inlet. Rating / Facing		12	ASME CL.300 RF									
	Outlet. Rating / Facing		13	ASME CL.150 RF									
MATERIALS	Body (Base)		14	SA216 WCB		Calculation of Capacity							
	Bonnet		15	SA216 WCB									
	Seat		16	316 SS-st.		$W = A \times (P \times 1.1 + 101.325) \times Kd \times Kb \times Kc \times Kn \times Ksh / 190.4$ $= 7132.89 \times (1765 \times 1.1 + 101.325) \times 0.831 \times 1 \times 1 \times 1 \times 0.872 / 190.4$ $= \underline{\underline{55456}} \text{ kg/h}$							
	Disc		17	316 SS-st.									
	Guide		18	316 SS									
	Gasket (Bonnet)		19	Graphite									
	Spring		20	316 SS									
	Bellows		21	None									
BASIS	Approved by		22	KGS UV STAMP		<div>W</div> <div>Valve Capacity</div> <div>55456 kg/h</div>							
	Comply with NACE		23	No									
	EN 10204		24	No									
	Code		25	API RP 520									
	Fire		26	No									
	Sizing Basis		27	Blocked Outlet									
	Rupture Disk		28	No									
SERVICE CONDITION	Fluid / State		29	MP Steam / STEAM		W1	Valve Capacity		55456 kg/h				
	Mol. Weight / Specific Gravity		30	18.02		W1	Required Capacity		35753 kg/h				
	Compressibility Factor		31	0.971		P	Set Pressure		1765 KPag				
	Ratio of Specific Heat		32	1.290		A1	Calculated Area		4598.654269 mm ²				
	Viscosity		33	-		A	Selected Area		7132.89 mm ²				
	Operating / Relieving Temp.		34	304 / 344 °C		Kd	Coefficient of Discharge		0.831				
	Design Min. / Design Max. Temp.		35	350 °C		Ksh	Steam Correction Factor		0.872				
	Operating / Set Pressure		36	1.569 / 1.765 MPag		Kb	Correction Factor Due to Back Pressure		1				
	Design Pressure / C.D.T.P		37	1.765/F.V / 1.8356 MPag		Kc	Correction Factor for a rupture disk		1				
	Back Pressure	Superimposed - Constant	38	0 MPag		Kn	Correction Factor for Napier equation		1				
		Superimposed - Variable	39	- MPag									
		Built-up	40	0.15 MPag		Remarks							
		Total	41	0.15 MPag									
	Allowable Overpressure		42	10 %		<u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)							
	Closing Pressure / Blowdown(%)		43	Min. 1.64145 MPag / 7%									
	Required Capacity		44	35753 kg/h						<u>*Remark</u> - Operating Pressure : 16 kgf/cm ² g - Setting Pressure : 18 kgf/cm ² g - Design Pressure : 18/F.V kgf/cm ² g - Built-up Back Pressure : 1.526 kgf/cm ² g			
	Valve Actual Capacity		45	55456 kg/h									
	Calculated Orifice Area		46	4598.654269 mm ²									
Selected Orifice Area		47	7132.89 mm ²										
Orifice Dia.(mm)		48	Q(95.3)										
ETC	Paint System & Color		49	See Remark									
	Test Gag		50	Yes									
	Bug screen		51	No									


 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		3 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-2008A							
	Tag No.	2	E2-PSV-2121							
	Service Line	3	PT-205A (P-205 Steam Turbine)							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		<div>Calculation of Area</div> $A1 = 190.4 \times W1 / ((P \times 1.1 + 101.325) \times Kd \times Kb \times Kc \times Kn \times Ksh)$ $= 190.4 \times 34875 / ((1765 \times 1.1 + 101.325) \times 0.831 \times 1 \times 1 \times 1 \times 0.872)$ $= \underline{4485.723369} \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Open							
	Lever Type	9	Plain Lever							
	Cap Type	10	Plain							
CONN.	Size. Inlet / Outlet	11	6"X8"		<div>Calculation of Capacity</div> $W = A \times (P \times 1.1 + 101.325) \times Kd \times Kb \times Kc \times Kn \times Ksh / 190.4$ $= 7132.89 \times (1765 \times 1.1 + 101.325) \times 0.831 \times 1 \times 1 \times 1 \times 0.872 / 190.4$ $= \underline{55456} \text{ kg/h}$					
	Inlet. Rating / Facing	12	ASME CL.300 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		<div>Calculation of Capacity</div> $W = A \times (P \times 1.1 + 101.325) \times Kd \times Kb \times Kc \times Kn \times Ksh / 190.4$ $= 7132.89 \times (1765 \times 1.1 + 101.325) \times 0.831 \times 1 \times 1 \times 1 \times 0.872 / 190.4$ $= \underline{55456} \text{ kg/h}$					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.							
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	Graphite							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	KGS UV STAMP		<div>Calculation of Capacity</div> $W = A \times (P \times 1.1 + 101.325) \times Kd \times Kb \times Kc \times Kn \times Ksh / 190.4$ $= 7132.89 \times (1765 \times 1.1 + 101.325) \times 0.831 \times 1 \times 1 \times 1 \times 0.872 / 190.4$ $= \underline{55456} \text{ kg/h}$					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520							
	Fire	26	No							
	Sizing Basis	27	Blocked Outlet							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	MP Steam / STEAM		W	Valve Capacity	55456 kg/h			
	Mol. Weight / Specific Gravity	30	18.02		W1	Required Capacity	34875 kg/h			
	Compressibility Factor	31	0.971		P	Set Pressure	1765 KPag			
	Ratio of Specific Heat	32	1.290		A1	Calculated Area	4485.723369 mm ²			
	Viscosity	33	-		A	Selected Area	7132.89 mm ²			
	Operating / Relieving Temp.	34	306 / 344 °C		Kd	Coefficient of Discharge	0.831			
	Design Min. / Design Max. Temp.	35	350 °C		Ksh	Steam Correction Factor	0.872			
	Operating / Set Pressure	36	1.569 / 1.765 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Design Pressure / C.D.T.P	37	1.765/F.V / 1.8356 MPag		Kc	Correction Factor for a rupture disk	1			
	Back Pressure	Superimposed - Constant	38	0 MPag		Kn	Correction Factor for Napier equation	1		
		Superimposed - Variable	39	- MPag						
		Built-up	40	0.15 MPag						
		Total	41	0.15 MPag						
	Allowable Overpressure	42	10 %		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 16 kgf/cm²g - Setting Pressure : 18 kgf/cm²g - Design Pressure : 18/F.V kgf/cm²g - Built-up Back Pressure : 1.526 kgf/cm²g </p>					
	Closing Pressure / Blowdown(%)	43	Min. 1.64145 MPag / 7%							
	Required Capacity	44	34875 kg/h							
	Valve Actual Capacity	45	55456 kg/h							
	Calculated Orifice Area	46	4485.723369 mm ²							
	SIZING & SELECTION	Selected Orifice Area	47	7132.89 mm ²		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 16 kgf/cm²g - Setting Pressure : 18 kgf/cm²g - Design Pressure : 18/F.V kgf/cm²g - Built-up Back Pressure : 1.526 kgf/cm²g </p>				
		Orifice Dia.(mm)	48	Q(95.3)						
			-							
			-							
			-							
ETC	Paint System & Color	49	See Remark		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 16 kgf/cm²g - Setting Pressure : 18 kgf/cm²g - Design Pressure : 18/F.V kgf/cm²g - Built-up Back Pressure : 1.526 kgf/cm²g </p>					
	Test Gag	50	Yes							
	Bug screen	51	No							


 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		4 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-3008							
	Tag No.	2	E2-PSV-3127A/B							
	Service Line	3	E-320A/B (Pyrolysis Gasoline Stripper Reboiler) TS							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	2							
TYPE	Nozzle Type	6	Full Nozzle		Calculation of Area					
	Design Type	7	Bellows		$A1 = 11.78 * W1 * (\sqrt{G / (P1 - Pb)}) / (Kd * Kb * Kc * Kv)$ $= 11.78 * 165 * \sqrt{(0.6652 / (463.1 - 41))} / (0.615 * 1 * 1)$ $= \underline{125.464992} \text{ mm}^2$					
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	1"X2"							
	Inlet. Rating / Facing	12	ASME CL.150 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		Calculation of Capacity					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.		$W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 132.9 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.6652 / (463.1 - 41))})$ $= 174.80 \text{ l/min}$ $= \underline{10.5} \text{ m}^3/\text{h}$					
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	Chrome Alloy(SWOSC-B)							
	Bellows	21	316L SS							
BASIS	Approved by	22	KGS UV STAMP		<div> <div>W</div> <div>Valve Capacity</div> <div>174.80 l/min</div> </div> <div> <div>W1</div> <div>Required Capacity</div> <div>165 l/min</div> </div> <div> <div>P</div> <div>Set Pressure</div> <div>421 KPag</div> </div> <div> <div>A1</div> <div>Calculated Area</div> <div>125.464992 mm²</div> </div> <div> <div>A</div> <div>Selected Area</div> <div>132.9 mm²</div> </div> <div> <div>Kd</div> <div>Coefficient of Discharge</div> <div>0.615</div> </div> <div> <div>G</div> <div>Specific Gravity</div> <div>0.6652</div> </div> <div> <div>Pb</div> <div>Back Pressure</div> <div>41 KPag</div> </div> <div> <div>Kb</div> <div>Correction Factor Due to Back Pressure</div> <div>1</div> </div> <div> <div>Kc</div> <div>Correction Factor for a rupture disk</div> <div>1</div> </div> <div> <div>Kv</div> <div>Correction Factor due to Viscosity</div> <div>1</div> </div> <div> <div>P1</div> <div>Set Pressure plus Overpressure</div> <div>463.1 KPag</div> </div>					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520-Certification							
	Fire	26	No							
	Sizing Basis	27	Blocked Outlet (with heat input)							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	Reboiler Liquid / LIQUID							
	Mol. Weight / Specific Gravity	30	0.6652							
	Compressibility Factor	31	-							
	Ratio of Specific Heat	32	-							
	Viscosity	33	-							
	Operating / Relieving Temp.	34	125 / 165 °C							
	Design Min. / Design Max. Temp.	35	-18/165 °C							
	Operating / Set Pressure	36	0.092 / 0.421 MPag							
	Design Pressure / C.D.T.P	37	0.421/HV / 0.42521 MPag							
	Back Pressure	Superimposed - Constant	38	0.03 MPag						
		Superimposed - Variable	39	- MPag						
		Built-up	40	0.011 MPag						
		Total	41	0.041 MPag						
	Allowable Overpressure	42	10 %							
	Closing Pressure / Blowdown(%)	43	Min. 0.3579 MPag / 14.9881%							
SIZING & SELECTION	Required Capacity	44	9.9 m ³ /h		<div>Remarks</div> <div> <u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver) </div> <div> <u>*Remark</u> - Operating Pressure : 0.94 kgf/cm²g - Setting Pressure : 4.3 kgf/cm²g - Design Pressure : 4.3/H.V kgf/cm²g - Constant Back Pressure : 0.3 kgf/cm²g - Built-up Back Pressure : 0.112 kgf/cm²g </div>					
	Valve Actual Capacity	45	10.5 m ³ /h							
	Calculated Orifice Area	46	125.464992 mm ²							
	Selected Orifice Area	47	132.9 mm ²							
	Orifice Dia.(mm)	48	D1(13)							
ETC	Paint System & Color	49	See Remark							
	Test Gag	50	Yes							
	Bug screen	51	Yes							


 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		5 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-9206							
	Tag No.	2	E2-PSV-9037A/B							
	Service Line	3	C-941 GTG FG Boosting Compressor 1 st stage discharge							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	2							
TYPE	Nozzle Type	6	Full Nozzle		Calculation of Area					
	Design Type	7	Bellows		$A1 = 13160 \times W1 \times (\sqrt{ZT/M}) / (C \times Kd \times (P \times 1.1 + 101.325) \times Kb \times Kc)$ $= 13160 \times 7800 \times (\sqrt{0.9913 \times 392.6 / 16}) / (345.08 \times 0.831 \times (1401 \times 1.1 + 101.325) \times 1 \times 1)$ $= \underline{1074.884601} \text{ mm}^2$					
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	3"X4"							
	Inlet. Rating / Facing	12	ASME CL.300 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		Calculation of Capacity					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.		$W = A \times C \times Kd \times (P \times 1.1 + 101.325) \times Kb \times Kc / (13160 \times \sqrt{ZT/M})$ $= 1187.74 \times 345.08 \times 0.831 \times (1401 \times 1.1 + 101.325) \times 1 \times 1 / (13160 \times \sqrt{(0.9913 \times 392.6 / 16)})$ $= \underline{8619} \text{ kg/h}$					
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	Chrome Alloy(SAE9254)							
	Bellows	21	316L SS							
BASIS	Approved by	22	KGS UV STAMP							
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520							
	Fire	26	No							
	Sizing Basis	27	Blocked Outlet							
	Rupture Disk	28	No		W	Valve Capacity	8619 kg/h			
SERVICE CONDITION	Fluid / State	29	Fuel Gas / GAS		W1	Required Capacity	7800 kg/h			
	Mol. Weight / Specific Gravity	30	16		P	Set Pressure	1401 KPag			
	Compressibility Factor	31	0.9913		A1	Calculated Area	1074.884601 mm ²			
	Ratio of Specific Heat	32	1.28		A	Selected Area	1187.74 mm ²			
	Viscosity	33	-		Kd	Coefficient of Discharge	0.831			
	Operating / Relieving Temp.	34	119.6 / 119.6 °C		C	Coefficient base on Ratio of Specific Heat	345.08			
	Design Min. / Design Max. Temp.	35	-18/180 °C		T	Kelvin Temperature	392.6 K			
	Operating / Set Pressure	36	1.184 / 1.401 MPag		M	Molecular Weight	16			
	Design Pressure / C.D.T.P	37	1.401 / 1.41501 MPag		Z	Compressibility Factor	0.9913			
	Back Pressure	Superimposed - Constant	38	0.03 MPag		Kb	Correction Factor Due to Back Pressure	1		
		Superimposed - Variable	39	- MPag		Kc	Correction Factor for a rupture disk	1		
		Built-up	40	0.14 MPag		<div>Remarks</div>				
		Total	41	0.17 MPag						
	Allowable Overpressure	42	10 %							
	Closing Pressure / Blowdown(%)	43	Min. 1.30293 MPag / 7%		<u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)					
	SIZING & SELECTION	Required Capacity	44	7800 kg/h		<u>*Remark</u> - Operating Pressure : 12.07 kgf/cm ² g - Setting Pressure : 14.3 kgf/cm ² g - Design Pressure : 14.3 kgf/cm ² g - Constant Back Pressure : 0.3 kgf/cm ² g - Built-up Back Pressure : 1.43 kgf/cm ² g				
		Valve Actual Capacity	45	8619 kg/h						
Calculated Orifice Area		46	1074.884601 mm ²							
Selected Orifice Area		47	1187.74 mm ²							
Orifice Dia.(mm)		48	K(38.9)							
			-							
ETC	Paint System & Color	49	See Remark							
	Test Gag	50	Yes							
	Bug screen	51	Yes							


 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		6 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-9206							
	Tag No.	2	E2-PSV-9038A/B							
	Service Line	3	C-941 GTG FG Boosting Compressor 2nd stage discharge							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	2							
TYPE	Nozzle Type	6	Full Nozzle		Calculation of Area					
	Design Type	7	Conventional		$A1 = 13160 \times W1 \times (\sqrt{ZT/M}) / (C \times Kd \times (P \times 1.1 + 101.325) \times Kb \times Kc)$ $= 13160 \times 7800 \times (\sqrt{0.9864 \times 395.2/16}) / (345.08 \times 0.831 \times (3746 \times 1.1 + 101.325) \times 1 \times 1)$ $= \underline{418.498758} \text{ mm}^2$					
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	2"X3"							
	Inlet. Rating / Facing	12	ASME CL.300 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		Calculation of Capacity					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.		$W = A \times C \times Kd \times (P \times 1.1 + 101.325) \times Kb \times Kc / (13160 \times \sqrt{ZT/M})$ $= 506.45 \times 345.08 \times 0.831 \times (3746 \times 1.1 + 101.325) \times 1 \times 1 / (13160 \times \sqrt{(0.9864 \times 395.2/16)})$ $= \underline{9439} \text{ kg/h}$					
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	Chrome Alloy(SWOSC-B)							
	Bellows	21	None							
BASIS	Approved by	22	KGS UV STAMP							
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520							
	Fire	26	No							
	Sizing Basis	27	Blocked Outlet							
	Rupture Disk	28	No		W	Valve Capacity	9439 kg/h			
SERVICE CONDITION	Fluid / State	29	Fuel Gas / GAS		W1	Required Capacity	7800 kg/h			
	Mol. Weight / Specific Gravity	30	16		P	Set Pressure	3746 KPag			
	Compressibility Factor	31	0.9864		A1	Calculated Area	418.498758 mm ²			
	Ratio of Specific Heat	32	1.28		A	Selected Area	506.45 mm ²			
	Viscosity	33	-		Kd	Coefficient of Discharge	0.831			
	Operating / Relieving Temp.	34	122.2 / 122.2 °C		C	Coefficient base on Ratio of Specific Heat	345.08			
	Design Min. / Design Max. Temp.	35	-18/180 °C		T	Kelvin Temperature	395.2 K			
	Operating / Set Pressure	36	3.118 / 3.746 MPag		M	Molecular Weight	16			
	Design Pressure / C.D.T.P	37	3.746 / 3.753766 MPag		Z	Compressibility Factor	0.9864			
	Back Pressure	Superimposed - Constant	38	0.0294 MPag		Kb	Correction Factor Due to Back Pressure	1		
		Superimposed - Variable	39	- MPag		Kc	Correction Factor for a rupture disk	1		
		Built-up	40	0.3452 MPag		<div>Remarks</div>				
		Total	41	0.3746 MPag						
	Allowable Overpressure	42	10 %							
	Closing Pressure / Blowdown(%)	43	Min. 3.48378 MPag / 7%		<u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)					
	SIZING & SELECTION	Required Capacity	44	7800 kg/h		<u>*Remark</u> - Operating Pressure : 31.8 kgf/cm ² g - Setting Pressure : 38.2 kgf/cm ² g - Design Pressure : 38.2 kgf/cm ² g - Constant Back Pressure : 0.3 kgf/cm ² g - Built-up Back Pressure : 3.5 kgf/cm ² g				
		Valve Actual Capacity	45	9439 kg/h						
Calculated Orifice Area		46	418.498758 mm ²							
Selected Orifice Area		47	506.45 mm ²							
Orifice Dia.(mm)		48	H(25.4)							
			-							
ETC	Paint System & Color	49	See Remark							
	Test Gag	50	Yes							
	Bug screen	51	No							


 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		7 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-9001A							
	Tag No.	2	E2-PSV-9003							
	Service Line	3	PT-901A (SHP BFW PUMP P-901A Turbine)							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		<div>Calculation of Area</div> $A1 = 190.4 * W1 / ((P * 1.1 + 101.325) * Kd * Kb * Kc * Kn * Ksh)$ $= 190.4 * 57600 / ((1765 * 1.1 + 101.325) * 0.831 * 1 * 1 * 0.943)$ $= \underline{\underline{6850.867165}} \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Open							
	Lever Type	9	Plain Lever							
	Cap Type	10	Plain							
CONN.	Size. Inlet / Outlet	11	6"X8"		<div>Calculation of Capacity</div> $W = A * (P * 1.1 + 101.325) * Kd * Kb * Kc * Kn * Ksh / 190.4$ $= 7132.89 * (1765 * 1.1 + 101.325) * 0.831 * 1 * 1 * 1 * 0.943 / 190.4$ $= \underline{\underline{59971}} \text{ kg/h}$					
	Inlet. Rating / Facing	12	ASME CL.300 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		<div>Calculation of Capacity</div> $W = A * (P * 1.1 + 101.325) * Kd * Kb * Kc * Kn * Ksh / 190.4$ $= 7132.89 * (1765 * 1.1 + 101.325) * 0.831 * 1 * 1 * 1 * 0.943 / 190.4$ $= \underline{\underline{59971}} \text{ kg/h}$					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.							
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	Graphite							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	KGS UV STAMP		<div>Calculation of Capacity</div> $W = A * (P * 1.1 + 101.325) * Kd * Kb * Kc * Kn * Ksh / 190.4$ $= 7132.89 * (1765 * 1.1 + 101.325) * 0.831 * 1 * 1 * 1 * 0.943 / 190.4$ $= \underline{\underline{59971}} \text{ kg/h}$					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520							
	Fire	26	No							
	Sizing Basis	27	Blocked Outlet							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	MP Steam / STEAM		W	Valve Capacity	59971 kg/h			
	Mol. Weight / Specific Gravity	30	18.02		W1	Required Capacity	57600 kg/h			
	Compressibility Factor	31	0.951		P	Set Pressure	1765 KPag			
	Ratio of Specific Heat	32	1.36		A1	Calculated Area	6850.867165 mm ²			
	Viscosity	33	-		A	Selected Area	7132.89 mm ²			
	Operating / Relieving Temp.	34	270 / 270 °C		Kd	Coefficient of Discharge	0.831			
	Design Min. / Design Max. Temp.	35	350 °C		Ksh	Steam Correction Factor	0.943			
	Operating / Set Pressure	36	1.47 / 1.765 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Design Pressure / C.D.T.P	37	1.765/F.V / 1.81795 MPag		Kc	Correction Factor for a rupture disk	1			
	Back Pressure	Superimposed - Constant	38	0 MPag		Kn	Correction Factor for Napier equation	1		
		Superimposed - Variable	39	- MPag						
		Built-up	40	0.09 MPag						
		Total	41	0.09 MPag						
	Allowable Overpressure	42	10 %		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 15 kgf/cm²g - Setting Pressure : 18 kgf/cm²g - Design Pressure : 18/F.V kgf/cm²g - Built-up Back Pressure : 0.92kgf/cm²g </p>					
	Closing Pressure / Blowdown(%)	43	Min. 1.64145 MPag / 7%							
	Required Capacity	44	57600 kg/h							
	Valve Actual Capacity	45	59971 kg/h							
	Calculated Orifice Area	46	6850.867165 mm ²							
SIZING & SELECTION	Selected Orifice Area	47	7132.89 mm ²							
	Orifice Dia.(mm)	48	Q(95.3)							
			-							
			-							
ETC	Paint System & Color	49	See Remark							
	Test Gag	50	Yes							
	Bug screen	51	No							


 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		8 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.		1	H465-E2-PID-9001A						
	Tag No.		2	E2-PSV-9009						
	Service Line		3	P-901A-E3 (SHP BFW PUMP P-901A Turbine Gland Condenser) TS						
	Model No.		4	JSV-FF100		Calculation				
	Quantity		5	1						
TYPE	Nozzle Type		6	Full Nozzle		Calculation of Area $A1 = 190.4 * W1 / ((P * 1.1 + 101.325) * Kd * Kb * Kc * Kn * Ksh)$ $= 190.4 * 65.5 / ((1358 * 1.1 + 101.325) * 0.831 * 1 * 1 * 1)$ $= \underline{9.408329} \text{ mm}^2$				
	Design Type		7	Conventional						
	Bonnet Type		8	Open						
	Lever Type		9	Plain Lever						
	Cap Type		10	Plain						
CONN.	Size. Inlet / Outlet		11	3/4"X1"		Calculation of Capacity $W = A * (P * 1.1 + 101.325) * Kd * Kb * Kc * Kn * Ksh / 190.4$ $= 132.9 * (1358 * 1.1 + 101.325) * 0.831 * 1 * 1 * 1 / 190.4$ $= \underline{925} \text{ kg/h}$				
	Inlet. Rating / Facing		12	ASME CL.150 RF						
	Outlet. Rating / Facing		13	ASME CL.150 RF						
MATERIALS	Body (Base)		14	SA216 WCB		Calculation of Capacity $W = A * (P * 1.1 + 101.325) * Kd * Kb * Kc * Kn * Ksh / 190.4$ $= 132.9 * (1358 * 1.1 + 101.325) * 0.831 * 1 * 1 * 1 / 190.4$ $= \underline{925} \text{ kg/h}$				
	Bonnet		15	SA216 WCB						
	Seat		16	316 SS-st.						
	Disc		17	316 SS-st.						
	Guide		18	316 SS						
	Gasket (Bonnet)		19	Graphite						
	Spring		20	Chrome Alloy(SWOSC-B)						
	Bellows		21	None						
BASIS	Approved by		22	KGS UV STAMP		W Valve Capacity 925 kg/h W1 Required Capacity 65.5 kg/h P Set Pressure 1358 KPag A1 Calculated Area 9.408329 mm² A Selected Area 132.9 mm² Kd Coefficient of Discharge 0.831 Ksh Steam Correction Factor 1 Kb Correction Factor Due to Back Pressure 1 Kc Correction Factor for a rupture disk 1 Kn Correction Factor for Napier equation 1				
	Comply with NACE		23	No						
	EN 10204		24	No						
	Code		25	API RP 520						
	Fire		26	No						
	Sizing Basis		27	Blocked Outlet						
	Rupture Disk		28	No						
SERVICE CONDITION	Fluid / State		29	Cooling Water / STEAM		Remarks <u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver) <u>*Remark</u> - Operating Pressure : 5 kgf/cm²g - Setting Pressure : 13.85 kgf/cm²g - Design Pressure : 13.85 kgf/cm²g - Built-up Back Pressure : 0.88 kgf/cm²g				
	Mol. Weight / Specific Gravity		30	18.02						
	Compressibility Factor		31	0.904						
	Ratio of Specific Heat		32	1.313						
	Viscosity		33	0.016 cP						
	Operating / Relieving Temp.		34	41.06 / 201.2 °C						
	Design Min. / Design Max. Temp.		35	65 °C						
	Operating / Set Pressure		36	0.49 / 1.358 MPag						
	Design Pressure / C.D.T.P		37	1.358 / 1.358 MPag						
	Back Pressure	Superimposed - Constant		38	0 MPag					
		Superimposed - Variable		39	- MPag					
		Built-up		40	0.086 MPag					
		Total		41	0.086 MPag					
	Allowable Overpressure		42	10 %						
	Closing Pressure / Blowdown(%)		43	Min. 1.26294 MPag / 7%						
SIZING & SELECTION	Required Capacity		44	65.5 kg/h		*Paint Color(*) Painting : P-5 (RAL 9006 Silver) *Remark - Operating Pressure : 5 kgf/cm²g - Setting Pressure : 13.85 kgf/cm²g - Design Pressure : 13.85 kgf/cm²g - Built-up Back Pressure : 0.88 kgf/cm²g				
	Valve Actual Capacity		45	925 kg/h						
	Calculated Orifice Area		46	9.408329 mm²						
	Selected Orifice Area		47	132.9 mm²						
	Orifice Dia.(mm)		48	D1(13)						
ETC	Paint System & Color		49	See Remark		*Paint Color(*) Painting : P-5 (RAL 9006 Silver) *Remark - Operating Pressure : 5 kgf/cm²g - Setting Pressure : 13.85 kgf/cm²g - Design Pressure : 13.85 kgf/cm²g - Built-up Back Pressure : 0.88 kgf/cm²g				
	Test Gag		50	Yes						
	Bug screen		51	No						


 JOKWANG I.L.I			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		9 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
		Checked		S.C.KIM		Approved		S.C.KIM		
GENERAL	P&ID No.	1	H465-E2-PID-91 57							
	Tag No.	2	E2-PSV-3750B							
	Service Line	3	CT-301 ERC Turbine Sealing Steam							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		<div>Calculation of Area</div> $A1 = 190.4 * W1 / ((P * 1.1 + 101.325) * Kd * Kb * Kc * Kn * Ksh)$ $= 190.4 * 1147 / ((127 * 1.1 + 101.325) * 0.831 * 1 * 1 * 0.811)$ $= \underline{1344.455377} \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Open							
	Lever Type	9	Plain Lever							
	Cap Type	10	Plain							
CONN.	Size. Inlet / Outlet	11	3"X4"		<div>Calculation of Capacity</div> $W = A * (P * 1.1 + 101.325) * Kd * Kb * Kc * Kn * Ksh / 190.4$ $= 1846.45 * (127 * 1.1 + 101.325) * 0.831 * 1 * 1 * 1 * 0.811 / 190.4$ $= \underline{1575} \text{ kg/h}$					
	Inlet. Rating / Facing	12	ASME CL150 RF							
	Outlet. Rating / Facing	13	ASME CL150 RF							
MATERIALS	Body (Base)	14	SA217 WC6		<div>Calculation of Capacity</div> $W = A * (P * 1.1 + 101.325) * Kd * Kb * Kc * Kn * Ksh / 190.4$ $= 1846.45 * (127 * 1.1 + 101.325) * 0.831 * 1 * 1 * 1 * 0.811 / 190.4$ $= \underline{1575} \text{ kg/h}$					
	Bonnet	15	SA217 WC6							
	Seat	16	AS(2.25Cr)-st.							
	Disc	17	Inconel 625							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	Graphite							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	KGS UV STAMP		<div>Calculation of Capacity</div> $W = A * (P * 1.1 + 101.325) * Kd * Kb * Kc * Kn * Ksh / 190.4$ $= 1846.45 * (127 * 1.1 + 101.325) * 0.831 * 1 * 1 * 1 * 0.811 / 190.4$ $= \underline{1575} \text{ kg/h}$					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520							
	Fire	26	No							
	Sizing Basis	27	Blocked Outlet							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	LP Steam / STEAM		W	Valve Capacity	1575 kg/h			
	Mol. Weight / Specific Gravity	30	18.02		W1	Required Capacity	1147 kg/h			
	Compressibility Factor	31	0.997		P	Set Pressure	127 KPag			
	Ratio of Specific Heat	32	1.281		A1	Calculated Area	1344.455377 mm²			
	Viscosity	33	-		A	Selected Area	1846.45 mm²			
	Operating / Relieving Temp.	34	415 / 433.5 °C		Kd	Coefficient of Discharge	0.831			
	Design Min. / Design Max. Temp.	35	434 °C		Ksh	Steam Correction Factor	0.811			
	Operating / Set Pressure	36	0.019 / 0.127 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Design Pressure / C.D.T.P	37	0.127/FV / 1.358 MPag		Kc	Correction Factor for a rupture disk	1			
	Back Pressure	Superimposed - Constant	38	0 MPag		Kn	Correction Factor for Napier equation	1		
		Superimposed - Variable	39	- MPag						
		Built-up	40	0.013 MPag						
		Total	41	0.013 MPag						
	Allowable Overpressure	42	10 %		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 0.2 kgf/cm²g - Setting Pressure : 1.3 kgf/cm²g - Design Pressure : 1.3/F.V kgf/cm²g - Built-up Back Pressure : 0.13 kgf/cm²g</p>					
	Closing Pressure / Blowdown(%)	43	Min. 0.11811 MPag / 7%							
	Required Capacity	44	1147 kg/h							
	Valve Actual Capacity	45	1575 kg/h							
	Calculated Orifice Area	46	1344.455377 mm²							
	SIZING & SELECTION	Selected Orifice Area	47	1846.45 mm²		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 0.2 kgf/cm²g - Setting Pressure : 1.3 kgf/cm²g - Design Pressure : 1.3/F.V kgf/cm²g - Built-up Back Pressure : 0.13 kgf/cm²g</p>				
		Orifice Dia.(mm)	48	L(48.5)						
			-							
			-							
			-							
ETC	Paint System & Color	49	See Remark		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 0.2 kgf/cm²g - Setting Pressure : 1.3 kgf/cm²g - Design Pressure : 1.3/F.V kgf/cm²g - Built-up Back Pressure : 0.13 kgf/cm²g</p>					
	Test Gag	50	Yes							
	Bug screen	51	No							


 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		10 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-9161							
	Tag No.	2	E2-PSV-5850B							
	Service Line	3	CT-501 ERC Turbine Sealing Steam							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		<div>Calculation of Area</div> $A1 = 190.4 * W1 / ((P * 1.1628 + 101.325) * Kd * Kb * Kc * Kn * Ksh)$ $= 190.4 * 228 / ((127 * 1.1628 + 101.325) * 0.831 * 1 * 1 * 0.877)$ $= \underline{239.221815} \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Open							
	Lever Type	9	Plain Lever							
	Cap Type	10	Plain							
CONN.	Size. Inlet / Outlet	11	1-1/2"X2"		<div>Calculation of Capacity</div> $W = A * (P * 1.1628 + 101.325) * Kd * Kb * Kc * Kn * Ksh / 190.4$ $= 260 * (127 * 1.1628 + 101.325) * 0.831 * 1 * 1 * 0.877 / 190.4$ $= \underline{248} \text{ kg/h}$					
	Inlet. Rating / Facing	12	ASME CL.150 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		<div>Calculation of Capacity</div> $W = A * (P * 1.1628 + 101.325) * Kd * Kb * Kc * Kn * Ksh / 190.4$ $= 260 * (127 * 1.1628 + 101.325) * 0.831 * 1 * 1 * 0.877 / 190.4$ $= \underline{248} \text{ kg/h}$					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.							
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	Graphite							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	KGS UV STAMP		<div>Calculation of Capacity</div> $W = A * (P * 1.1628 + 101.325) * Kd * Kb * Kc * Kn * Ksh / 190.4$ $= 260 * (127 * 1.1628 + 101.325) * 0.831 * 1 * 1 * 0.877 / 190.4$ $= \underline{248} \text{ kg/h}$					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520							
	Fire	26	No							
	Sizing Basis	27	Blocked Outlet							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	LP Steam / STEAM		W	Valve Capacity	248 kg/h			
	Mol. Weight / Specific Gravity	30	18.02		W1	Required Capacity	228 kg/h			
	Compressibility Factor	31	0.996		P	Set Pressure	127 KPag			
	Ratio of Specific Heat	32	1.290		A1	Calculated Area	239.221815 mm ²			
	Viscosity	33	-		A	Selected Area	260 mm ²			
	Operating / Relieving Temp.	34	299 / 347.2 °C		Kd	Coefficient of Discharge	0.831			
	Design Min. / Design Max. Temp.	35	347 °C		Ksh	Steam Correction Factor	0.877			
	Operating / Set Pressure	36	0.019 / 0.127 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Design Pressure / C.D.T.P	37	0.127/FV / 0.13081 MPag		Kc	Correction Factor for a rupture disk	1			
	Back Pressure	Superimposed - Constant	38	0 MPag		Kn	Correction Factor for Napier equation	1		
		Superimposed - Variable	39	- MPag						
		Built-up	40	0.013 MPag						
		Total	41	0.013 MPag						
	Allowable Overpressure	42	3 psi		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 0.2 kgf/cm²g - Setting Pressure : 1.3 kgf/cm²g - Design Pressure : 1.3/F.V kgf/cm²g - Built-up Back Pressure : 0.13 kgf/cm²g </p>					
	Closing Pressure / Blowdown(%)	43	Min. 0.11811 MPag / 7%							
	Required Capacity	44	228 kg/h							
	Valve Actual Capacity	45	248 kg/h							
	Calculated Orifice Area	46	239.221815 mm ²							
SIZING & SELECTION	Selected Orifice Area	47	260 mm ²		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 0.2 kgf/cm²g - Setting Pressure : 1.3 kgf/cm²g - Design Pressure : 1.3/F.V kgf/cm²g - Built-up Back Pressure : 0.13 kgf/cm²g </p>					
	Orifice Dia.(mm)	48	F1(18.2)							
ETC	Paint System & Color	49	See Remark		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 0.2 kgf/cm²g - Setting Pressure : 1.3 kgf/cm²g - Design Pressure : 1.3/F.V kgf/cm²g - Built-up Back Pressure : 0.13 kgf/cm²g </p>					
	Test Gag	50	Yes							
	Bug screen	51	No							


 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		11 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-91 64							
	Tag No.	2	E2-PSV-6850B							
	Service Line	3	CT-601 ERC Turbine Sealing Steam							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		Calculation of Area					
	Design Type	7	Conventional		$A1 = 190.4 * W1 / ((P * 1.1628 + 101.325) * Kd * Kb * Kc * Kn * Ksh)$ $= 190.4 * 578 / ((127 * 1.1628 + 101.325) * 0.831 * 1 * 1 * 0.817)$ $= \underline{650.98549} \text{ mm}^2$					
	Bonnet Type	8	Open							
	Lever Type	9	Plain Lever							
	Cap Type	10	Plain							
CONN.	Size. Inlet / Outlet	11	2"X3"							
	Inlet. Rating / Facing	12	ASME CL.150 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		Calculation of Capacity					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.		$W = A * (P * 1.1628 + 101.325) * Kd * Kb * Kc * Kn * Ksh / 190.4$ $= 834.19 * (127 * 1.1628 + 101.325) * 0.831 * 1 * 1 * 0.817 / 190.4$ $= \underline{741} \text{ kg/h}$					
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	Graphite							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	KGS UV STAMP		<div> <div>W</div> <div>Valve Capacity</div> <div>741 kg/h</div> </div>					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520							
	Fire	26	No							
	Sizing Basis	27	Blocked Outlet							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	LP Steam / STEAM		W	Valve Capacity	741 kg/h			
	Mol. Weight / Specific Gravity	30	18.02		W1	Required Capacity	578 kg/h			
	Compressibility Factor	31	0.997		P	Set Pressure	127 KPag			
	Ratio of Specific Heat	32	1.282		A1	Calculated Area	650.98549 mm ²			
	Viscosity	33	m		A	Selected Area	834.19 mm ²			
	Operating / Relieving Temp.	34	419 / 424.4 °C		Kd	Coefficient of Discharge	0.831			
	Design Min. / Design Max. Temp.	35	424 °C		Ksh	Steam Correction Factor	0.817			
	Operating / Set Pressure	36	0.019 / 0.127 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Design Pressure / C.D.T.P	37	0.127/FV / 0.13081 MPag		Kc	Correction Factor for a rupture disk	1			
	Back Pressure	Superimposed - Constant	38	0 MPag		Kn	Correction Factor for Napier equation	1		
			Superimposed - Variable	39	- MPag					
			Built-up	40	0.013 MPag					
			Total	41	0.013 MPag					
	Allowable Overpressure	42	3 psi		<div>Remarks</div> <div> <u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver) </div> <div> <u>*Remark</u> - Operating Pressure : 0.2 kgf/cm²g - Setting Pressure : 1.3 kgf/cm²g - Design Pressure : 1.3/F.V kgf/cm²g - Built-up Back Pressure : 0.13 kgf/cm²g </div>					
	Closing Pressure / Blowdown(%)	43	Min. 0.11811 MPag / 7%							
	SIZING & SELECTION	Required Capacity	44	578 kg/h						
		Valve Actual Capacity	45	741 kg/h						
Calculated Orifice Area		46	650.98549 mm ²							
Selected Orifice Area		47	834.19 mm ²							
Orifice Dia.(mm)		48	J(32.6)							
ETC	Paint System & Color	49	See Remark							
	Test Gag	50	Yes							
	Bug screen	51	No							


 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		12 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-9207							
	Tag No.	2	E2-PSV-9039							
	Service Line	3	C-941 GTG FG Boosting Compressor Lube Oil Cooler 2							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		<div>Calculation of Area</div> $A1 = 11.78 \times W1 \times (\sqrt{G/(P1-Pb)}) / (Kd \times Kb \times Kc \times Kv)$ $= 11.78 \times 0 \times \sqrt{(0.986/(1133-103))} / (0.615 \times 1 \times 1)$ $= 0 \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	3/4"X1"		<div>Calculation of Capacity</div> $W = A \times Kd \times Kb \times Kc \times Kv / (11.78 \times \sqrt{G/(P1-Pb)})$ $= 70.97 \times 0.615 \times 1 \times 1 / (11.78 \times \sqrt{(0.986/(1133-103))})$ $= 119.80 \text{ l/min}$ $= 7.2 \text{ m}^3/\text{h}$					
	Inlet. Rating / Facing	12	ASME CL150 RF							
	Outlet. Rating / Facing	13	ASME CL150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		<div>Calculation of Capacity</div> $W = A \times Kd \times Kb \times Kc \times Kv / (11.78 \times \sqrt{G/(P1-Pb)})$ $= 70.97 \times 0.615 \times 1 \times 1 / (11.78 \times \sqrt{(0.986/(1133-103))})$ $= 119.80 \text{ l/min}$ $= 7.2 \text{ m}^3/\text{h}$					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.							
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	UV STAMP		<div>Calculation of Capacity</div> $W = A \times Kd \times Kb \times Kc \times Kv / (11.78 \times \sqrt{G/(P1-Pb)})$ $= 70.97 \times 0.615 \times 1 \times 1 / (11.78 \times \sqrt{(0.986/(1133-103))})$ $= 119.80 \text{ l/min}$ $= 7.2 \text{ m}^3/\text{h}$					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520-Certification							
	Fire	26	No							
	Sizing Basis	27	Thermal Expansion							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	Cooling Water / LIQUID		W	Valve Capacity	119.80 l/min			
	Mol. Weight / Specific Gravity	30	0.986		W1	Required Capacity	0 l/min			
	Compressibility Factor	31	-		P	Set Pressure	1030 KPag			
	Ratio of Specific Heat	32	-		A1	Calculated Area	0 mm ²			
	Viscosity	33	0.5 cP		A	Selected Area	70.97 mm ²			
	Operating / Relieving Temp.	34	43 / 55 °C		Kd	Coefficient of Discharge	0.615			
	Design Min. / Design Max. Temp.	35	-18/65 °C		G	Specific Gravity	0.986			
	Operating / Set Pressure	36	0.539 / 1.03 MPag		Pb	Back Pressure	103 KPag			
	Design Pressure / C.D.T.P	37	1.03 / 1.03 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Back Pressure	Superimposed - Constant	38	- MPag		Kc	Correction Factor for a rupture disk	1		
		Superimposed - Variable	39	- MPag		Kv	Correction Factor due to Viscosity	1		
		Built-up	40	0.103 MPag		P1	Set Pressure plus Overpressure	1133 KPag		
		Total	41	0.103 MPag		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 1 0.5 kgf/cm²g - Design Pressure : 1 0.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1 .05 kgf/cm²g </p>				
	Allowable Overpressure	42	10 %							
	Closing Pressure / Blowdown(%)	43	Min. 0.78 MPag / 24.2718%							
	SIZING & SELECTION	Required Capacity	44	0 m ³ /h		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 1 0.5 kgf/cm²g - Design Pressure : 1 0.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1 .05 kgf/cm²g </p>				
		Valve Actual Capacity	45	7.2 m ³ /h						
		Calculated Orifice Area	46	0 mm ²						
Selected Orifice Area		47	70.97 mm ²							
Orifice Dia.(mm)		48	D(9.5)							
ETC	Paint System & Color	49	See Remark		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 1 0.5 kgf/cm²g - Design Pressure : 1 0.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1 .05 kgf/cm²g </p>					
	Test Gag	50	Yes							
	Bug screen	51	No							


 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		13 of 20		Rev . No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-9207							
	Tag No.	2	E2-PSV-9040							
	Service Line	3	C-941 GTG FG Boosting Compressor Rod Packing 1							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		<div>Calculation of Area</div> $A1 = 11.78 * W1 * (\sqrt{G / (P1 - Pb)}) / (Kd * Kb * Kc * Kv)$ $= 11.78 * 0 * \sqrt{(0.94 / (1133 - 103))} / (0.615 * 1 * 1)$ $= 0 \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	3/4"X1"		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.94 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Inlet. Rating / Facing	12	ASME CL.150 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.94 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.							
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	UV STAMP		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.94 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520-Certification							
	Fire	26	No							
	Sizing Basis	27	Thermal Expansion							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	Cooling Water / LIQUID		W	Valve Capacity	122.60 l/min			
	Mol. Weight / Specific Gravity	30	0.94		W1	Required Capacity	0 l/min			
	Compressibility Factor	31	-		P	Set Pressure	1030 KPag			
	Ratio of Specific Heat	32	-		A1	Calculated Area	0 mm ²			
	Viscosity	33	0.22 cP		A	Selected Area	70.97 mm ²			
	Operating / Relieving Temp.	34	43 / 122.2 °C		Kd	Coefficient of Discharge	0.615			
	Design Min. / Design Max. Temp.	35	-18/65 °C		G	Specific Gravity	0.94			
	Operating / Set Pressure	36	0.539 / 1.03 MPag		Pb	Back Pressure	103 KPag			
	Design Pressure / C.D.T.P	37	1.03 / 1.03 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Back Pressure	Superimposed - Constant	38	- MPag		Kc	Correction Factor for a rupture disk	1		
		Superimposed - Variable	39	- MPag		Kv	Correction Factor due to Viscosity	1		
		Built-up	40	0.103 MPag		P1	Set Pressure plus Overpressure	1133 KPag		
		Total	41	0.103 MPag		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 10.7 kgf/cm²g </p>				
	Allowable Overpressure	42	10 %							
	Closing Pressure / Blowdown(%)	43	Min. 0.78 MPag / 24.2718%							
	Required Capacity	44	0 m ³ /h							
	SIZING & SELECTION	Valve Actual Capacity	45	7.4 m ³ /h		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 10.7 kgf/cm²g </p>				
		Calculated Orifice Area	46	0 mm ²						
Selected Orifice Area		47	70.97 mm ²							
Orifice Dia.(mm)		48	D(9.5)							
ETC	Paint System & Color	49	See Remark		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 10.7 kgf/cm²g </p>					
	Test Gag	50	Yes							
	Bug screen	51	No							


 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		14 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-9207							
	Tag No.	2	E2-PSV-9041							
	Service Line	3	C-941 GTG FG Boosting Compressor Rod Packing 2							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		<div>Calculation of Area</div> $A1 = 11.78 * W1 * (\sqrt{G / (P1 - Pb)}) / (Kd * Kb * Kc * Kv)$ $= 11.78 * 0 * \sqrt{(0.94 / (1133 - 103))} / (0.615 * 1 * 1)$ $= 0 \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	3/4"X1"		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.94 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Inlet. Rating / Facing	12	ASME CL.150 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.94 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.							
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	UV STAMP		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.94 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520-Certification							
	Fire	26	No							
	Sizing Basis	27	Thermal Expansion							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	Cooling Water / LIQUID		W	Valve Capacity	122.60 l/min			
	Mol. Weight / Specific Gravity	30	0.94		W1	Required Capacity	0 l/min			
	Compressibility Factor	31	-		P	Set Pressure	1030 KPag			
	Ratio of Specific Heat	32	-		A1	Calculated Area	0 mm ²			
	Viscosity	33	0.22 cP		A	Selected Area	70.97 mm ²			
	Operating / Relieving Temp.	34	43 / 122.2 °C		Kd	Coefficient of Discharge	0.615			
	Design Min. / Design Max. Temp.	35	-18/65 °C		G	Specific Gravity	0.94			
	Operating / Set Pressure	36	0.539 / 1.03 MPag		Pb	Back Pressure	103 KPag			
	Design Pressure / C.D.T.P	37	1.03 / 1.03 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Back Pressure	Superimposed - Constant	38	- MPag		Kc	Correction Factor for a rupture disk	1		
		Superimposed - Variable	39	- MPag		Kv	Correction Factor due to Viscosity	1		
		Built-up	40	0.103 MPag		P1	Set Pressure plus Overpressure	1133 KPag		
		Total	41	0.103 MPag		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>				
	Allowable Overpressure	42	10 %							
	Closing Pressure / Blowdown(%)	43	Min. 0.78 MPag / 24.2718%							
	Required Capacity	44	0 m ³ /h							
	SIZING & SELECTION	Valve Actual Capacity	45	7.4 m ³ /h		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>				
		Calculated Orifice Area	46	0 mm ²						
Selected Orifice Area		47	70.97 mm ²							
Orifice Dia.(mm)		48	D(9.5)							
ETC	Paint System & Color	49	See Remark		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>					
	Test Gag	50	Yes							
	Bug screen	51	No							


 JOKWANG I.L.I			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		15 of 20		Rev . No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-9207							
	Tag No.	2	E2-PSV-9042							
	Service Line	3	C-941 GTG FG Boosting Compressor Rod Packing 3							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		<div>Calculation of Area</div> $A1 = 11.78 * W1 * (\sqrt{G / (P1 - Pb)}) / (Kd * Kb * Kc * Kv)$ $= 11.78 * 0 * \sqrt{(0.94 / (1133 - 103))} / (0.615 * 1 * 1)$ $= 0 \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	3/4"X1"		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.94 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Inlet. Rating / Facing	12	ASME CL.150 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.94 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.							
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	UV STAMP		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.94 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520-Certification							
	Fire	26	No							
	Sizing Basis	27	Thermal Expansion							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	Cooling Water / LIQUID		W	Valve Capacity	122.60 l/min			
	Mol. Weight / Specific Gravity	30	0.94		W1	Required Capacity	0 l/min			
	Compressibility Factor	31	-		P	Set Pressure	1030 KPag			
	Ratio of Specific Heat	32	-		A1	Calculated Area	0 mm ²			
	Viscosity	33	0.22 cP		A	Selected Area	70.97 mm ²			
	Operating / Relieving Temp.	34	43 / 122.2 °C		Kd	Coefficient of Discharge	0.615			
	Design Min. / Design Max. Temp.	35	-18/65 °C		G	Specific Gravity	0.94			
	Operating / Set Pressure	36	0.539 / 1.03 MPag		Pb	Back Pressure	103 KPag			
	Design Pressure / C.D.T.P	37	1.03 / 1.03 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Back Pressure	Superimposed - Constant	38	- MPag		Kc	Correction Factor for a rupture disk	1		
		Superimposed - Variable	39	- MPag		Kv	Correction Factor due to Viscosity	1		
		Built-up	40	0.103 MPag		P1	Set Pressure plus Overpressure	1133 KPag		
		Total	41	0.103 MPag		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>				
	Allowable Overpressure	42	10 %							
	Closing Pressure / Blowdown(%)	43	Min. 0.78 MPag / 24.2718%							
	Required Capacity	44	0 m ³ /h							
	SIZING & SELECTION	Valve Actual Capacity	45	7.4 m ³ /h		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>				
		Calculated Orifice Area	46	0 mm ²						
Selected Orifice Area		47	70.97 mm ²							
Orifice Dia.(mm)		48	D(9.5)							
ETC	Paint System & Color	49	See Remark		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>					
	Test Gag	50	Yes							
	Bug screen	51	No							

 JOKWANG I.L.I. <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		16 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-3047							
	Tag No.	2	E2-PSV-3128A/B							
	Service Line	3	F-305 (Guard Dryer Filter)							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	2							
TYPE	Nozzle Type	6	Full Nozzle		Calculation of Area					
	Design Type	7	Conventional		$A1 = 13160 \times W1 \times (\sqrt{ZT/M}) / (C \times Kd \times (P \times 1.1 + 101.325) \times Kb \times Kc)$ $= 13160 \times 3793 \times (\sqrt{0.610 \times 461 / 27.10}) / (339.24 \times 0.831 \times (4511 \times 1.1 + 101.325) \times 1 \times 1)$ $= \underline{112.64632} \text{ mm}^2$					
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	1"X2"							
	Inlet. Rating / Facing	12	ASME CL.300 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		Calculation of Capacity					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.		$W = A \times C \times Kd \times (P \times 1.1 + 101.325) \times Kb \times Kc / (13160 \times \sqrt{ZT/M})$ $= 126.45 \times 339.24 \times 0.831 \times (4511 \times 1.1 + 101.325) \times 1 \times 1 / (13160 \times \sqrt{(0.610 \times 461 / 27.10)})$ $= \underline{4258} \text{ kg/h}$					
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	KGS UV STAMP							
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520							
	Fire	26	No							
	Sizing Basis	27	External Fire							
	Rupture Disk	28	No		W	Valve Capacity	4258 kg/h			
SERVICE CONDITION	Fluid / State	29	Reactor Effluent / GAS		W1	Required Capacity	3793 kg/h			
	Mol. Weight / Specific Gravity	30	27.10		P	Set Pressure	4511 KPag			
	Compressibility Factor	31	0.610		A1	Calculated Area	112.64632 mm ²			
	Ratio of Specific Heat	32	1.22		A	Selected Area	126.45 mm ²			
	Viscosity	33	0.01 cP		Kd	Coefficient of Discharge	0.831			
	Operating / Relieving Temp.	34	40 / 188 °C		C	Coefficient base on Ratio of Specific Heat	339.24			
	Design Min. / Design Max. Temp.	35	-18/149 °C		T	Kelvin Temperature	461 K			
	Operating / Set Pressure	36	3.677 / 4.511 MPag		M	Molecular Weight	27.10			
	Design Pressure / C.D.T.P	37	4.511 / 4.481 MPag		Z	Compressibility Factor	0.610			
	Back Pressure	Superimposed - Constant	38	0.03 MPag		Kb	Correction Factor Due to Back Pressure	1		
		Superimposed - Variable	39	- MPag		Kc	Correction Factor for a rupture disk	1		
		Built-up	40	0.114 MPag		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p>				
		Total	41	0.144 MPag						
	Allowable Overpressure	42	10 %							
	Closing Pressure / Blowdown(%)	43	Min. 4.19523 MPag / 7%							
	SIZING & SELECTION	Required Capacity	44	3793 kg/h						
		Valve Actual Capacity	45	4258 kg/h						
Calculated Orifice Area		46	112.64632 mm ²							
Selected Orifice Area		47	126.45 mm ²							
Orifice Dia.(mm)		48	E(12.7)							
ETC	Paint System & Color	49	See Remark							
	Test Gag	50	Yes							
	Bug screen	51	No							

 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		17 of 20		Rev. No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-9201							
	Tag No.	2	E2-PSV-9044							
	Service Line	3	W-931 No.1 Gas Turbine Generator Package							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		<div>Calculation of Area</div> $A1 = 11.78 * W1 * (\sqrt{G / (P1 - Pb)}) / (Kd * Kb * Kc * Kv)$ $= 11.78 * 0 * \sqrt{(0.941 / (1133 - 103))} / (0.615 * 1 * 1)$ $= 0 \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	3/4"X1"		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.941 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Inlet. Rating / Facing	12	ASME CL.150 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.941 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.							
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	UV STAMP		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.941 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520-Certification							
	Fire	26	No							
	Sizing Basis	27	Thermal Expansion							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	Cooling Water / LIQUID		W	Valve Capacity	122.60 l/min			
	Mol. Weight / Specific Gravity	30	0.941		W1	Required Capacity	0 l/min			
	Compressibility Factor	31	-		P	Set Pressure	1030 KPag			
	Ratio of Specific Heat	32	-		A1	Calculated Area	0 mm ²			
	Viscosity	33	0.22 cP		A	Selected Area	70.97 mm ²			
	Operating / Relieving Temp.	34	43 / 123 °C		Kd	Coefficient of Discharge	0.615			
	Design Min. / Design Max. Temp.	35	-18/65 °C		G	Specific Gravity	0.941			
	Operating / Set Pressure	36	0.539 / 1.03 MPag		Pb	Back Pressure	103 KPag			
	Design Pressure / C.D.T.P	37	1.03 / 1.03 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Back Pressure	Superimposed - Constant	38	- MPag		Kc	Correction Factor for a rupture disk	1		
		Superimposed - Variable	39	- MPag		Kv	Correction Factor due to Viscosity	1		
		Built-up	40	0.103 MPag		P1	Set Pressure plus Overpressure	1133 KPag		
		Total	41	0.103 MPag		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>				
	Allowable Overpressure	42	10 %							
	Closing Pressure / Blowdown(%)	43	Min. 0.78 MPag / 24.2718%							
	Required Capacity	44	0 m ³ /h							
	SIZING & SELECTION	Valve Actual Capacity	45	7.4 m ³ /h		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>				
		Calculated Orifice Area	46	0 mm ²						
Selected Orifice Area		47	70.97 mm ²							
Orifice Dia.(mm)		48	D(9.5)							
ETC	Paint System & Color	49	See Remark		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>					
	Test Gag	50	Yes							
	Bug screen	51	No							

 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		18 of 20		Rev . No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-9202							
	Tag No.	2	E2-PSV-9045							
	Service Line	3	W-941 No.2 Gas Turbine Generator Package							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		<div>Calculation of Area</div> $A1 = 11.78 * W1 * (\sqrt{G / (P1 - Pb)}) / (Kd * Kb * Kc * Kv)$ $= 11.78 * 0 * \sqrt{(0.941 / (1133 - 103))} / (0.615 * 1 * 1)$ $= 0 \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	3/4"X1"		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.941 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Inlet. Rating / Facing	12	ASME CL.150 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.941 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.							
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	UV STAMP		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 / (11.78 * \sqrt{(0.941 / (1133 - 103))})$ $= 122.60 \text{ l/min}$ $= 7.4 \text{ m}^3/\text{h}$					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520-Certification							
	Fire	26	No							
	Sizing Basis	27	Thermal Expansion							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	Cooling Water / LIQUID		W	Valve Capacity	122.60 l/min			
	Mol. Weight / Specific Gravity	30	0.941		W1	Required Capacity	0 l/min			
	Compressibility Factor	31	-		P	Set Pressure	1030 KPag			
	Ratio of Specific Heat	32	-		A1	Calculated Area	0 mm ²			
	Viscosity	33	0.22 cP		A	Selected Area	70.97 mm ²			
	Operating / Relieving Temp.	34	43 / 123 °C		Kd	Coefficient of Discharge	0.615			
	Design Min. / Design Max. Temp.	35	-18/65 °C		G	Specific Gravity	0.941			
	Operating / Set Pressure	36	0.539 / 1.03 MPag		Pb	Back Pressure	103 KPag			
	Design Pressure / C.D.T.P	37	1.03 / 1.03 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Back Pressure	Superimposed - Constant	38	- MPag		Kc	Correction Factor for a rupture disk	1		
		Superimposed - Variable	39	- MPag		Kv	Correction Factor due to Viscosity	1		
		Built-up	40	0.103 MPag		P1	Set Pressure plus Overpressure	1133 KPag		
		Total	41	0.103 MPag		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>				
	Allowable Overpressure	42	10 %							
	Closing Pressure / Blowdown(%)	43	Min. 0.78 MPag / 24.2718%							
	Required Capacity	44	0 m ³ /h							
	SIZING & SELECTION	Valve Actual Capacity	45	7.4 m ³ /h		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>				
		Calculated Orifice Area	46	0 mm ²						
Selected Orifice Area		47	70.97 mm ²							
Orifice Dia.(mm)		48	D(9.5)							
ETC	Paint System & Color	49	See Remark		<div>Remarks</div> <p>*Paint Color(*) Painting : P-5 (RAL 9006 Silver)</p> <p>*Remark - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>					
	Test Gag	50	Yes							
	Bug screen	51	No							

 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		19 of 20		Rev . No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-9201							
	Tag No.	2	E2-PSV-9046							
	Service Line	3	W-931 Lube Oil Cooler Cold							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		<div>Calculation of Area</div> $A1 = 11.78 \times W1 \times (\sqrt{G/(P1-Pb)}) / (Kd \times Kb \times Kc \times Kv)$ $= 11.78 \times 0 \times \sqrt{(0.972/(1133-103))} / (0.615 \times 1 \times 1)$ $= 0 \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	3/4"X1"		<div>Calculation of Capacity</div> $W = A \times Kd \times Kb \times Kc \times Kv / (11.78 \times \sqrt{G/(P1-Pb)})$ $= 70.97 \times 0.615 \times 1 \times 1 / (11.78 \times \sqrt{(0.972/(1133-103))})$ $= 120.60 \text{ l/min}$ $= 7.2 \text{ m}^3/\text{h}$					
	Inlet. Rating / Facing	12	ASME CL.150 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		<div>Calculation of Capacity</div> $W = A \times Kd \times Kb \times Kc \times Kv / (11.78 \times \sqrt{G/(P1-Pb)})$ $= 70.97 \times 0.615 \times 1 \times 1 / (11.78 \times \sqrt{(0.972/(1133-103))})$ $= 120.60 \text{ l/min}$ $= 7.2 \text{ m}^3/\text{h}$					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.							
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	UV STAMP		<div>Calculation of Capacity</div> $W = A \times Kd \times Kb \times Kc \times Kv / (11.78 \times \sqrt{G/(P1-Pb)})$ $= 70.97 \times 0.615 \times 1 \times 1 / (11.78 \times \sqrt{(0.972/(1133-103))})$ $= 120.60 \text{ l/min}$ $= 7.2 \text{ m}^3/\text{h}$					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520-Certification							
	Fire	26	No							
	Sizing Basis	27	Thermal Expansion							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	Cooling Water / LIQUID		W	Valve Capacity	120.60 l/min			
	Mol. Weight / Specific Gravity	30	0.972		W1	Required Capacity	0 l/min			
	Compressibility Factor	31	-		P	Set Pressure	1030 KPag			
	Ratio of Specific Heat	32	-		A1	Calculated Area	0 mm²			
	Viscosity	33	0.35 cP		A	Selected Area	70.97 mm²			
	Operating / Relieving Temp.	34	43 / 80 °C		Kd	Coefficient of Discharge	0.615			
	Design Min. / Design Max. Temp.	35	-18/65 °C		G	Specific Gravity	0.972			
	Operating / Set Pressure	36	0.539 / 1.03 MPag		Pb	Back Pressure	103 KPag			
	Design Pressure / C.D.T.P	37	1.03 / 1.03 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Back Pressure	Superimposed - Constant	38	- MPag		Kc	Correction Factor for a rupture disk	1		
		Superimposed - Variable	39	- MPag		Kv	Correction Factor due to Viscosity	1		
		Built-up	40	0.103 MPag		P1	Set Pressure plus Overpressure	1133 KPag		
		Total	41	0.103 MPag		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>				
	Allowable Overpressure	42	10 %							
	Closing Pressure / Blowdown(%)	43	Min. 0.78 MPag / 24.2718%							
	Required Capacity	44	0 m³/h							
	SIZING & SELECTION	Valve Actual Capacity	45	7.2 m³/h		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>				
		Calculated Orifice Area	46	0 mm²						
Selected Orifice Area		47	70.97 mm²							
Orifice Dia.(mm)		48	D(9.5)							
ETC	Paint System & Color	49	See Remark		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>					
	Test Gag	50	Yes							
	Bug screen	51	No							

 JOKWANG I.L.I <small>Since 1968</small>			Pressure Safety & Relief Valve Specification and Calculation Sheet							
			Sheet No.		20 of 20		Rev . No		1	
			Project Name		Yeosu No.2 Complex Project(E2) 2nd PO					
			Project No.							
			Date		2021-01-27		By		S.W.PARK	
Checked		S.C.KIM		Approved		S.C.KIM				
GENERAL	P&ID No.	1	H465-E2-PID-9202							
	Tag No.	2	E2-PSV-9047							
	Service Line	3	W-941 Lube Oil Cooler Cold							
	Model No.	4	JSV-FF100		<div>Calculation</div>					
	Quantity	5	1							
TYPE	Nozzle Type	6	Full Nozzle		<div>Calculation of Area</div> $A1 = 11.78 * W1 * (\sqrt{G / (P1 - Pb)}) / (Kd * Kb * Kc * Kv)$ $= 11.78 * 0 * \sqrt{(0.972 / (1133 - 103))} / (0.615 * 1 * 1 * 1)$ $= 0 \text{ mm}^2$					
	Design Type	7	Conventional							
	Bonnet Type	8	Close							
	Lever Type	9	None							
	Cap Type	10	Screwed							
CONN.	Size. Inlet / Outlet	11	3/4"X1"		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 * 1 / (11.78 * \sqrt{(0.972 / (1133 - 103))})$ $= 120.60 \text{ l/min}$ $= 7.2 \text{ m}^3/\text{h}$					
	Inlet. Rating / Facing	12	ASME CL.150 RF							
	Outlet. Rating / Facing	13	ASME CL.150 RF							
MATERIALS	Body (Base)	14	SA216 WCB		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 * 1 / (11.78 * \sqrt{(0.972 / (1133 - 103))})$ $= 120.60 \text{ l/min}$ $= 7.2 \text{ m}^3/\text{h}$					
	Bonnet	15	SA216 WCB							
	Seat	16	316 SS-st.							
	Disc	17	316 SS-st.							
	Guide	18	316 SS							
	Gasket (Bonnet)	19	PTFE							
	Spring	20	316 SS							
	Bellows	21	None							
BASIS	Approved by	22	UV STAMP		<div>Calculation of Capacity</div> $W = A * Kd * Kb * Kc * Kv / (11.78 * \sqrt{G / (P1 - Pb)})$ $= 70.97 * 0.615 * 1 * 1 * 1 / (11.78 * \sqrt{(0.972 / (1133 - 103))})$ $= 120.60 \text{ l/min}$ $= 7.2 \text{ m}^3/\text{h}$					
	Comply with NACE	23	No							
	EN 10204	24	No							
	Code	25	API RP 520-Certification							
	Fire	26	No							
	Sizing Basis	27	Thermal Expansion							
	Rupture Disk	28	No							
SERVICE CONDITION	Fluid / State	29	Cooling Water / LIQUID		W	Valve Capacity	120.60 l/min			
	Mol. Weight / Specific Gravity	30	0.972		W1	Required Capacity	0 l/min			
	Compressibility Factor	31	-		P	Set Pressure	1030 KPag			
	Ratio of Specific Heat	32	-		A1	Calculated Area	0 mm ²			
	Viscosity	33	0.35 cP		A	Selected Area	70.97 mm ²			
	Operating / Relieving Temp.	34	43 / 80 °C		Kd	Coefficient of Discharge	0.615			
	Design Min. / Design Max. Temp.	35	-18/65 °C		G	Specific Gravity	0.972			
	Operating / Set Pressure	36	0.539 / 1.03 MPag		Pb	Back Pressure	103 KPag			
	Design Pressure / C.D.T.P	37	1.03 / 1.03 MPag		Kb	Correction Factor Due to Back Pressure	1			
	Back Pressure	Superimposed - Constant	38	- MPag		Kc	Correction Factor for a rupture disk	1		
		Superimposed - Variable	39	- MPag		Kv	Correction Factor due to Viscosity	1		
		Built-up	40	0.103 MPag		P1	Set Pressure plus Overpressure	1133 KPag		
		Total	41	0.103 MPag		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>				
	Allowable Overpressure	42	10 %							
	Closing Pressure / Blowdown(%)	43	Min. 0.78 MPag / 24.2718%							
	Required Capacity	44	0 m ³ /h							
	SIZING & SELECTION	Valve Actual Capacity	45	7.2 m ³ /h		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>				
		Calculated Orifice Area	46	0 mm ²						
Selected Orifice Area		47	70.97 mm ²							
Orifice Dia.(mm)		48	D(9.5)							
ETC	Paint System & Color	49	See Remark		<div>Remarks</div> <p><u>*Paint Color(*)</u> Painting : P-5 (RAL 9006 Silver)</p> <p><u>*Remark</u> - Operating Pressure : 5.5 kgf/cm²g - Setting Pressure : 10.5 kgf/cm²g - Design Pressure : 10.5 kgf/cm²g - Constant Back Pressure : 0 kgf/cm²g - Built-up Back Pressure : 1.05 kgf/cm²g </p>					
	Test Gag	50	Yes							
	Bug screen	51	No							

**JOKWANG I.L.I****Pressure Safety & Relief Valve Specification and Calculation Sheet**

Sheet No.	1 of 1	Rev. No	1
Project Name	Yeosu No.2 Complex Project (긴급분)		
Project No.			
Date	2021-03-24	By	S.W.PARK
Checked	S.C.KIM	Approved	S.C.KIM

GENERAL	P&ID No.		1	H465-E2-PID-2013					
	Tag No.		2	E2-PSV-2122					
	Service Line		3	E-211 (Process Condensate Stripper Reboiler) SS					
	Model No.		4	JSV-FF100		Calculation			
	Quantity		5	1					
TYPE	Nozzle Type		6	Full Nozzle		Calculation of Area			
	Design Type		7	Conventional		A1 = 11.78*W1*(√G/(P1-Pb))/(Kd*Kb*Kc*Kv) = 11.78*0*√(0.894/(1455.3-25))/(0.615*1*1*1) = 0 mm ²			
	Bonnet Type		8	Close					
	Lever Type		9	None					
	Cap Type		10	Screwed					
Size. Inlet / Outlet		11	3/4"X1"						
CONN.	Inlet. Rating / Facing		12	ASME CL.150 RF		Calculation of Capacity W = A*Kd*Kb*Kc*Kv/(11.78*√(G/(P1-Pb))) = 70.97*0.615*1*1/(11.78*√(0.894/(1455.3-25))) = 148.20 ℓ/min = 8.9 m3/h			
	Outlet. Rating / Facing		13	ASME CL.150 RF					
	Body (Base)		14	SA216 WCB					
MATERIALS	Bonnet		15	SA216 WCB				W = A*Kd*Kb*Kc*Kv/(11.78*√(G/(P1-Pb))) = 70.97*0.615*1*1/(11.78*√(0.894/(1455.3-25))) = 148.20 ℓ/min = 8.9 m3/h	
	Seat		16	316 SS-st.					
	Disc		17	316 SS-st.					
	Guide		18	316 SS					
	Gasket (Bonnet)		19	PTFE					
	Spring		20	Chrome Alloy(SWOSC-B)					
	Bellows		21	None					
	Approved by		22	KGS UV STAMP					
BASIS	Comply with NACE		23	/		W Valve Capacity 148.20 ℓ/min W1 Required Capacity 0 ℓ/min P Set Pressure 1323 KPag A1 Calculated Area 0 mm ² A Selected Area 70.97 mm ² Kd Coefficient of Discharge 0.615 G Specific Gravity 0.894 Pb Back Pressure 25 KPag Kb Correction Factor Due to Back Pressure 1 Kc Correction Factor for a rupture disk 1 Kv Correction Factor due to Viscosity 1 P1 Set Pressure plus Overpressure 1455.3 KPag			
	EN 10204		24	No					
	Code		25	API RP 520-Certification					
	Fire		26	No					
	Sizing Basis		27	Thermal Expansion					
	Rupture Disk		28	No					
	Fluid / State		29	Process Condensate / LIQUID					
SERVICE CONDITION	Mol. Weight / Specific Gravity		30	0.894		P Set Pressure 1323 KPag			
	Compressibility Factor		31	-		A1 Calculated Area 0 mm ²			
	Ratio of Specific Heat		32	-		A Selected Area 70.97 mm ²			
	Viscosity		33	0.155 cP		Kd Coefficient of Discharge 0.615			
	Operating / Relieving Temp.		34	117.1 / 173.4 °C		G Specific Gravity 0.894			
	Design Min. / Design Max. Temp.		35	-18/195 °C		Pb Back Pressure 25 KPag			
	Operating / Set Pressure		36	0.072 / 1.323 MPag		Kb Correction Factor Due to Back Pressure 1			
	Design Pressure / C.D.T.P		37	1.323/FV / 1.33623 MPag		Kc Correction Factor for a rupture disk 1			
	Back Pressure	Superimposed - Constant	38	- MPag		Kv Correction Factor due to Viscosity 1			
		Superimposed - Variable	39	- MPag		P1 Set Pressure plus Overpressure 1455.3 KPag			
		Built-up	40	0.025 MPag		Remarks			
		Total	41	0.025 MPag					
	Allowable Overpressure		42	10 %					
	Closing Pressure / Blowdown(%)		43	Min. 1.12455 MPag / 15%		*Paint Color(*) P-5 *Remark - Operating Pressure : 0.74 kgf/㎥ ^g - Setting Pressure : 13.5 kgf/㎥ ^g - Design Pressure : 13.5/FV kgf/㎥ ^g - Constant Back Pressure : 0 kgf/㎥ ^g - Built-up Back Pressure : 0.251 kgf/㎥ ^g			
	SIZING & SELECTION	Required Capacity		44	0 m3/h				
Valve Actual Capacity		45	8.9 m3/h						
Calculated Orifice Area		46	0 mm ²						
Selected Orifice Area		47	70.97 mm ²						
Orifice Dia.(mm)		48	D(9.5)						
			-						
			-						
ETC	Paint System & Color		49	See Remark					
	Test Gag		50	Yes					
	Bug screen		51	No					