



Commission Agenda Report

City of Kalamazoo

TO: Mayor Hopewell, Vice Mayor Knott, and City Commissioners

FROM: James K. Ritsema, ICMA-CM, City Manager

REVIEWED BY: James J. Baker, PE Public Services Director and City Engineer

PREPARED BY: Ryan S. Stoughton, PE Asst. City Engineer - Wastewater

DATE: 8/24/2018

SUBJECT: Secondary Clarifier Drives & Sweeps No.5 - No.8 Design Contract Approval

RECOMMENDATION

It is recommended that the City Commission approve a Purchase Order and Professional Service Agreement with Wightman Associates Inc (WAI) for the design of permit and bid documents for the Kalamazoo Water Reclamation Plant's (KWRP) Secondary Clarifiers, No.5 through No.8 Drives & Sweeps Project in the amount of \$380,000.00.

BACKGROUND

The existing Secondary Clarifier infrastructure including concrete tanks, drives, sweeps, support super structure, weirs, baffles, electrical and process control systems, and all appurtenances, have been in service since around 1984 with a replacement of the drives around 1994. The existing infrastructure is showing its 34-plus year age along with the 24-plus year old replacement drives with increased required maintenance, wear, and treatment inefficiencies.

In addition to the current physical condition of the existing infrastructure, recent Plant treatment modeling results indicate the existing secondary clarifier design as being a major limiting factor in the ability for the Plant to handle increased flow rates while keeping the loading concentration rates constant.

COMMUNITY RESOURCES CONSULTED

This recommendation did not require advisory board consultation or additional public input.

FISCAL IMPACT

Funding for the design phase of this Project is available via the 2018 WWR-CIP.

FY 2018 CIP.....	\$325,000.00
FY 2018 O&M.....	\$ 55,000.00
	\$380,000.00