

INSTRUMENT CALIBRATION RECORD

Tag: PT-4471 Type: pressure transmitter Range 0-25 barg Loop: V-204 overhead
Calibration date: 21 Aug 2026 Technician: K. Pillai

TEST POINT (barg)	AS FOUND (barg)	AS LEFT (barg)
0.0	0.31	0.02
6.25	6.58	6.26
12.5	12.87	12.51
25.0	25.42	25.03

As-found error 1.7% of span exceeds the 0.5% tolerance: recorded as FAILED AS FOUND.
Adjusted and passed as left. Impulse line flushed; fouling found at vessel nozzle.

Calibrated by: K. Pillai

