

MECHANICAL SPECIFICATION — SECTION 3.4

Data Centre Chilled Water Plant

3.4.2 Chiller Cooling Capacity

Each chiller shall provide not less than 500 TR at 35C ambient dry-bulb.