

MECHANICAL SPECIFICATION — SECTION 3.4

Data Centre Chilled Water Plant

3.4.2 Chiller Cooling Capacity

Each chiller shall provide not less than 500 TR at 35C ambient.

3.4.3 Chiller Integrated Part Load Value (IPLV)

Each chiller shall achieve a minimum IPLV of 6.2 EER.

3.4.4 Chiller Sound Power Level

Chiller noise shall not exceed 82 dBA at 1 meter, full load.

3.4.5 Chiller Bearing Vibration

Chiller bearing vibration shall not exceed 2.8 mm/s RMS.