

ELECTRICAL SPECIFICATION — DIVISION 16

Enclosures, Switchgear, Cable

16.1.2 Outdoor Enclosure Rating

All outdoor equipment enclosures shall be minimum NEMA 4X (IP66 equivalent).

16.4.2.1 Breaker Coordination Study

Submittal package shall include a coordination study demonstrating breaker selectivity.

16.9.1 Fire Safety — Cable Rating

Power cable in trays within 10 m of IT equipment shall be rated IEC 60332-1 Category A.