

PROJECT SUBMITTAL — REDUNDANCY & DOCUMENTATION PACKAGE

Generator Schedule, Piping Plan, Vendor Documents

Generator Configuration (Project Schedule)

One (1) 2500 kVA diesel generator

Chilled Water Piping Plan

Dual loops from single chiller-plant header, no isolation valves

Documents Provided

Product cut sheet, warranty (certificate of compliance and test reports not included)