

ELECTRICAL SPECIFICATION — SECTION 2.8

Uninterruptible Power Supply (UPS)

2.8.1 UPS Runtime

UPS shall provide not less than 20 minutes runtime at full load, 25C ambient.

2.8.2 UPS Power Capacity

UPS shall provide not less than 250 kW at the specified load.

2.8.3 UPS Mean Time Between Failure

UPS modules shall have MTBF of not less than 100,000 hours.