

TIER III REDUNDANCY SPECIFICATION

Power Train and Cooling Topology (per TIA-942)

Tier III Power Train — Generator Redundancy

Facility shall provide N+1 generator redundancy: two independent 2500 kVA generators, either capable of carrying full IT load.

Tier III Cooling — Chilled Water Loop Redundancy

Two independent chilled water loops shall be provided; either loop shall independently cool the full facility load.

QUAL-2.3 Submittal Documentation

All vendor submittals shall include certificate of compliance, equipment test reports, and warranty documentation.