

Project Name: Eastern Coalfields Subterranean Expansion

RFP ID: ECSE-2026-HV-009

Issue Date: June 2, 2026

Section 1: Project Scope Eastern Coalfields Ltd requires the supply of heavy-duty power cables for underground mining operations and surface-level distribution. All materials must meet strict industrial safety tolerances.

Section 2: Technical Requirements Matrix

LOT 1: Surface Level Distribution (Standard)

- **Application:** General facility lighting and low-power machinery.
- **Core Count:** 3 Core
- **Conductor:** Aluminum
- **Voltage Rating:** 600V
- **Insulation:** Standard XLPE
- **Quantity:** 10,000 meters

LOT 2: Heavy-Duty Subterranean Excavator Feeders (Custom/MTO)

- **Application:** Direct power feed to mobile continuous mining machines deep underground.
- **Core Count:** 4 Core
- **Conductor:** Highly Flexible Stranded Copper
- **Voltage Rating:** 1100V
- **Insulation:** Heavy-Duty Ethylene Propylene Rubber (EPR) with reinforced steel-wire armoring.
- **Quantity:** 2,500 meters

Section 3: Testing Requirements

- Insulation Resistance Test at 1200V.
- Severe mechanical impact and crush resistance testing for Lot 2.
-