

GILES CHEMICAL CORPORATION		
COMPANY PROCEDURE		
Standard Operating Procedure	Page : 1 of 2	Revision : Date : 02/12/07
Author: Maintenance	Title: Lock Out Tag Out Flexcon #2 CM	

Safety: *All safety glasses and appropriate safety apparel is to be worn at all times.*

Purpose or Objective: *The purpose of this procedure is to define the process required to lock out the Flexcon #2 CM at repack facility*

Procedure: *The proper process to lockout the Flexcon #2 CM is as follows:*

- 1. Notify all affected employees that the machine is being taken out of production.*
- 2. Turn electrical disconnect off and install pad lock-multi locking device with id tag*
- 3. ID tag must contain name, date and time lock out occurs.*
- 4. Test the machine to ensure that it is locked out and will not start.*

Proper procedure to return equipment to operation:

- 1. Make sure all work is complete and all tools and maintenance equipment has been removed from the machine.*
- 2. Notify all affected employees that equipment is about to be put back into service.*
- 3. Remove Id tag with name, date and time*
- 4. Remove padlock-multi locking device*
- 5. Remove breaker lock out device*
- 6. Place breaker in the on position*
- 7. Test to ensure that Flexcon #2 CM is operating properly and available to be placed back in service.*

GILES CHEMICAL CORPORATION			
COMPANY PROCEDURE			
Standard Operating Procedure		Page : 2 of 2	Revision : Date : 02/12/07
	Author: Maintenance Title: Lock Out Tag Out Flexcon #2 CM		

TRAINING DOCUMENTATION

	EMPLOYEE	TITLE	SIGNATURE	DATE
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				