
	GILES CHEMICAL ~ PREMIER MAGNESIA		
	Company Form		
	Title: PM Sly Dust Collection System	Number: M16-PR-200-F061	
	Owner: Thomas Evans	Revision: 00	
	Effective Date: 05/20/2016	Page: 1 of 1	

For each of the items listed below please place a check in the **Completed** column as you complete that task. For any item that is not completed please place a check in the **Not Completed** column and give a brief explanation in the **Notes** section as to why it wasn't completed.

Items to be completed	Completed	Not Completed
Dust Collector Asset Tag #: 10763		
Check barrels. Empty if full.		
Remove filters and inspect gasket. Replace or repair if necessary.		
Remove dust build up from inside walls so that it falls into collection barrels.		
Inspect gaskets on hatch doors for leaks. Replace or repair as needed.		
Check all air lines and fittings for leaks. Replace or repair as needed.		
Blow out pressure gauge lines.		
Fan		
Check belt tension and wear		
Grease both bearings		
Check anchor bolts for tightness		

Notes:

Maintenance Signature: _____ Date: _____

Maintenance Supervisor: _____ Date: _____

Controlled Document

Only those quality documents viewed through the Giles Chemical electronic Documentation System are officially controlled. All other copies, whether viewed through another computer program or a printed version, are not controlled and, therefore, the Quality Unit at Giles assumes no responsibility for accuracy of the document