

	GILES CHEMICAL		
	COMPANY PROCEDURE		
	Lock Out Tag Out: Mix Pot Agitator	Page : 1 of 3	Revision : 00 Date : 10/30/2009
	Author: Mike Sonderman		Safety

Safety: All safety glasses and appropriate safety apparel is to be worn at all times.

Purpose or Objective: The purpose of this procedure is to define the process required to lock out the Mix Pot Agitator at the facility at 200 Brown St. Greendale IN.

Procedure: The proper process to lockout Mix Pot Agitator is as follows:

1. Notify all affected employees that the machine is being taken out of production.
2. Locate disconnect for Mix Pot Agitator
3. Turn disconnect for Mix Pot Agitator to the off position
4. Install multi-locking device on the disconnect
5. ID tag with name, date and time
6. Test start switch to ensure equipment is not operational

Proper procedure to return equipment to operation:

1. Make sure all work is complete and all tools and maintenance equipment has been removed from the machine.
2. Notify all affected employees that equipment is about to be put back into service.
3. Remove Id tag with name, date and time
4. Remove padlock-multi locking device from disconnect for Mix Pot Agitator
5. Turn disconnect handle to the on position
6. Ensure that Mix Pot Agitator is operating properly and available to be returned to production



**GILES CHEMICAL
COMPANY PROCEDURE**

Lock Out Tag Out: Mix Pot Agitator

Page : 2 of 3

Revision : 00
Date : 10/30/2009

Author: **Mike Sonderman**

Safety

TRAINING DOCUMENTATION

	EMPLOYEE	TITLE	SIGNATURE	DATE
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				

