

| | | |
|-------------------------------------|---|-------------------------------|
| GILES CHEMICAL CORPORATION | | |
| COMPANY PROCEDURE | | |
| Standard Operating Procedure | Page : 1 of 2 | Revision : Date : 02/12/07 |
| Author: Maintenance | Title: Lock Out Tag Out boiler room #1 Boiler | |

Safety: *All safety glasses and appropriate safety apparel is to be worn at all times.*

Purpose or Objective: *The purpose of this procedure is to define the process required to lock out the boiler room #1 Boiler at the main facility at 102 Commerce Street*

Procedure: *The proper process to lockout the boiler room #1 Boiler is as follows:*

1. *Notify all affected employees that the #1 Boiler is being taken out of production.*
2. *Locate disconnect for #1 Boiler*
3. *Turn disconnect to the off position*
4. *Attach multi lockout device with lock*
5. *ID tag with name, date and time*
6. *Test #1 Boiler to ensure it will not start*

Proper procedure to return equipment to operation:

1. *Make sure all work is complete and all tools and maintenance equipment has been removed from the machine.*
2. *Notify all affected employees that equipment is about to be put back into service.*
3. *Remove ID tag with name, date and time*
4. *Remove multi lockout device*
5. *Engage disconnect to the on position*
6. *Ensure that equipment is operational and available to be returned to production*

| | | | |
|-------------------------------------|---|---------------|-------------------------------|
| GILES CHEMICAL CORPORATION | | | |
| COMPANY PROCEDURE | | | |
| Standard Operating Procedure | | Page : 2 of 2 | Revision : Date : 02/12/07 |
| | Author: Maintenance Title: Lock Out Tag Out boiler room #1 Boiler | | |

TRAINING DOCUMENTATION

| | EMPLOYEE | TITLE | SIGNATURE | DATE |
|----|----------|-------|-----------|------|
| 1 | | | | |
| 2 | | | | |
| 3 | | | | |
| 4 | | | | |
| 5 | | | | |
| 6 | | | | |
| 7 | | | | |
| 8 | | | | |
| 9 | | | | |
| 10 | | | | |
| 11 | | | | |
| 12 | | | | |
| 13 | | | | |
| 14 | | | | |
| 15 | | | | |
| 16 | | | | |
| 17 | | | | |
| 18 | | | | |