

**GILES CHEMICAL ~ PREMIER MAGNESIA****Company Form**Title: **PM Fans**Number: **M14-PR-200-F053**Owner: **Rick Hall**Revision: **01**Effective Date: **06/30/2015**Page: **1 of 1**

For each Fan listed below that is serviced, please place a check in the **Completed** column. For any Fan that is not serviced, please place a check in the **Not Completed** column and give a brief explanation in the **Notes** section as to why it wasn't serviced.

Steps to complete Fan PM

Disconnect fan from power source.

Remove and clean cover.

Clean fan blades to remove any dust.

Clean outside of fan.

Inspect fan for any signs of rust.

Replace cover.

Reconnect fan to power source.

Fan Number	Location	Completed	Not Completed
1	Mounted to scale platform on Auto 1		
2	Above Manual Line 1 mounted to 2 nd Floor Office balcony		
3	Above Manual Line 2 mounted to 2 nd Floor Office balcony		
4	Mounted to beam for Auto 2 beside roll up door		
5	Mounted to beam for Auto 2 pack out beside roll up door		
6	Mounted to Auto 3 Hopper pointing to Auto 1 pack out		
7	Mounted to Auto 3 Hopper pointing to Auto 3 Operator		
8	Back Corner behind Carton Machine Main Hopper		
9	Mounted under Carton Machine Intermediate Hopper for Carton Magazine Loader		
10	Middle Warehouse beside electrical panels pointing at Birthing Station		
11	Carton Machine Pack Out Area behind Video Jet Room pointing at CM2 Packers		
12	Carton Machine Pack Out Area by Lab entrance pointing at CM1 Packers		
13	Maintenance Shop back wall		
14	Shipping/Receiving beside Dock E in corner		

Notes:

Maintenance Signature: _____ Date: _____

Maintenance Supervisor: _____ Date: _____

Controlled Document

Only those quality documents viewed through the Giles Chemical electronic Documentation System are officially controlled. All other copies, whether viewed through another computer program or a printed version, are not controlled and, therefore, the Quality Unit at Giles assumes no responsibility for accuracy of the document.