GILES CHEMICAL							
COMPANY PROCEDURE							
Standard Operating Procedure		Page	:	1 of 2	Revision Date	:	10/26/2007
Author: Selwyn Scoggin / Patrick Owen	Title: (01) I	Oryers					

## Personnel responsible:

Lead operator, Assistant Operator

## Safety:

Always wear steel toed shoes and safety glasses when in the manufacturing area.

#### **Summary:**

The dryers take the damp salt from the centrifuge and dry the surface moisture so the salt can be stored in a bag or super sack for an extended period of time without sticking.

#### **Procedure:**

#### A. Starting dryers:

- 1. Start dryer rotation by pressing dryer start buttons on MCC #1, and then pressing the start buttons on the Variable Speed Drives for the dryers.
- 2. Start the dryer dust collector fans. The Switches are at the back near each dust collector.
- 3. Start the dryer intake fans. The switches are at the back near the water recovery room.
- 4. Open steam control valve isolators, main steam valves and condensate valves to the heaters.
- 5. At the Monitoring System display, set the exit air temperature controls to 45 C.
- 6. Allow dryers to warm up for 30 min.
- 7. Blow down the condensate out of the radiators by opening the condensate blowdown valve for approximately 10 seconds on each dryer.
- 8. Confirm dryer temperature controls are adjusted properly.
- 9. Begin feed to the dryers and adjust temperature controls accordingly.

#### B. Normal operation:

- 1. Operators are to continually monitor the dryer operation and record the operating parameters.
- 2. The salt temperature range will be posted on the Doc System Manufacturing Screen.
- 3. Examine the condition of the salt and make adjustments as required.

GILES CHEMICAL							
COMPANY PROCEDURE							
Standard Operating Procedure	Page	:	2 of 2	Revision Date	:	10/26/2007	
Author: Selwyn Scoggin / Patrick Owen Title: (0)	1) Dryers						

#### C. Shutting down dryers:

- 1.
- Stop crystal feed to the dryers.

  Allow all salt in dryers to empty out into the discharge screw.

  Press Stop on the Variable Speed Drives.

  Shut off steam and condensate valves to heaters. 2.
- 3.
- 4.
- 5.
- Stop dryer inlet fans.
  Stop dryer dust collector fans. 6.

GILES CHEMICAL								
COMPANY PROCEDURE								
Standard	Operating Procedure	Page	:	3 of 2	Revision Date	:	10/26/2007	
Author:	Selwyn Scoggin / Patrick Owen Title: (01) 1	Oryers						

# TRAINING DOCUMENTATION

	EMPLOYEE	TITLE	SIGNATURE	DATE
1				
2				
3				
4				
5				
6				Č
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				