

Municipal Water Quality Report — Cedar Falls District

This report presents the results of routine water quality testing conducted across the Cedar Falls municipal water district during the first quarter of the year. Samples were collected from nine monitoring stations distributed throughout the distribution network.

Lead levels at all nine stations remained below the EPA action threshold of 15 parts per billion, with the highest reading recorded at Station 4 near the Elmwood Avenue pumping station at 6.2 parts per billion.

Chlorine residual levels averaged 1.1 milligrams per liter across the network, within the target range of 0.5 to 2.0 milligrams per liter set by the district's treatment guidelines.

A brief turbidity spike was recorded at Station 7 on February 3rd following heavy rainfall, reaching 1.8 NTU before returning to baseline within six hours. No boil-water advisory was required.

The district completed replacement of 1,400 feet of aging cast-iron piping along Birchwood Lane in March, part of an ongoing five-year infrastructure modernization plan.

Bacteriological testing across all stations returned negative results for total coliform and E. coli throughout the entire reporting period.

The next scheduled testing cycle begins in April, with two additional monitoring stations planned for installation in the newly annexed Fairview Heights subdivision.