

C	Minimum ventilation rate per Section § 121, Table 1-F.
E	Based on expected number of occupants or at least 50% of Chapter 10 1997 UBC occupant density
I	Must be greater than or equal to H, or use Transfer Air. Design outdoor air includes ventilation from supply air system & exhaust fans which Operate at design conditions
K	Must be greater than or equal to (H - I), and, for VAV, greater than or equal to (H - J).

November 1998

November 1998November 1998

CODE TABLES: Enter code from table below into columns above

DOCUMENTATION AUTHOR ROY DEHOBIS	SIGNATURE <i>Roy DeHobis</i>	DATE 11/12/80
--	---------------------------------	-------------------------

The Principal Mechanical Designer hereby certifies that the proposed building design represented in this set of construction documents is consistent with the other compliance forms and worksheets, with the specifications, and with any other calculations submitted with this permit application. The proposed building has been designed to meet the mechanical and energy requirements contained in the applicable parts of Sections 110 through 115, 120 through 124, 140 through 142, 144 and 145.

Please check one:

☒ I hereby affirm that I am eligible under the provisions of Division 3 of the Business and Professions Code to sign this document as the person responsible for it's preparation; and that I am licensed in the State of California as a civil engineer or mechanical engineer, or I am a licensed architect.

☐ I affirm that I am eligible under the exemption to Division 3 of the Business and Professions Code by Section 5537.2 of 5373.2 to sign this document as the person responsible for its preparation; and that I am a licensed contractor performing this work.

☐ I affirm that I am eligible under the exemption to Division 3 of the Business and Professions Code to sign this document because it pertains to a structure or type of work described pursuant to Business and Professions Code sections 5537, 5538, and 6737.1.

PRINCIPAL MECHANICAL DESIGNER-NAME ROY DEHOBBI	SIGNATURE <i>[Signature]</i>	DATE 11/12/00	LIC # 15082
--	---------------------------------	-------------------------	-----------------------

MECHANICAL MANDATORY MEASURES

Indicate location on plans of Note Block for Mandatory Measures _____

INSTRUCTIONS TO APPLICANT

Consultants

RENOVATION PROJECT
FOR
SAINT EDMUND'S
EPISCOPAL CHURCH
1175 SAN GABRIEL BLVD., SAN MARINO, CA., 91108-8048

STAMPSREVISIONS

DESCRIPTION	DATE	BY
PLAN CHECK	1/10	

PROJECT NUMBER	3000
----------------	------

SCALE AS NOTED

PRINTED	11/14/2000
---------	------------

MECHANICAL FORMSSHEET

M-8

34 OF 44