

ELECTRIC SYMBOLS

- CEILING OUTLET
- BRACKET OUTLET
- RECESSED FIXTURE
- FLOODLIGHT DIRECTION OF BEAM
- SINGLE POLE SWITCH 4'-6"
- THREE WAY SWITCH 4'-6"
- MANUAL MOTOR STARTER
- CONVENIENCE RECEPTACLE 11-0" OR AS MARKED
- FLOOR BOX AND RECEPTACLE
- MOTOR OUTLET
- PANELBOARD
- CONDUIT CONCEALED IN WALL OR ABOVE CEILING
- CONDUIT BELOW FLOOR OR UNDERGROUND
- CONDUIT EXPOSED
- SWITCH CONTROL
- CONDUIT UP OR DOWN AS MARKED
- DISCONNECT SWITCH
- THERMOSTAT OUTLET 5'-0"
- JUNCTION BOX
- 1/2" CONDUIT
- 3/4" CONDUIT
- 1" CONDUIT

FEEDER SCHEDULE									
FEEDER NO.	CONNECTION	CONN. LOAD	FEEDER VOLTS	CONDUCTOR SIZE	CONDUIT SIZE	PROTECTION			
FROM	TO	H.P. AMPS	LENGTH	PHASE	NO. & SIZE	%	POLES	AMPS	
LA	MAIN SW. TO PANEL "A"	17.4	40'	120/240-1φ	3-#4/0	2 1/2	30	225	
LB	" " " " " " " "	9.3	50'	120/240-1φ	3-#2	1 1/4	15	100	
LC	" " " " " " " "	4.9	90'	120/240-1φ	3-#4	1 1/4	15	70	

1. FEEDER LENGTH IN SCHEDULE ARE APPROXIMATE FOR VOLTAGE DROP CALCULATION ONLY AND ARE NOT FOR MATERIAL PURPOSES

PANEL "C" IN MUSIC ROOM WEST SIDE OF ENTRY HALL TO PARISH HALL

PANEL "C" SCHEDULE

LOCATION - ROOM #103A
FEEDER ENTRY - BOTTOM

SURFACE MOUNTED
120/240 V. 1φ 3W S/N

CIR.	BREAKER	OUTLETS	WATTAGE						
NO.	POLES	AMPS	LTS REC.	MISCAL.	BUSSES	A	B	C	D
1	1	20	6		1080				ENTRANCE, 12, 104, & 106A
2			3		540				107
3			7		1260				102, 103A, 105, 106 & ENTRANCE
4				ELEC. HTR	750				107
5			3		1080				102, 106, 106A & 107
6			3		1110				102
7				2 HEATERS	1500				107
8			2		360				102
9				SPACE	1000				
10				"	1000				
11	1			"	1000				
12	1	20		"	1000				
WATTS/BUSSES					5510	5570			
TOTAL WATTAGE = 11,680 = 49 AMPS AT 240V.									

ABBREVIATIONS

- C.O. CONDUIT ONLY
- M.H. MOUNTING HEIGHT TO BOTTOM OF FIXTURE
- 4'-6" HEIGHT ABOVE FLOOR TO E. OF OUTLET

NOTES

- WHERE CONDUIT RUNS ARE MARKED 2-12, 3-12 ETC. THE FIRST NUMBER INDICATES THE NUMBER OF WIRES AND THE SECOND NUMBER INDICATES THE SIZE OF THE WIRES.
- WHERE NO NUMBERS ARE SHOWN ON ONE HALF INCH CONDUIT PROVIDE TWO NO. 12 WIRES.
- ARROWS ON CONDUITS INDICATE RUNS TO PANELS AND TERMINALS.
- OUTLETS MARKED AS FOLLOWS INDICATE:
 - A TYPE OF LIGHTING FIXTURE
 - 2-60, 150 ETC. WATTAGE OF LAMPS.
 - B-2 CIRCUIT NUMBER

PANEL AT REAR OF PARISH HALL

PANEL "A" SCHEDULE									
LOCATION - ROOM #102 FEEDER ENTRY - BOTTOM					SURFACE MOUNTED 120/240V. 1φ 3W. S/N				
CIR.	BREAKER	OUTLETS		WATTAGE		DESTINATION			
NO.	POLES	AMPS	LTS	REC.	MISCEL.	BUSSES	A	B	ROOM NUMBERS
1	1	20	2				1800		#102
2			2				1800		#102
3			2					1800	#102
4			2					1800	#102
5			5				900		#102 & EXTERIOR LITES
6		↑	10				1800		#101 & #102
7		20	6					1080	E-101
8		30			1 H.P.			1920	E-101 DISHWASHER
9		20	6				1080		E-101
10		20			1/3 H.P.		850		E-101 REFRIGERATOR
11		30			3/4 H.P.			1660	E-101 DISPOSAL
12		20			1/2 H.P.			1117.5	KITCHEN EXH. FAN ON ROOF
13				4			720		#101 & #102
14				1			1000		E-101
15				2			1070		E-101 & E-108
16				1			1000		E-101
17				1			1000		E-101
18				1			1000		E-101
19				1			1000		E-101
20				1			1000		E-101
21				1			1000		E-101
22				1			1000		E-101
23					SPARE		1000		
24					↑		1000		
25							1000		
26	1	20			SPARE		1000		
27	1	20			1/4 HP			670	#101 FURNACE FAN
28	2	50					4500	4500	E-101 H.W. HEATER
29									
30									
WATTS/BUSSES						21,430	21,275		
TOTAL WATTAGE = 41,705 = 174 AMPS AT 240V.									

180
41720

W.P. TERMINATING PULL BOX
SIZED AS REQUIRED BY S.C.
E.C.C.

NOTE:
IT IS INTENDED THAT ALL CONDUIT IN THE
KITCHEN BE CONCEALED. EXPOSED CONDUIT
OR WIREMOLD SHALL ONLY BE RUN WITH
SPECIFIC APPROVAL OF THE ARCHITECT.

Circuit #4-13 will take a total of 720 watts or 480 watts and have 4 outlets

Wired # C-6 will take a total of 1110 watts or about 10 amps. have 3 outlets or 370 watts per outlet

C-6 will take a total of 1080 watts or 9 amps. after outlets in closets and room etc.

SEE NEXT PAGE

SEE REVISED PART OF GROUND FLOOR PLAN DATED 3-25-66, SHEET E-3
GROUND FLOOR
SCALE: 1/4" = 1'-0"

REVISIONS

3/25/66	PARISH HALL ADDITION
3/25/66	FOR ST. EDMUND'S EPISCOPAL CHURCH
3/25/66	1175 SAN GABRIEL BLVD. SAN ANTONIO, CALIFORNIA

REVISED MARCH 25, 1966

JOHN M. GARY	BREO FREEMAN
CONSULTING ENGINEER	ARCHITECT
407 COMMERCIAL CENTER STREET	45 SOUTH MARENGO
BEVERLY HILLS, CALIFORNIA	PASADENA 1, CALIFORNIA

DATE: 12-30-65

928
E-2
OF 5