



1a Startforth Road, Riverside Park, Middlesbrough TS2 1PT.
Tel: 01642 247337 Email: info@he-woolley.co.uk
www.fireriskassessment.com

No. 38414



Certificate of Inspection of Fire Alarm

We being the competent persons responsible for the servicing of the fire alarm system, particulars set out below certify that the said work for which we have been responsible complies to the best of our knowledge and belief with the recommendations of Clause 45 of BS 5839-1:2017 periodic service except for the variations stated in this certificate.

Customer <u>Infratec</u>	Date <u>26/6/23</u>
Address <u>8 Easter Park, Riverside Park Ind Est</u>	Order No.
<u>Middlesbrough</u>	Account Ref.
Invoice Address if different from above	Invoice No.

CALL OUT <input type="checkbox"/>	FIRE ALARM		LAST SERVICE DATE
OUT OF HOURS CALL OUT <input type="checkbox"/>	SERVICED 25% <input type="checkbox"/> 50% <input type="checkbox"/> 100% <input checked="" type="checkbox"/>		NEXT SERVICE DATE <u>Dec 23</u>
ADDITIONAL HOURS <input type="checkbox"/>	WHOLE SYSTEM <input checked="" type="checkbox"/> SUB SYSTEM <input type="checkbox"/>		CURRENT BAFE CERTIFICATE OF COMPLIANCE YES <input type="checkbox"/> NO <input type="checkbox"/>

VARIATIONS FROM THE RECOMMENDATIONS OF CLAUSE 45: <input type="checkbox"/> 12 MONTHLY SERVICE INTERVALS <input type="checkbox"/> MISSING DEVICES <input type="checkbox"/> BELLS NOT TESTED Relevant details of the work carried out and the faults identified have been entered in the system log book <input type="checkbox"/> During the past 12 months false alarms have occurred The above number of false alarms equates to per 100 automatic fire detections per annum. For type M systems, enter N/A.	SPARES	CONV.	ADDR.	NOTES
	Panel			
	Detector - smoke			
	Detector - heat			
	Detector - base			
	Sounder			
	Call Point			
	Call Point IP67			
	Battery 1amp-3amp	<u>2</u>		<u>2V 2.6L</u>
	Battery 3amp-7amp			
	Battery 12amp-24amp			
	Spare Glass			
	Aspirator Filter			
	Door Magnet			

NOTES:
Replaced batteries in Fire Panel
Panel in Unit 8 only controls the Call Points + the SNO ADS FAP + Warehouse Wall.
Detection in Unit 8 was originally part of Unit 9+10 fire system. +
Unit 8 Detection is currently disconnected + not in use.

- HE Woolley Ltd is not responsible for any installation or alteration made by others at any time to any equipment included in this certificate. The certificate is subject to our conditions of sale, copies of which are available upon request.
- It is the client's responsibility to ensure that a weekly test of the alarm system and a monthly check of the emergency lights are performed by the nominated fire/safety officer in order to ensure correct operation. The system log book should be completed accordingly.

Engineer's Signature <u>[Signature]</u>	Print <u>P. HUTCHINSON</u>	Total	
Customer's Signature		VAT	
Print Name		Total	
Position	Date <u>26/6/23</u>		