



1a Startforth Road, Riverside Park, Middlesbrough TS2 1PT.
Tel: 01642 247337 Email: info@he-woolley.co.uk
www.fireriskassessment.com



Emergency Lighting
Periodic Inspection and Test

Customer	Intratec -	Date	28/10/24
Address	Units 8-9 Easton Park, Barton Rd Middlesbrough, TS2 1RY	Order No.	
Invoice if different from above		Account Ref.	
	Address	Invoice No.	

I/we hereby certify that the emergency lighting installation at the above premises has been inspected/tested by me/us in accordance with the schedule below, and to the best of my/our knowledge and belief with BS 5266-1:2011, except for the variations, if any, stated in this certificate.

Annual Inspection and Test ☒ 1 Hour Burn ☐ 3 Hour Burn ☒ Remedial Work ☐

RESULTS OF EMERGENCY LIGHT SERVICE		Yes	No
Regular test results logged		✓	
Installation in a satisfactory condition		✓	
Central battery system			✓
Self-contained luminaires and signs		✓	
Devices operate on mains failure		✓	
Maintained devices		✓	
Non-maintained devices		✓	
Defective devices		✓	
REMEDIAL WORK / PARTS SUPPLIED & FITTED		Quantity	
Twin Spot Light			
Bulkhead Light			
Battery			
8w Tube			

NOTE: Because of the possibility of failure of the supply to the normal lighting occurring shortly after a period of testing, all tests should be undertaken at times of minimal risk. Alternatively, suitable temporary arrangements should be made until the batteries are recharged.

Comments and Variations, if any, from BS 5266-1:2011

Unit 8 - All OK
Unit 9 - 1x failed WC circular recessed

Engineer's Signature	Print P. Hutchinson	Total	
Customer's Signature		VAT	
Print Name		Total	
Position	Date 28/10/24		