

Certificate Number:

HET-CM-6163

1. DESCRIPTION OF THE MINOR WORKS

Client address:	Infratec Uk Ltd Easter Park, Unit 8-9 Barton Road, Middlesbrough, TS2 1RY	Installation address:	Infratec Uk Ltd Easter Park, Unit 8-9 Barton Road, Middlesbrough, TS2 1RY
-----------------	---	-----------------------	---

Description of the minor works:

- 1): Replace 3 high level flood lights
- 2): Replace 5 strip lights under mez
- 3): Replace office bulkhead
- 4): Install 2 new bulkheads to 1st floor, 1 in toilet and 1 in bathroom
- 5): N/A

Details of departures from BS 7671:2018 as amended to 2022 for the circuit altered or extended (Regulation 120.3, 133.1.3 and 133.5). Where applicable, a suitable risk assessment(s) must be attached to the Certificate:

None

Date minor works completed: 13/12/2023 Risk assessment attached: N/A

Comments on (including any defects observed in) the existing installation (Regulation 644.1.2):

N/A

2. PRESENCE AND ADEQUACY OF INSTALLATION EARTHING AND BONDING ARRANGEMENTS

System type and earthing arrangements:	TN-C-S	N/A	TN-S	N/A	TT	N/A				
Earth fault loop impedance at distribution board (Z _{db}) supplying the final circuit:	N/A					Ω				
Presence of adequate main protective conductors:	Earthing Conductor			N/A						
Main protective bonding conductor(s) to:	Water	N/A	Gas	N/A	Oil	N/A	Structural Steel	N/A	Other:	N/A

3. DECLARATION

I/we certify that the work covered by this certificate does not impair the safety of the existing installation and the work has been designed, constructed, inspected and tested in accordance with BS 7671:2018 amended to 2022 and that to the best of my/our knowledge and belief, at the time of my/our inspection, complied with BS 7671 except as detailed in Section 1 above.

Trading Title:	Hawkesworth				
Address:	Guidance house York road Thirsk		Registration Number (if applicable):		609910000
	Postcode: YO7 3BT		Telephone Number:		01845 524498
Name:	Craig McKenna	Position:	Electrician	Signature:	C. McKenna
				Date:	13/12/2023

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE GUIDANCE FOR RECIPIENTS

(to be appended to the Certificate)

This Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671.

You should have received an 'original' Certificate and the person that issued the certificate should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a copy of it, to the owner. A separate Certificate should have been received for each existing circuit on which minor works have been carried out. This Certificate is not appropriate if you requested the person that issued the certificate to undertake more extensive installation work, for which you should have received an Electrical Installation Certificate.

The Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the minor electrical installation work carried out complied with the requirements of BS 7671 at the time the Certificate was issued.

For safety reasons, the electrical installation will need to be inspected at appropriate intervals by a skilled person or person(s), competent in such work. Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or Test. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.